



GENERAL NOTES

1. DUCTILE-IRON PIPE SHALL BE CEMENT LINED PUSH-ON TYPE JOINT, THICKNESS CLASS 2, WITH DUCTILE-IRON OR CAST IRON MECHANICAL-JOINT FITTINGS.
2. THE LOCATION OF UNDERGROUND UTILITIES IS NOT GUARANTEED. CONTRACTOR SHALL VERIFY THE LOCATION OF UNDERGROUND UTILITIES WITH THE UTILITY OWNERS PRIOR TO DOING ANY WORK IN THE VICINITY. THE CONTRACTOR SHALL COMPLY WITH THE REQUIREMENTS OF UTILITY OWNERS PRIOR TO DOING ANY WORK IN THE VICINITY, AND SHALL ALSO COMPLY WITH THE REQUIREMENTS OF UTILITY OWNERS REGARDING NOTICE OF WORK AND PROTECTION OF UTILITIES.
3. TEST PITS SHALL BE EXCAVATED AT CROSSINGS OF UTILITIES TO DETERMINE LOCATION AND DEPTH OF UTILITIES SUFFICIENTLY IN ADVANCE OF WATER MAIN CONSTRUCTION TO PERMIT ADJUSTING WATER MAIN LOCATION BY DEFLECTION OF THE PIPE WHERE POSSIBLE. TEST PITS SHALL ALSO BE EXCAVATED WHERE REQUIRED BY THE ENGINEER AND WHERE NECESSARY TO DETERMINE SIZE REQUIREMENT.
4. THE PROPOSED PIPELINE, VALVE, AND HYDRANT LOCATIONS ARE APPROXIMATE. FINAL LOCATION WILL BE DETERMINED AT THE TIME OF CONSTRUCTION. THE APPROXIMATE LOCATION OF THE PROPOSED PIPELINE IS INDICATED ON THE PLANS, BUT THE LOCATION WILL BE GOVERNED BY THE ACTUAL LOCATION OF THE UNDERGROUND UTILITIES, OR OTHER CONTROLLING FACTORS.
5. MINIMUM PIPE COVER SHALL BE 4'-6" EXCEPT AS OTHERWISE SPECIFIED.
6. ALL FITTINGS SHALL BE BACKED UP WITH CONCRETE AS INDICATED ON SHEET 2. WHERE ADEQUATE BACKING CANNOT BE OBTAINED, SUITABLE TIE RODS AND CLAMPS SHALL BE USED.
7. DIRECTION OF ROTATION OF OPERATING NUTS ON VALVES SHALL BE IN ACCORDANCE WITH THE HARRISVILLE FIRE DISTRICT STANDARDS.
8. ANY EXISTING PIPE OR UTILITY DAMAGED BY THE CONTRACTOR'S OPERATIONS SHALL BE REPAIRED IMMEDIATELY BY THE CONTRACTOR AT NO COST TO THE OWNER.
9. ALL PAVED SURFACES AND CURBS REMOVED OR DAMAGED BY WORK UNDER THIS CONTRACT SHALL BE RESTORED OR REPLACED TO A CONDITION AT LEAST EQUAL TO THAT EXISTING PRIOR TO THE BEGINNING OF WORK.
10. PRIOR TO ORDERING TAPPING SLEEVES AND VALVES, THE CONTRACTOR SHALL VERIFY SIZE AND DIAMETER OF ALL PIPES WHERE CONNECTIONS ARE TO BE MADE.

VOID

RECORD DRAWING

NUMBER	DATE	MADE BY	CHECKED BY	DESCRIPTION
REVISIONS				

DRAWN BY
A. Latina

DEPT. CHECK
Rj Marshall

PROJ. CHECK
Rj Marshall

CHARLES Y. HITCHCOCK, JR.
No. 1354
REG. PROF. ENGR. R.I. NO. 1054

MICHAEL EUGENE GWILL
No. 3620
REG. PROF. ENGR. R.I. NO. 3620

M&E METCALF & EDDY, INC. / ENGINEERS
BOSTON / NEW YORK / PALO ALTO / CHICAGO

Michael E. Hill
REG. PROF. ENGR. R.I. NO. 1054
DATE 6-27-77

Michael E. Hill
REG. PROF. ENGR. R.I. NO. 3620
DATE 6-22-77

SCALE:
AS SHOWN

UNLESS OTHERWISE NOTED OR CHANGED BY REPRODUCTION

TOWN OF BURRILLVILLE, RHODE ISLAND
BOARD OF SEWER COMMISSIONERS

WASTEWATER TREATMENT FACILITIES

WATER MAIN PLAN

CIVIL

JOB 4869

FILE NO. H-68967-1

CONTRACT 76-1

SHEET C-7