



ALSO SEE SHEETS E-11 AND E-12

ELEVATION
STAIR NO. 3
SCALE: 1/4"=1'-0"

- NOTES:
1. FOR SYMBOLS AND GENERAL NOTES SEE SHEET E-1.
 2. FOR INTERCOM RISER DIAGRAM SEE SHEET E-14.
 3. FOR PANELBOARD SCHEDULE OF "PA", "PB" AND "PC" SEE SHEET E-20 AND E-21.
 4. OUTLET, SWITCH, JUNCTION, PULL AND TERMINAL BOXES SHALL BE PROVIDED AS INDICATED ON EQUIPMENT ENCLOSURE SCHEDULE ON SHEET E-20.
 5. FOR LIGHTING FIXTURE TYPE AND DETAILS SEE APPENDIX "B" OF THE SPECIFICATIONS.
 6. ALL CONDUITS TO LIGHTING FIXTURES IN AREAS WITH HUNG CEILINGS SHALL BE RUN CONCEALED ABOVE HUNG CEILINGS, CONDUIT RUNS TO RECEPTACLES AND SWITCHES SHALL BE CONCEALED IN FLOOR OR WALL SLABS.
 7. ALL RECEPTACLES IN THIS WING SHALL BE CONNECTED TO PANEL "PB".

RECORD DRAWING

DRAWN BY <i>S. W. Paulson</i>				DEPT. CHECK <i>A. F. Benoit</i>		PROJ. CHECK <i>R. J. Marshall</i>		MICHAEL EUGENE GRILLI REG. PROF. ENGR. No. 3620		M&E METCALF & EDDY, INC. / ENGINEERS BOSTON / NEW YORK / PALO ALTO / CHICAGO David W. Paulson REG. PROF. ENGR. No. 18107		SCALE: 0 4 8 12 SCALE IN FEET SCALE 1/4" = 1'-0"		TOWN OF BURRILLVILLE, RHODE ISLAND BOARD OF SEWER COMMISSIONERS WASTEWATER TREATMENT FACILITIES OPERATIONS BUILDING FIRST FLOOR PART II LIGHTING ELECTRICAL		JOB 4868 FILE NO. H-69060-1 SHEET E-13	
NUMBER	DATE	MADE BY	CHECKED BY	REVISIONS		DESCRIPTION											