



- NOTES:
1. BLOWER NO. 3 AND 4 HAS A CAPACITY OF 400 SCFM AT 6 PSIG AND A MINIMUM CAPACITY OF 100 SCFM.
 2. BLOWER NO. 2 HAS A CAPACITY OF 100 SCFM AT 4 PSIG AND A MINIMUM CAPACITY OF 40 SCFM.
 3. FOR CONTINUATION OF PIPING SEE SHEET C-4.
 4. HEAT EXCHANGERS ADDED FOR BLOWERS NO. 1 THROUGH NO. 4.

RECORD DRAWING

DRAWN BY: <i>Michael E. Gull</i> DEPT. CHECK: <i>Michael E. Gull</i> PROJ. CHECK: <i>R. J. Marshall</i>						M&E METCALF & EDDY, INC./ENGINEERS BOSTON / NEW YORK / PALO ALTO / CHICAGO <i>Michael E. Gull</i> 6/23/77 REG. PROF. ENGR. 3-27-77		SCALE: SCALE IN FEET SCALE 1/4" = 1'-0"		TOWN OF BURRILLVILLE, RHODE ISLAND BOARD OF SEWER COMMISSIONERS WASTEWATER TREATMENT FACILITIES PUMP GALLERY - SECTION III MECHANICAL		JOB 4868 FILE NO. H-69025-1 SHEET M-16																										
<table border="1"> <thead> <tr> <th>NUMBER</th> <th>DATE</th> <th>MADE BY</th> <th>CHECKED BY</th> <th>DESCRIPTION</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>				NUMBER	DATE	MADE BY	CHECKED BY	DESCRIPTION																					REVISIONS									
NUMBER	DATE	MADE BY	CHECKED BY	DESCRIPTION																																		