FIRST FLOOR PLAN

PART PLAN - LABORATORY

SECTION (6/M-21)

SECTION (7/M-21)

NOTE:
FOR EXACT LOCATION OF REGISTERS AND DIFFUSERS REFER TO ARCHITECTURAL REFLECTED CEILING PLANS.

NOTE: FOR ADDITIONAL PIPE SIZING IN LAB. SEE RISER DIAGRAMS DWGS. M-25 & M-26

NOTE: TYPICAL INSECT SCREENING TO BE 18×14 ALUMINUM MESH. VERIFY IN FIELD.

MOTOR OPERATED DAMPER IN DUCT COLLAR WITH REMOVABLE INSECT SCREEN. FULL SIZE OF LOUVER OVER DOOR.

MOTOR OPERATED DAMPER IN DUCT COLLAR W/REMOVABLE INSECT SCREEN. FULL SIZE OF LOUVER, 4'-0"×3'-4" M.O. DAMPER

RECORD DRAWING

NUMBER	DATE	MADE BY	CHECKED BY	DESCRIPTION
1	12-7-77	C DONOVAN	R E WOLF	CHANGED DUCTS TO ACCOMODATE MOVED MCC'S.
				ADDED EFW & REV. CW SWS & DRAINAGE SYSTEM.

REVISIONS

DRAWN BY

DEPT. CHECK

PROJ. CHECK

METCALF & EDDY, INC. / ENGINEERS
BOSTON · NEW YORK / PALO ALTO / CHICAGO

REG. PROF. ENGR., MASS. NO. 6851, 6/27/77 DATE

REG. PROF. ENGR. R.I. NO. 1620, 6-27-77 DATE

SCALE:
0 4 8 12
SCALE IN FEET
SCALE 1/4" = 1'-0"

UNLESS OTHERWISE NOTED OR CHANGED BY REPRODUCTION

TOWN OF BURRILLVILLE, RHODE ISLAND
BOARD OF SEWER COMMISSIONERS

WASTEWATER TREATMENT FACILITIES

OPERATIONS BUILDING
FIRST FLOOR PLAN I

H.V.A.C. & PLUMBING

JOB 4868

FILE NO. H-69948-1

SHEET M-21

MAKEPEACE P-1457