


CONNECTICUT RIVER FLOOD CONTROL

**CHICOPEE FALLS
LOCAL PROTECTION PROJECT**

CHICOPEE RIVER, MASSACHUSETTS

DESIGN MEMORANDUM NO. 6

PUMPING STATIONS



U.S. ARMY ENGINEER DIVISION, NEW ENGLAND
CORPS OF ENGINEERS WALTHAM, MASS.

APRIL 1963

115

ENOCW-EX (10 Apr 63)

3rd Ind

SUBJECT: Chicopee Falls Local Protection Project, Chicopee River,
Massachusetts - Design Memorandum No. 6 - Pumping Stations

Office, Chief of Engineers, Washington D. C. 20315, 2 Aug 1963

TO: Division Engineer, U. S. Army Engineer Division, New England

The actions taken in regard to the CCE comments contained in the preceding CCE 1st indorsement dated 10 May 1963 are satisfactory.

FOR THE CHIEF OF ENGINEERS:

2 Incls

1. Plate No. 7 (marked
in green)
2. Cy of Spec - Retention Doors

HERACE A. JOHNSON

Acting Chief, Engineering Division
Civil Works

Mrs. Coffin
Messrs. Coffin/Towler/Haines/Whittemore/1c/515

MEMO (10 Apr 63)

2nd Ind

SUBJECT: Chicopee Falls Local Protection Project, Chicopee River,
Massachusetts - Design Memorandum No. 6 - Pumping Stations

U.S. Army Engineer Division, New England, Waltham, Mass. 27 July 1963

TO: Chief of Engineers, AFM: , Washington, D. C.

Submitted below are comments, referenced to paragraph numbers of 1st Indorsement.

Par. 2a. Add to Paragraph 7. - "This pumping station is located at the toe of slope on the land side of an earth dike. Seepage beneath the pumping station is controlled by features of the adjoining dike section and by the minimum depth of adjoining fill which equals approximately the hydraulic head, ensuring the tail water at the top of the fill. The adjoining dike section provides for a foundation cut-off and also for relief of foundation seepage pressures by the large gravel fill section along the north and south walls of the pumping station".

Par. 2b. Rock anchors at the Main Street pumping station have been deleted.

Par. 2c. The bar racks have been checked and corrected to agree with the requirements set forth in paragraph 2c of W 1110-2-3104. Spacing of bars will be 1-3/4 inches.

Par. 2d. Contract specifications require hydraulic starters.

Par. 2e(1). Contract specifications permit either mixed flow or propeller type pumps and the specified heads are as requested.

Par. 2e(2). The gravity conduit discharge gates can readily serve as bypass during marginal inflow. Moreover, the pump engines will be equipped with governors permitting adjustable speed settings, to accommodate variable flow conditions. As agreed in recent telephone discussion between Messrs. W. Farrar and E. Croden, additional bypass provisions are not required.

Par. 2e(3). Pump intake areas have been approximately doubled.

Par. 2f. Electric motor sluice gate operators were provided on all pumping stations previously constructed by the Corps in Chicopee. City desires similar arrangement at these stations to conserve manpower during flood emergencies. Savings resulting from use of manual operators and portable hoist are not considered sufficient to justify change.

MEMOR (10 Apr 63)

2nd Ind

5 July 1963

SUBJECT: Chicopee Falls Local Protection Project, Chicopee River,
Massachusetts - Design Memorandum No. 6 - Pumping Stations

Par. 2c. Fuel tanks have been changed to above ground installation.

Par. 2d. Rehumidifiers have been added in each station.

Par. 2e. The pumping station entrance doors will be approved industrial steel paneled doors as called for in the contract plans and specifications.

Par. 2(1). The suggested reduction of 1 1/2 feet on the riverside base cannot be made as this would shorten the creep ratio of the adjacent toe walls. The large extension on the riverside matches the heel extension on both adjacent toe walls. Inasmuch as the riverside distance cannot be shortened there is no apparent need for extending the base on the landside out under the 30-inch RFP pipe.

Par. 2(2). The use of steel channels for stop lag slots is undesirable. The slots formed into the concrete are easy to form, will require no maintenance, and have little likelihood of being used. The suggested channels will require maintenance that may be difficult due to possible water conditions at the lower part and will protrude out into the pump discharge which is not considered desirable.

Par. 2f. Investigation has been made for additional steel required to resist the application of passive pressure to the landside wall.

FOR THE DIVISION ENGINEER:

2 Incls
no

JOHN W. LESLIE
Chief, Engineering Division

cc: Mr. Leslie
Mr. Groden
Mr. Coffin
Mr. Fowler
Mr. Haines
Mr. Whittemore
Eng. Div. File

ENGCON-KZ (10 Apr 63)

1st Ind

SUBJECT: Chicopee Falls Local Protection Project, Chicopee River,
Massachusetts - Design Memorandum No. 6 - Pumping Stations

Office, Chief of Engineers, Washington 25, D. C., 10 May 1963

TO: Division Engineer, U. S. Army Engineer Division, New England

1. Reference is made to NED letter dated 19 April 1963, same subject.
2. Design Memorandum No. 6 is approved subject to changes included in NED letter referenced in paragraph 1 above, and to the following comments:
 - a. Paragraph 7 should be expanded to discuss the means of controlling underseepage.
 - b. Paragraph 18, last sentence. Consideration should be given to deleting rock anchors at the Main Street station since the passive pressure of the deep earth embankment is adequate to develop resistance to the unbalanced horizontal forces.
 - c. Paragraph 19. Bar racks should be designed in accordance with the criteria set forth in subparagraph 8b of EM 1110-2-3104.
 - d. Paragraph 21. The engines should be provided with hydraulic starters as described in paragraph 12b(2) of EM 1110-2-3105.
 - e. Paragraph 24.

(1) The contract specifications should permit the furnishing of axial flow pumps with either the mixed flow or propeller type of impeller. In specifying the performance for the pumps to be installed in the Main Street Station, the specification should state: "Rating. Each pump shall be capable of operating and delivering not less than 9900 gpm at a pool to pool head of 7.7 feet and not less than 9000 gpm at a pool to pool head of 19.4 feet." In this case, as the pumps discharge directly into the river, pool to pool head is the difference in elevation between the water surface at minimum seep and the water surface of the river at low water stage or at design flood. It is not considered that the pumps will be required to operate at river stages above design flood. For the Oak Street Station, the specification should state: "Rating. Starting with a static head of 11.1 feet each pump shall be capable of operating and delivering not less than 8600 gpm at a pool to pool head of ___ feet and starting with a static head of 21.0 feet each pump shall be capable of operating and delivering not less than 7000 gpm at a pool to pool head of ___ feet." Static head is the difference in elevation between the water surface at minimum seep and the river water surface at low water or at design flood when there is no flow through the

ENGOW-EZ (10 Apr 63)

1st Ind

10 May 1963

SUBJECT: Chicopee Falls Local Protection Project, Chicopee River,
Massachusetts - Design Memorandum No. 6 - Pumping Stations

outfall. Pool to pool head is the sum of the static head and the losses for a given flow between the discharge chamber and the river when there is flow through the outfall. A curve giving these losses for various flows should be included in the specification.

(2) As previously pointed out, a diesel engine is not too satisfactory a pump drive for those pump stations that have limited pump capacity (such as in the instant case) and the pumps will be required to cycle "ON" and "OFF" every four to six minutes when the flows are less than the design flow. To alleviate this undesirable operating condition, a station bypass should be provided as described in subparagraph 6d of EM 1110-2-3102. The usable pump volume of the Main Street Station could be increased by the use of a longer pump column that would place the pump intake bell at the accepted distance above the pump floor.

(3) The size of the pump intakes should be increased.

f. Paragraph 26. All sluice gates should be provided with manually operated type floorstands and a portable power-driven wrench provided at each station for the operation of the sluice gates. Information covering this feature is given in paragraph 18c of EM 1110-2-3105, 10 December 1962.

g. Paragraph 27. In order to prevent damage to the fuel storage tank from corrosion, it should be placed in a covered concrete pit rather than buried in the ground. The pit should be provided with an adequate drain, the tank painted with a cold applied coal tar, placed on saddles and anchored, and the pit filled with coarse sand or pea gravel.

h. Paragraph 30. In view of the type heating system to be installed, dehumidification equipment should be provided to remove moisture from the station during inoperative periods. Information covering the design of the dehumidification facility is covered in paragraph 22 of EM 1110-2-3105.

i. Plate No. 6. Inclosed (Inclosure No. 2) is a copy of the specification for pumping station entrance doors to be used as a guide in the preparation of the specification covering doors for the subject pumping stations. This type door has been used by the St. Louis District in most of the pumping stations constructed as a part of the St. Louis Project.

j. Plate No. 7.

(1) Since it will be necessary to extend the excavation on the eastern side of the pump station to include the 30-inch R.C.P. bypass main, consideration should be given to extending the base slab approximately 8 feet

ENGCCW-KZ (10 Apr 63)

1st Ind

10 May 1963

SUBJECT: Chicopee Falls Local Protection Project, Chicopee River,
Massachusetts - Design Memorandum No. 6 - Pumping Stations

outside of the station on this side so as to permit a reduction of approximately 14 feet in the long slab extension on the other side and to avoid encroachment of the excavation into the river channel. No major change in slab thickness or reinforcement is considered necessary.

(2) Stop log slots should be constructed using steel channels as indicated in green on the drawing (Inclosure No. 1). This type of slot should also be used on the Oak Street Station.

k. Page A-28. Consideration should be given to increasing the load on the landside wall to include passive pressure from the external earth to resist sliding.

FOR THE CHIEF OF ENGINEERS:

2 Incls

1. Plate No. 7 (marked in green)
2. Cy of Spec - Entrance Doors
(Incl 1 w/d)

W. E. Joyce
For

WENDELL E. JOYCE
Chief, Engineering Division
Civil Works

17 APRIL 1963

MEMO

SUBJECT: Chicago Falls Local Protection Project, Chicago River, Massachusetts - Design Memorandum No. 6 - Pumping Stations

EFH

TO: Chief of Engineers
ATTN: ~~MEMORANDUM~~
Department of the Army
Washington 25, D. C.

1. In reply to our letter dated 20 April 1963, submitting the subject memorandum. Please note the corrections which should be made therein

Page 9 - Paragraph 22 is deleted in its entirety and the following is substituted therefore: "Alternate Pump Drives. A cost comparison to determine the most economical pump drive was made. Based on these comparisons as shown below, Diesel engine drive was selected".

Page 12 - Paragraph 37 is deleted and the following is substituted therefore: "All interior and exterior wiring is in steel conduit. Conduits are copper with insulation conforming to Civil Works Code Specification C.W. 112.01".

FOR THE OFFERING ENGINEER:

JOHN W. LESLIE
Chief, Engineering Division

cc: Mr. Leslie
Mr. Gordon
Mr. Coffin
Eng Div Files

U. S. ARMY ENGINEER DIVISION, NEW ENGLAND

CORPS OF ENGINEERS

424 TRAPELO ROAD

WALTHAM 54, MASS.

DIRECTRESS REPLY TO:
DIVISION ENGINEER

REFER TO FILE NO.

NEDGW


10 April 1963

SUBJECT: Chicopee Falls Local Protection Project, Chicopee
River, Massachusetts - Design Memorandum No. 6 -
Pumping Stations

TO: Chief of Engineers
ATTENTION: ENGCW-E
Department of the Army
Washington 25, D. C.

There is submitted for review and approval Design Memorandum No. 6 - Pumping Stations, for the Chicopee Falls Local Protection Project, Chicopee River, Massachusetts, in accordance with EM 1110-2-1150. The contract award for construction of this project is scheduled for May, 1963, and an early receipt of your review comments will be appreciated in order that the plans and specifications may be completed on schedule.

FOR THE DIVISION ENGINEER:



JOHN WM. LESLIE
Chief, Engineering Division

Incl (10 cys)
Des. Memo No. 6

FLOOD CONTROL PROJECT
CHICOPEE FALLS LOCAL PROTECTION PROJECT
CHICOPEE RIVER
CHICOPEE RIVER BASIN
MASSACHUSETTS

DESIGN MEMORANDA INDEX

<u>Number</u>	<u>Title</u>	<u>Submission Date</u>	<u>Approved</u>
1	(Omitted)		
2	General Design, Hydrology, Hydraulics & Geology	21 Dec 1962	22 Jan 1963
3	Real Estate	29 Mar 1963	
4	Concrete Materials	9 Nov 1962	23 Nov 1962
5	Embankment & Foundations	6 Mar 1963	21 Mar 1963
6	Pumping Stations	10 Apr 1963	
7	Detailed Design of Flood- walls & Structures	13 Mar 1963	

TABLE OF CONTENTS

<u>Paragraph</u>		<u>Page</u>
	A. PERTINENT DATA	1-2
	B. INTRODUCTION	2-3
1.	Purpose	2
2.	Scope	3
3.	Construction Schedule	3
4.	C. HYDROLOGY AND HYDRAULICS	3
	D. GEOLOGY	3
5.	General Site Geology	3
6.	Main Street Station	3
7.	Oak Street Station	3
	E. CONCRETE MATERIALS	3
8.	Concrete Aggregate	3
	F. ARCHITECTURAL DESIGN	3
9.	General	3
10.	Architectural Design	4
	G. STRUCTURAL DESIGN	4-9
11.	General	4
12.	Design Criteria	4-6
13.	Basic Data and Assumptions	7-8
14.	General Description of Pumping Stations	8
15.	Extent of Design	8
16.	Superstructure	8
17.	Engine Room Floor	8
18.	Substructure	9
19.	Trash Racks	9
	H. MECHANICAL DESIGN	9-11
20.	General	9
21.	Pump Drives	9
22.	Alternate Pump Drives	9-10
23.	Right Angle Gear Units	10

TABLE OF CONTENTS (Cont'd)

<u>Paragraph</u>		<u>Page</u>
24.	Pumps	10
25.	Crane	10
26.	Sluice Gates	10-11
27.	Diesel Fuel System	11
28.	Sump Pump	11
29.	Valves	11
30.	Heating System	11
	I. ELECTRICAL DESIGN	11-12
31.	Electric Service	11-12
32.	Distribution	12
33.	Telephone Service	12
34.	Motors	12
35.	Heating	12
36.	Ground System	12
37.	Conduit and Cables	12
38.	Motor Controllers	12
39.	Electrical Load	12

Appendix

- A. Structural Computations,
Main Street Pumping Station
- B. Structural Computations,
Oak Street Pumping Station
- C. Pump Selection

PLATES

<u>Number</u>	<u>Title</u>
1.	Location Plan
2.	Project Plan
3.	General Plan and Profile Sta. 23+40 to Sta. 28+23
4.	General Plan Sta. 45+45 to Sta. 49+61
5.	General Profile Sta. 33+17 to Sta. 54+14

Main Street Pumping Station

6.	Architectural - Elevations
7.	Architectural - Plans and Section
8.	Structural - Reinforcing Details
9.	Mechanical
10.	Electrical Distribution One-Line Diagram

Oak Street Pumping Station

11.	Architectural - Elevations
12.	Architectural - Plans and Section
13.	Structural - Reinforcing Details
14.	Structural - Reinforcing Details
15.	Mechanical
16.	Electrical Distribution One-Line Diagram

FLOOD PROTECTION
CHICOPEE FALLS
LOCAL PROTECTION PROJECT
CHICOPEE RIVER, MASSACHUSETTS
DESIGN MEMORANDUM NO. 9
PUMPING STATIONS

APRIL, 1963

A. PERTINENT DATA

- | | | | |
|----|---------------------------------------|---|-------------------|
| a. | <u>Number of Stations</u> | 2 - Main and Oak Streets | |
| b. | <u>Purpose</u> | To pass combined storm runoff, industrial waste water and sanitary sewage originating below the protection elevation through the dike and floodwall at high river stages. | |
| c. | <u>Location of Stations</u> | | |
| | (1) State | Massachusetts | |
| | (2) City | Chicopee | |
| | (3) Area of City | Chicopee Falls | |
| | (4) River | Chicopee River, left bank downstream from Deady Memorial Bridge. | |
| | | <u>Main Street</u> | <u>Oak Street</u> |
| d. | <u>Drainage Area</u> | 20.5A | 17.8A |
| e. | <u>Sanitary and Industrial Wastes</u> | 4 c.f.s. | 20 c.f.s. max. |
| f. | <u>Allowance for Underseepage</u> | 6 c.f.s. | 6 c.f.s. |

g. <u>Pumping Stations</u>		<u>Main Street</u>	<u>Oak Street</u>
(1)	Type	Wet Pit	Wet Pit
(2)	Size	17'x21'	21'x28'
(3)	Architectural Treatment	Concrete superstructures	
(4)	Rated Capacity		
	High River Stage	40.0 c.f.s.	46.6 c.f.s.
	Low River Stage	44.0 c.f.s.	57.0 c.f.s.
(5)	Pumps		
(a)	Type	Mixed Flow	Axial Flow
(b)	Number	2	3
(c)	Size	16-inch (18-in. discharge)	16-inch (16-in. discharge)
(d)	Performance, each, River at high stage		
	1. Capacity	9000 gpm	7000 gpm
	2. Static Head	19.4 ft.	21.1 ft.
	3. Total Dynamic Head	21.4 ft.	23.5 ft.
(e)	Performance, each, River at low stage		
	1. Capacity	9900 gpm	8600 gpm
	2. Static Head	7.7 ft.	7.0 ft.
	3. Total Dynamic Head	10.1 ft.	10.8 ft.
(f)	Drive		
	1. Type	Diesel	Diesel
	2. Horsepower	85 hp	75 hp
(6)	Sump Water Elevations, MSL		
(a)	Maximum w.l.	83.0	80.0
(b)	Minimum w.l.	78.37	75.0

B. INTRODUCTION

1. Purpose. The purpose of this memorandum is to summarize and record the basic features of the design for two pumping stations for the Chicopee Falls Local Protection Project, to facilitate review and provide a convenient reference.

2. Scope. This memorandum presents basic design including preliminary plans and discussion. Design criteria, typical computations for pump sizes, station stability and stresses, and other pertinent data are included.

3. Construction Schedule. These stations will be constructed under a continuing type contract to be advertised in the Spring of 1963. The contract will include channel work, dikes, flood walls, etc., for the project. Construction of the pumping stations will be scheduled for 1963.

C. HYDROLOGY AND HYDRAULICS

4. Hydrology and Hydraulics are presented in Design Memorandum No. 2, General Design, Hydrology, Hydraulics and Geology, as are the Pumping Station Design Concepts summarized in A above.

D. GEOLOGY

5. General site geology is presented in Design Memorandum No. 2, General Design, Hydrology, Hydraulics and Geology.

6. The Main Street Station is founded on sound shale bedrock, as is the adjacent flood wall. Rock anchors are used to eliminate differential movement relative to the adjoining anchored tee walls.

7. The Oak Street Station is founded on granular soil, about three feet above a stratum of dense glacial till.

E. CONCRETE MATERIALS

8. Concrete Aggregate. Six commercial sources of sand and crushed stone were considered: five are recommended as satisfactory. A complete discussion of sources and costs with test results is included in Design Memorandum No. 4, Concrete Aggregates.

F. ARCHITECTURAL DESIGN

9. General. Architectural design of the pumping stations is in accordance with the Engineering Manual, EM 1110-2-3103, "Architectural Design of Pumping Stations," dated February 1960. Architectural treatment is shown on Plates 6, 7, 10 and 11.

10. Architectural Design. The superstructures of the pumping stations are cast-in-place reinforced concrete. The roofs are pitched to the pump discharge chambers, which are carried full height of the building. Roof construction is concrete slab with rigid insulation and 5-ply built-up roofing. Access to the roofs is by interior ladder. Stop log storage is provided on the roofs. Metal cabinet enclosures are used to provide security for the sluice gate operators.

G. STRUCTURAL DESIGN

11. General. This section presents the design criteria, basic data and assumptions used in the design of the pumping stations. A brief discussion of the stations is included as background for the structural computations which are presented in Appendices A and B.

12. Design Criteria.

a. General. All working stresses conform to those specified in the Engineering Manual for Civil Works, EM 1110-1-2101, "Working Stresses for Structural Design" dated 6 January 1958. Loading conditions, design assumptions, and other design criteria are based on the following applicable parts of the Engineering Manual for Civil Works: Standard Practice for Concrete (EM Part CXX - October 1953); Pumping Stations - Structural Design (EM 1110-2-3104 - 9 June 1958); and Wall Design - Flood Walls (EM 1110-2-2501 - January 1948 with changes 1 and 2 and Supplement). Accepted practice has been followed where the Engineering Manual for Civil Works does not apply.

b. Concrete. The following table lists the concrete and reinforced concrete working stresses used in the design of structures.

<u>Description</u>	<u>p.s.i.</u>
(Based on $f_c = 3,000$ p.s.i.)	
<u>Flexure</u> - (f_c)	
Extreme Fiber stress in compression	1050

<u>Description (Cont'd)</u>	<u>p.s.i.</u>
<u>Shear - (v)</u>	
Beams - no web reinforcement	90
Beams with properly designed web reinforcement	240
Flat Slab at critical section	90
<u>Bond - (u)</u>	
Deformed Bars	
Top bars	210
All others	300
<u>Bearing - (f_c)</u>	
Load on entire area	750
Load on 1/3 area or less (Maximum permissible) (When loaded area is greater than 1/3, the stress coefficient should vary lineally between the above values.)	1125
<u>Modular Ratio - (n)</u>	10

c. Reinforcement.

(1) Grade and Working Stresses. All reinforcement in the structures including temperature and shrinkage reinforcement is designed for the working stresses of new billet steel, intermediate grade, deformed bars: 20,000 p.s.i. in flexural tension. Reinforcement will conform to the requirements of Federal Specifications QQ-S-632, Type II and to ASTM A305.

(2) Spacing. The clear distance between parallel bars will not be less than 1-1/2 times the diameter of round bars except that in no case will the clear distance between parallel bars be less than one inch, or 1-1/2 times the maximum size of the coarse aggregate whichever is greater.

(3) Minimum Cover for Main Reinforcement

	<u>Min. Cover</u> (Inches)
Bottom of base slabs	4
Top of base slabs	3
Foundation walls, both faces	3
Exterior walls above grade	2
Floor and roof slabs	3/4
Interior girders	2
Interior floor beams	1-1/2

The concrete covering of stirrups, spacer rods, and similar reinforcement may be reduced by the diameter of such rods.

(4) Splices. All splices are lapped 24 diameters to develop, by bond, the total working strength of the bars. Splices in the main reinforcement at points of maximum moment are avoided in the design.

(5) Temperature and Shrinkage Reinforcement. Temperature and shrinkage reinforcement is provided in slabs and walls where the main reinforcement extends in only one direction. Such reinforcement, based on deformed bars, provides for a minimum ratio of steel area to concrete area (bd) of 0.002 with a minimum of $.001$ in each face up to a maximum of #6 bars @ $12''$ center-to-center.

d. Structural Steel. Structural steel is designed in accordance with the specifications for the Design, Fabrication and Erection of Structural Steel for Buildings, issued by the American Institute of Steel Construction. Allowable design working stresses conform to those given in the Engineering Manual for Civil Works using a basic stress of $20,000$ p.s.i.

e. Increase in Normal Working Stresses. Normal allowable working stresses will be increased by $33\text{-}1/3$ per cent for water at the top of the flood wall.

13. Basic Data and Assumptions.

a. <u>Controlling Elevations</u>	<u>Main St.</u>	<u>Oak St.</u>
Engine room floor slab	90.0	86.06
Sump floor slab	74.0	73.0
Water elevation riverside	102.0	97.0
Water elevation landside	88.5	83.5
Maximum elevation of water in sump	83.0	80.0
Minimum elevation of water in sump	78.37	75.0
Finished ground elevation	88.5	83.5-89.0

b. Loads

(1) Dead Loads. The following unit weights for materials have been used:

<u>Material</u>	<u>Pounds per cubic foot</u>
Water	62.5
Dry earth	125
Saturated earth	135
Submerged earth	72.5
Concrete	150

(2) Live Loads. The following live loads have been used:

	<u>Pounds per square foot</u>
Wind	50
Equipment	As furnished by manufacturers
Snow on roof	40
Engine room floor	100 plus equipment loads

c. External Water Pressure. In cases where hydraulic pressure affects the design of a structure, it has been assumed to act over the entire area in question under the full head available. Specific uplift assumptions for the structure are described in a later paragraph.

d. Earth Pressure. Earth pressure against the pumping station walls has been assumed at 40 lbs. per square foot equivalent liquid pressure for dry earth and 24 lbs. per square foot for submerged earth.

14. General Description of Pumping Stations.

a. General. The pumping stations consist of reinforced concrete structures. Discharge chamber required top elevations are nearly at the roofs; they are, therefore, carried to the full building height. Both stations contain gravity by-pass, wet sumps, engine rooms and discharge chambers. Sluice gates are seating type against river pressures. Stop log slots are provided in the discharge chamber to allow pumps or flap valves to be removed for servicing.

b. Main Street Pumping Station. This station is an integral part of the flood wall. The station is located in the yard of the Chicopee Manufacturing Company.

c. Oak Street Pumping Station. This station is located on the landside of the dike. It is on the riverside of the existing river wall at the U. S. Rubber Company.

15. Extent of Design. Design has been carried to an extent which determined a workable layout. A transverse section through the station has been designed for the maximum conditions affecting critical structural framing. The same design procedure will be followed wherever a change in loading or in section is made. Modifications will be made as prescribed by detailed layout and design.

16. Superstructure. The roof slabs are 6-inch, 2-way slabs supported on reinforced concrete walls. Crane loads are carried directly by the concrete walls. Impact load of the cranes is taken as 25% and lateral load is 20% of the live load.

17. Engine Room Floor. Live load on engine room floors is taken as 100 p.s.f. plus equipment concentrations. Slab is of uniform (12") thickness at Main Street. A beam-and-slab arrangement was used at Oak Street.

18. Substructure. Substructures are of reinforced concrete consisting of intake chambers, junction chambers, discharge chambers and sumps. Loads consist of horizontal earth and water pressures, bearing pressures and hydraulic uplifts. Hydrostatic head was determined by the line of creep method for design river levels, with tailwater at ground level. Substructures were designed as monolithic. The Main Street Station adjoins flood walls with rock anchored footings; for this reason, the station base slab is anchored to the rock to limit creep of the structure to match the walls.

19. Trash Racks. Steel trash racks have been provided in the intake chambers, with provision for raking. Racks are designed for full hydrostatic pressure halfway to the top of the chambers.

H. MECHANICAL DESIGN

20. General. This section presents pertinent information concerning the mechanical design of the pumping stations, including pumps, drives, cranes, gates and heating.

21. Pump Drives. Pumps are driven by industrial diesel power units capable of operating the pumps at rated speed at any head conditions that may develop. Required horsepower is less than the continuous engine rating. Drives are mounted on concrete bases and connected to right angle gear units through flexible couplings.

22. Alternate Pump Drives. Consideration was given to provision of reliable electric service from commercial power with dual service or standby power. Due to the length of secondary between stations and from the stations to a reliable underground source, diesel drives are substantially less expensive:

Diesel drives, gear units, fuel systems, aerial service for lighting, etc., for all units at both stations.	\$29,300
---	----------

Single aerial power service, transformers, switch gear, starters, motors, etc., plus diesel generator sets at each station	\$61,000
--	----------

Dual underground service, transformers, switch gear, starters, motors, etc. This includes savings due to reduction in building size.	\$72,500
--	----------

An important consideration in these small stations was the flexibility of operation provided by the variable speed available with diesel drives with adjustable governors. A curve sheet showing the effect of varying speed is included in Appendix C for each station, for the pump selected.

23. Right Angle Gear Units. The gears are of the self-contained type designed for transmitting power from the horizontal engine shaft through a gear train to the vertical pump shaft. The units are enclosed in a cast-iron and structural steel housing and have service factors of not less than 1.25 times the maximum power required to drive the pumps.

24. Pumps.

a. Main Street Station. Two pumps are required. To provide a reasonable capacity in the event of failure of a pump, two 16-inch mixed-flow pumps with a combined capacity of 40.0 c.f.s. against high river stage are provided. Design concepts for both stations are discussed in detail in Design Memorandum No. 2, "General Design Hydrology, Hydraulics and Geology."

b. Oak Street Station. Three 16-inch axial-flow pumps are required at this station to pass maximum process water flow plus storm water from a rainfall approaching a five-year storm at high river stage. At all river stages not requiring pumping of the process water from intermediate plant levels, there is a capacity for pumping storm runoff of 100-year frequency or more.

c. The type, size and general characteristics of pumps required were computed by the procedures outlined in EM 1110-2-3105 dated 10 December 1962. Computations are appended as Appendix C.

25. Crane. A two-ton overhead crane is provided in the engine room of each station to facilitate moving or repair of equipment. Cranes are of standard construction, hand-operated throughout.

26. Sluice Gates. Motor operated sluice gates will be located at the entrance of the sumps; these will be normally closed, except when pumping. Gates on the riverside of the by-pass

opening into the discharge chamber will normally be open except when pumping. At Oak Street, a third gate is provided to allow flows of process water from intermediate levels to by-pass the station while flows from lower areas are pumped. This gate will normally be open when not pumping, closed when pumping against low or moderate river stages, and open at high river stages.

27. Diesel Fuel System. Diesel fuel supply is stored in tanks, buried in the ground adjacent to the pumping stations; approximately 600 gallons at each station. Each engine is supplied through an individual line running directly to the tank. Drip pans are provided on each engine and connected to a common header running back to the tank. All fuel pipe is copper tubing with flared joint connections. At points where lines are embedded in concrete or pass through walls, they are protected by wrought-iron sleeves.

28. Sump Pump. Motor operated sump-pumps of 50 g.p.m. capacity are provided in the wet sumps for the purpose of drying them up after the pumping stations have been in operation.

29. Valves. A flap valve is installed on the end of each pump discharge line to facilitate the starting of the pump and to prevent backflow through it when the river is at flood stage. Stop log slots and logs are provided to close pump discharge lines in the event of flap valve failure.

30. Heating System. The heating system consists of electric powered unit heaters, sized for 50° F. temperature rise. Control is by thermostat with an overriding humidistat, to keep the temperature above the dew point. The use of diesel-oil fired unit heaters was considered with a resulting saving of \$400 per year in power costs. However, the City Engineer requested that electric heat be provided to reduce maintenance inspection costs.

I. ELECTRICAL DESIGN

31. Electric Service. Electric service from the City of Chicopee Electric Light Department is overhead from a pole at Blake and Main Streets. The Municipal Electric Light Department has proposed to install electric service for \$3,800.

Service poles and transformers will be the responsibility of the Electric Light Department. Service is 120-/240 three wire, single phase, 60 cycle.

32. Distribution. Utility secondary metering and a service entrance breaker is installed at the pumping station. A panel is furnished to serve motor, small power, lighting and receptacle loads in the pumping station. The wiring diagram is shown on Plates 10 and 16.

33. Telephone Service. Conduit, pull wire, and terminal box is provided for the installation of telephone service by the New England Telephone and Telegraph Company.

34. <u>Motors.</u>	<u>Main Street</u>	<u>Oak Street</u>
Floor stands	2 @ 1 HP	3 @ 1 HP
Wet sump exhaust fan	1 @ 1/7 HP	1 @ 1/7 HP
Sump pump	1 @ 2 HP	1 @ 2 HP
Heating Unit	1 @ 7.5 KW	1 @ 15 KW




35. Heating. The unit heater with blower is thermostatically controlled with overriding humidistat.

36. Ground System. All conduit, equipment and the neutral conductor are grounded in accordance with the National Electric Code.

37. Conduit and Cables. All interior and exterior wiring are in steel conduit. Copper conductors with 600-volt RHW insulation is used for all wiring.

38. Motor Controllers. Motor controllers suitable for the intended application are installed as required.

39. Electrical Load. The electrical load is expected to create an estimated maximum demand of 11 KW at Main Street and 18 KW at Oak Street.




REVISION	DATE	DESCRIPTION


GREEN ENGINEERING AFFILIATES, INC.
 BOSTON, MASS. ARCHITECT-ENGINEER
 U.S. ARMY ENGINEER DIVISION, NEW ENGLAND
 CORPS OF ENGINEERS
 WALTHAM, MASS.



DESIGNED BY: W. E. B. CHECKED BY: H. G. H.
 DRAWN BY: PROJECT ENGINEER:

CHICOPEE RIVER FLOOD CONTROL
CHICOPEE FALLS
 LOCATION PLAN
 CHICOPEE RIVER MASSACHUSETTS
 APPROVED: _____ DATE: 1963

SPEC. NO. CIV. ENG. 19-010
 DRAWING NUMBER: _____












CURVE DATA
 $\Delta = 7^\circ 31' 31''$
 $R = 400.00'$
 $T = 26.31'$
 $L = 52.54'$

NOTES:
 1. For General Notes and Legend see Sheet No. 1.
 2. For profile of dikes and drain see Sheet No. 17.

<p>GREEN ENGINEERING AFFILIATES, INC. SOUTH, MASS. ARCHITECTS - ENGINEERS</p>	<p>U.S. ARMY ENGINEER DIVISION, NEW ENGLAND CORPS OF ENGINEERS WASHINGTON, D.C.</p>
<p>CHICOPEE RIVER FLOOD CONTROL CHICOPEE FALLS</p>	
<p>STA. 45+45 TO STA. 49+61 CHICOPEE RIVER MASSACHUSETTS</p>	
<p>DATE: APRIL, 1963</p>	
<p>SCALE: AS SHOWN (SHEET NO. CH-585-10-50-00-01)</p>	
<p>CT-585</p>	


PLAN
 SCALE 1" = 20'






NOTES:
 1. For Plans see Sheets 106510, 11, 12, 13 and 14
 2. Rework roof/leader piping for gravity connections
 Install sump pumps for basement pits at U.S. Rubber Bldgs.


PROFILE -- DIKE
 HOR. 1"=20'
 VERT. 1"=10'




GREEN ENGINEERING APPLIATES, INC. BOSTON, MASS.		U.S. ARMY ENGINEER DIVISION, NEW ENGLAND CORPS OF ENGINEERS MILFORD, MASS.	
PROJECT: CHICOPEE RIVER FLOOD CONTROL CHICOPEE FALLS		PROJECT: CHICOPEE RIVER FLOOD CONTROL CHICOPEE FALLS	
STATION: STA. 33+17 TO STA. 54+14.83		STATION: CHICOPEE RIVER MASSACHUSETTS	
DATE: APRIL, 1963		DATE: APRIL, 1963	
DRAWN BY: P.A.L. (Scale 1/200)		SCALE: AS SHOWN (Scale 1/200)	
SHEET 17		CT-5885	




SOUTH ELEVATION
SCALE: 3/8" = 1'-0"



WEST ELEVATION
SCALE: 3/8" = 1'-0"



EAST ELEVATION
SCALE: 3/8" = 1'-0"




NORTH ELEVATION
SCALE: 3/8" = 1'-0"

GRAPHIC SCALE
0 10 20


DESIGNED BY	DATE	BY	DATE
GREEN ENGINEERS APPLICATED, INC. BOSTON, MASS.		U.S. ARMY ENGINEER DIVISION, NEW ENGLAND CORPS OF ENGINEERS WATERWAYS BRIGADE	
CHICOPEE RIVER FLOOD CONTROL CHICOPEE FALLS MAIN STREET PUMPING STATION ARCHITECTURAL ELEVATIONS			
CHICOPEE RIVER		MASSACHUSETTS	
DRAWN BY		DATE	
APRIL, 1963			
SCALE AS SHOWN (SEE DRAWING NOTES)			
CT-5885			
SHEET 41			




RIVERSIDE



FLOOR PLAN
SCALE: 1/8"=1'-0"




SECTION A-A
SCALE: 1/8"=1'-0"



ROOF PLAN
SCALE: 1/8"=1'-0"




GREEN ENGINEERS APPLICATES, INC. BOSTON, MASS. ARCHITECT - ENGINEER		U.S. ARMY ENGINEER DIVISION, NEW ENGLAND CORPS OF ENGINEERS MILITARY ENGINEER	
CHICOPEE RIVER FLOOD CONTROL CHICOPEE FALLS MAIN STREET PUMPING STATION			
ARCHITECTURAL PLANS AND SECTION CHICOPEE RIVER MASSACHUSETTS			
DATE: MARCH, 1963		SCALE AS SHOWN UNLESS OTHERWISE SPECIFIED	




DESIGNED BY	ARCHITECT-ENGINEER
GREEN ENGINEERS APPLICATES, INC. BOSTON, MASS.	U.S. ARMY ENGINEER DIVISION, NEW ENGLAND CORPS OF ENGINEERS BOSTON, MASS.
PROJECT NO.	CHICOPEE RIVER FLOOD CONTROL MAIN STREET PUMPING STATION STRUCTURAL
DATE	REINFORCING DETAILS CHICOPEE RIVER MASSACHUSETTS
APPROVED	MARCH 1963
SCALE AS SHOWN (SPEL NO. 01515-0-00)	CLASSIFICATION




RIVERSIDE




OPERATING FLOOR PLAN
SCALE: 3/8\"/>




ISOMETRIC OF FUEL OIL PIPING
NO SCALE




SECTION A-A
SCALE: 3/8\"/>




DETAIL A
NO SCALE




DETAIL B
SCALE: 3/8\"/>




DESIGNED BY	GREEN ENGINEERING APPLICATES, INC.	U.S. ARMY ENGINEER DIVISION, NEW BRUNSWICK, N.J.
CHECKED BY	BOSTON, MASS.	CORPS OF ENGINEERS
PROJECT NUMBER		
DATE	APRIL, 1963	
CHICOPEE RIVER FLOOD CONTROL CHICOPEE FALLS MAIN STREET PUMPING STATION MECHANICAL PLAN, SECTION, AND DETAILS CHICOPEE RIVER MASSACHUSETTS		
<small>SCALE AS SHOWN UNLESS OTHERWISE NOTED</small> CT-5885		




MAIN ST. PUMPING STATION
ELECTRICAL DISTRIBUTION
ONE-LINE DIAGRAM




EAST ELEVATION
SCALE: 3/8"=1'-0"




NORTH ELEVATION
SCALE: 3/8"=1'-0"




WEST ELEVATION
SCALE: 3/8"=1'-0"




SOUTH ELEVATION
SCALE: 3/8"=1'-0"




DESIGNED BY	DATE	REVISIONS	BY
GREEN ENGINEERING APPLICATES, INC. BOSTON, MASS. REGISTERED ENGINEER		U.S. ARMY ENGINEER DIVISION, NEW ENGLAND CORPS OF ENGINEERS WALTON, MASS.	
PROJECT NAME		CHICOPEE RIVER FLOOD CONTROL CHICOPEE FALLS OAK STREET PUMPING STATION ARCHITECTURAL ELEVATIONS	
PROJECT NUMBER		CHICOPEE RIVER MASSACHUSETTS	
DATE		APRIL, 1963	
SCALE AS SHOWN (FOR USE OF G.I. 100-10-01-02-04)		CT-5885	
SHEET NO.		SHEET 42	




FLOOR PLAN
SCALE: 3/8" = 1'-0"




ROOF PLAN
SCALE: 3/8" = 1'-0"



SECTION A-A
SCALE: 3/8" = 1'-0"




DESIGNED BY	W. H. W. H. D.	CHECKED BY	W. H. W. H. D.
DATE		DATE	
GREEN ENGINEERING APPLICATES, INC. BOSTON, MASS. ARCHITECT-ENGINEER		U.S. ARMY ENGINEER DIVISION, NEW ENGLAND CORPS OF ENGINEERS MILITARY ENGINEER	
CHICOPEE RIVER FLOOD CONTROL CHICOPEE FALLS OAK STREET PUMPING STATION ARCHITECTURAL PLANS AND SECTION CHICOPEE RIVER MASSACHUSETTS			
DRAWN BY		DATE	
SCALE AS SHOWN		APRIL 1953	
PROJECT NO.		CT-5885	




SECTION A-A
SCALE 3/8"=1'-0"


KEY PLAN
SCALE 1/8"=1'-0"



DESIGNED BY	CHICHOPEE RIVER FLOOD CONTROL
CHECKED BY	CHICHOPEE RIVER FLOOD CONTROL
DATE	APRIL 1963
<p>GREEN ENGINEERING AFFILIATES, INC. BOSTON, MASS. ARCHITECT - ENGINEER</p> <p>U.S. ARMY ENGINEER DIVISION, NEW ENGLAND CORPS OF ENGINEERS MILITARY DISTRICT OF MASSACHUSETTS</p> <p>CHICHOPEE RIVER FLOOD CONTROL CHICHOPEE FALLS OAK STREET PUMPING STATION STRUCTURAL REINFORCING DETAILS CHICHOPEE RIVER MASSACHUSETTS</p>	
<p>SCALE AS SHOWN (SEE ENCL. SHEET 2-24-63-01)</p> <p>ENGINEER: ROBERT W. BROWN</p> <p>PROJECT: CT-5885</p>	




SECTION B-B
SCALE: 3/8" = 1'-0"




SECTION C-C
SCALE: 3/8" = 1'-0"

PROJECT	CHICOPEE RIVER FLOOD CONTROL
CITY	CHICOPEE, MASS.
DESIGNER	ENGINEERING AFFILIATES, INC.
	BOSTON, MASS.
	ANDREWS - BOSTON
BY	U.S. ARMY ENGINEER DIVISION, NEW ENGLAND
CHECKED	CORPS OF ENGINEERS
	WATERVILLE, MAINE
CHICOPEE RIVER FLOOD CONTROL	
CHICOPEE FALLS	
OAK STREET PUMPING STATION	
STRUCTURAL	
REINFORCING DETAILS NO. 2	
CHICOPEE RIVER MASSACHUSETTS	
DATE	APRIL, 1952
SCALE AS SHOWN	SCALE NO. 3000 (SPEL. 32, CIV. ENR. 10-22-52-52)
SHEET NO.	CT-5885




1
2
3
4
5
6
7
8




NOTE:
For Isometric of Fuel Oil Piping, see
Main Street Pumping Station Plan



DESIGNER	ENGINEERING APPLICATES, INC. BOSTON, MASS.	U.S. ARMY ENGINEER DIVISION, NEW BRUNSWICK CORPS OF ENGINEERS SALTWATER, MASS.
PROJECT	CHICOPEE RIVER FLOOD CONTROL CHICOPEE FALLS OAK STREET PUMPING STATION	
MECHANICAL	PLAN, SECTIONS, AND DETAILS	
LOCATION	CHICOPEE RIVER MASSACHUSETTS	
DATE	APRIL, 1963	
PROJECT NUMBER	CT-5685	



PROJECT Chicopee Falls
 SUBJECT Main Street Pump Station



PROJECT Chicopee Falls

SUBJECT Main Street Pump Station

Center of Gravity of Conc. Struct. only. Moments about land face of pump sta.

	Calculation (LxWxH)	Volume		Arm	Moment	
		↓	↑		↷	↶
Total	22.42 x 29.75 x 37.25	24850		11.21	278500	
①	13.42 x 14.00 x 15.00		2820	8.21		23100
②	13.83 x 15.00 x 14.75		3060	8.00		24500
③	14.33 x 15.00 x 2.00		430	8.25		3540
④	6.00 x 12.00 x 9.00		495	19.42		9610
⑤	6.00 x 10.00 x 21.00		1260	19.42		24500
⑥	6.00 x 5.00 x 28.00		840	19.42		16300
⑦	6.00 x 21.92 x 2.25		296	19.42		5750
⑧	16.42 x 3.00 x 3.00		148	8.21		1220
⑨	14.92 x 4.25 x 26.00		1650	7.46		12300
⑩	14.92 x 2.50 x 33.25		1240	7.46		9620
⑪	6.00 x 1.50 x 33.25		299	17.92		5370
⑫	9.00 x 4.50 x 14.00		568	5.75		3270
⑬	11.50 x 5.75 x 18.00		1190	5.75		6850
⑭	9.42 x 5.75 x 33.25		1800	16.21		29150
⑮	1.00 x 6.00 x 5.00		30	.50		15
⑯	3.50 x 2.00 x 5.00		35	4.60		161
⑰	5.0 x 1.00 x 7.00		35	11.75		410
⑱	4.0 x 1.50 x 3.00		18	8.25		149
		<u>24850</u>	<u>16214</u>		<u>278500</u>	<u>175815</u>
		16214			175815	
Wc		8636		11.86	102685	

PROJECT Chicopee Falls

SUBJECT Main Street Pump Station

PROJECT NO. 6205
 SHEET NO. 2 OF
 DATE Feb 7, 1963
 COMPUTED BY R. R. [unclear]
 CHECKED BY HR

Center of Gravity of Earth Fill only. Moments about land face of pump sta.

		Volume		Arm	Moment	
		↓	↑		↷	↶
⑨	14.92 × 4.25 × 7.75	490		7.46	3660	
⑩	14.92 × 2.50 × 15.00	561		7.46	4180	
⑪	6.00 × 1.50 × 15.00	135		17.92	2420	
⑫	9.42 × 5.75 × 15.00	812		16.21	13150	
⑮	6.0 × 10.0 × 8.0	480		19.42	9320	
		<u>2478</u>		<u>13.20</u>	<u>32,730</u>	

Center of Gravity of Water to El. 105.00 Case I

		Volume		Arm	Moment	
		↓	↑		↷	↶
①	13.42 × 14.00 × 9.00	1690		8.21	13870	
⑤		1260			24500	
⑥		840			16300	
⑧		148			1220	
⑫	9.00 × 4.50 × 9.00	365		5.75	2100	
		<u>4303</u>		<u>13.48</u>	<u>57,990</u>	

Center of Gravity of Water to El. 102.00 Case II

		Volume		Arm	Moment	
		↓	↑		↷	↶
①		1690			13,870	
⑤	6.00 × 10.00 × 18.00	1080		19.42	20,970	
⑥	6.00 × 5.00 × 25.00	750		19.42	14,560	
⑧		148			1,220	
⑫		365			2,100	
		<u>4033</u>		<u>13.12</u>	<u>52,720</u>	

PROJECT Chicopee Falls

SUBJECT Main St. Pump Sta.

PROJECT NO. _____

SHEET NO. 3 OF _____

DATE _____

COMPUTED BY ROP

CHECKED BY WR

Center of Gravity of Misc. Equipment & Items.

		Weight		Arm	Moment	
		↓	↑		↷	↶
Prime Mover	2 x 2.0*	4.0		7.0	28	
Crane	Unit	2.0*		15.12 [±]	30	
Stop Logs	.5 x .5 x 5.0 x .055 x 60EA	4.0		14.00	56	
Sluice Gate	Unit	1.0		17.18	17	
Sluice Gate	Unit	1.0		2.0'	2	
Pump	2 x 3.0	6.0		11.92	71	
Gear Unit	2 x 1.0	2.0		11.92	24	
Pump Thrust	2 x 3.0	6.0		11.92	71	
L.L. Floor	14.08 x 15.00 x .100	21.10		8.12	172	
L.L. Roof	14.33 x 15.00 x .050	10.75		8.25	89	
Wm		57.85		9.70'	560	

GREEN ENGINEERING AFFILIATES, INC.
ENGINEERS
BOSTON, MASS.

PROJECT Gloucester Falls

SUBJECT Main Street Pump Sta.

PROJECT NO. _____
 SHEET NO. 4 OF _____
 DATE Feb
 COMPUTED BY R. J. ...
 CHECKED BY WR

Case I (wt per foot of LOADS)

		↓	↑	→	←	Arm	↷	↶
W_c	$8636 \times \frac{.150}{29.75}$	43.40				11.86	515	
W_{es1}	$2478 \times \frac{.135}{29.75}$	11.23				13.20	148	
W_{H_2O}	$4303 \times \frac{.0625}{29.75}$	9.04				13.48	122	
W_m	$\frac{57.85}{29.75}$	1.94				9.70	19	
U_{w1}	$25.80 \times 31.0 \times .0625$	50.00				35.32	1765	
W_{w2}	$2.00 \times 25.8 \times \frac{1}{2} \times .0625$	1.61				39.62	64	
W_{e2}	$5.0 \times 8.0 \times (.135 - .0625)$	2.90				24.92	71	
W_{e3}	$\frac{1}{2} \times 8.0 \times 20.8 \times (.0725)$	6.00				34.35	206	
W_{e4}	$\frac{1}{2} \times 12.5 \times 6.5 \times (.0725)$	2.94				44.06	130	
W_{c21}	$25.80 \times 2.0 \times .150$	7.74				35.32	273	
W_{c22}	$\frac{1}{2} \times 25.8 \times 2.00 \times .150$	3.87				31.02	120	
U_1	$23.53 \times 48.22 \times .0625$		71.00			24.11		1710
U_2	$\frac{1}{2} \times 48.22 \times 11.47 \times .0625$		17.28			32.15		555
P_{e1}	$\frac{1}{2} \times 0.0725 \times 12^2 \times \frac{1}{3}$				1.7	4.00		7
P_{wI}	$\frac{1}{2} \times .0625 \times 35.0$				38.3	11.67		446
P_{e2}	$\frac{1}{2} \times 0.0725 \times 19^2 \times 0.50$			6.5		6.33	41	
P_{w2}	$\frac{1}{2} \times 19.0 \times 23.53 \times .0625$			14.0		6.33	89	
		140.67	88.28	20.5	40.0		3563	2718
		88.28					2718	
		52.39					845	

$$\frac{\sum H}{\sum V} = \frac{19.5}{52.4} = 0.372$$

$$\bar{x} = 16.1$$

$e = 8.1$ MID 1/3 BASE

$$p = \frac{52.39}{48.22} \left[1 \pm \frac{6 \times 8.1}{48.22} \right] = 1.09 [1 \pm 1.005]$$

$$= 2.18 \text{ KSF } \pm .00 \text{ KSF NET}$$

★ Note: Rock anchors will be provided, similar to wall sects. adj. to pump sta, to prevent differential movement between the pumping station and adjacent walls

GREEN ENGINEERING AFFILIATES, INC.
ENGINEERS
BOSTON, MASS.

PROJECT Chicopee Falls

SUBJECT Main St. Pump St.

PROJECT NO. _____
 SHEET NO. 5 OF _____
 DATE _____
 COMPUTED BY ROP
 CHECKED BY [Signature]

Case II

		↓	↑	→	←	Arm	↷	↶
Wc		43.40					515	
Wes1		11.23					148	
Wh20	$4033 \times \frac{.0625}{29.75}$	8.47				13.12	111	
Wm		1.94					19	
Ww1	$25.80 \times 28.0 \times .0625$	45.20				35.32	1593	
Ww2		1.61					64	
Wes2		2.90					71	
Wes3		6.05					206	
Wes4		2.94					130	
Wc21		7.74					273	
Wc22		3.27					120	
U1	$22.68 \times 48.22 \times .0625$		68.40			24.11		1648
U2	$\frac{1}{2} \times 48.22 \times 9.32 \times .0625$		14.03			32.15		452
Pw11	$\frac{1}{2} \times .0625 \times 32.0^2$				32.0	10.67		341
Pw2	$\frac{1}{2} \times 19 \times 22.68 \times .0625$			13.45		6.33	-85	
Pe1					1.7			7
Pe2				6.5			41	
		135.30	92.43	19.95	33.7	17.5	3376	2448
		82.43				6.6'	2448	
		52.87					928	

RESULTANT IN MID 1/3 BASE

$$P = \frac{52.87}{48.22} \left[1 \pm \frac{6 \times 6.6}{48.22} \right] = 1.10 (1 \pm .823)$$

$$= 2.00 \text{ KSF, } +.19 \text{ KSF}$$

* See note case I

$$\frac{\Sigma H}{\Sigma V} = \frac{13.75}{52.87} = .260$$

PROJECT Chicopee Falls
SUBJECT Main St. Pump Sta.

Case II + 6' Rock (WALL ON BOTH SIDES WILL BE ANCHORED)

		↓	↑	→	←	Arm	↷	↶
Wc		43.40					515	
Wes1		11.23					148	
W _{H2O}		8.47					111	
Wm		1.94					19	
Ww1		45.20					1593	
Ww2		1.61					64	
Wes2		2.90					71	
Wes3		6.00					206	
Wes4		2.94					130	
Wc21		7.74					273	
Wc22		3.87					120	
W _{rock}	6.0 × 48.22 × .170	49.20				24.11	1185	
U ₁	29.44 × 48.22 × .0625		88.90			24.11		2140
U ₂	1/2 × 8.56 × 48.22 × .0625		12.90			32.15		415
Pe ₁	1/2 × .0725 × 18 ² × 1/2				3.9	6.00		24
Pe ₂	1/2 × .0625 × 38.0				45.1	12.67		571
Pe ₃	1/2 × .0725 × 25 × 0.5			11.3		8.33	95	
Pp	1/2 × 25.0 × 29.44 × .0625			23.0		8.33	192	
		184.50	101.80	34.3	49.0		4722	3150
		101.80					3150	
		82.70				R = 19.0	1572	

BY Friction = 49.0 - 11.3 - 23.0 = 14.7

< 0.3 × 82.70 (TAKEN BY FRICTION)

★ See note Case I

$$\frac{\Sigma H}{\Sigma V} = \frac{14.7}{82.7} = 0.178$$

PROJECT Chicopee Falls

SUBJECT Main St. Pump Sta.

PROJECT NO. _____

SHEET NO. 7 OF _____

DATE _____

COMPUTED BY R.P.P.

CHECKED BY WA

Case I + 6' Rock

		↓	↑	→	←	Arm	↷	↶
Wc		43.40					515	
Wes1		11.23					148	
Ww20		9.04					122	
Wm		1.94					19	
Ww1		50.00					1765	
Ww2		1.61					64	
Wes2		2.90					71	
Wes3		6.00					206	
Wes4		2.94					130	
Wc 21-22	7.74 + 3.87 = 11.61	11.61					393	
Wrock		49.20					1185	
U1	$30.46 \times 48.22 \times .0625$		91.80			24.11		2215
U2	$\frac{1}{2} \times 10.54 \times 48.22 \times .0625$		15.90			32.15		511
Pe1					3.90	—		24
PwI	$\frac{1}{2} \times .0625 \times 41.0^2$				52.50	13.67		718
Pe2				11.30		—	95	
Pp				23.80		8.33	198	
		189.87	107.70	35.10	56.40	17.6	4917	3468
		107.70		*	*		3468	
		82.17					1443	
						> 12.06		
						e = 6.5		

BY FRICTION = $56.40 - 35.10 = 21.30K$

$< .4 \times 82.17$ (by friction)

$.3 \times 153\% = .4$

Bottom of Rock

$$p = \frac{82.17}{48.22} \left[1 \pm \frac{6.5 \times 6}{48.22} \right] = 1.705 (1 \pm .816)$$

= 3.08 KSF, 0.32 KSF


* See note case I

PROJECT CHICOPEE FALLS

SUBJECT MAIN ST PUMP STATION

PROJECT NO. 6205-2
 SHEET NO. 8 OF
 DATE FEB 63
 COMPUTED BY DR
 CHECKED BY RLT

Center of Gravity of structure with NORMAL WATER
 WATER AT 80.0 ELEVATION
 3 FT SURCHARGE
 GROUND AT 89.0 EL.
 WIND AT 50 #/FT²



LOADING #3

		↓	↑	→	←	ARM	M ↓	M ↑
Wc-21,22	(PAGE 4)	55.01				—	908	
Wes1	≈ (PAGE 4) = 11.23	11.23					148	
Ww1	.0625 x 6 x 25.80	9.68				35.32	342	
Ww2		1.61				39.62	64	
Wes2-3-4		11.84					387	
Pes1	.130 x 1/3 x 12 ² x 1/2			3.12		14.00	43.7	
Pes2	.130 x 1/3 x 12 x 10			5.20		5.00	26.0	
Pes3	.0725 x 1/3 x 10 ² x 1/2			1.21		3.33	4.0	
WIND	.05 x 18.25			0.91		28.12	25.6	
L	.0625 x 10 x 48.12		30.20			24.11		728
Wm	(PAGE 34)	1.94				970	19.0	
Pes4					1.72	4.00		8
		91.31	30.20	10.44	1.72		1967.3	736
		<u>30.20</u>					<u>736.0</u>	
		61.11					1231.3	

RESULTANT AT $\frac{1231.3}{61.11} = 20.2 \text{ FT.}$

$e = 3.9'$

$p = \frac{61.11}{48.22} \left[1 \pm \frac{6 \times 3.9}{48.22} \right] = 1.270 \left[1 \pm 0.486 \right]$

$= 1.89, 1.65 \text{ KSF NET}$
 $.62, .62 \text{ UPLIFT}$

2.51 KSF 1.27 KSF

PROJECT CHICOPEE FALLS

SUBJECT MAJ. ST. PUMPING STATION

ROCK ANCHORS { REFER NOTE ON PAGE 4 }

LOADING #1
(REFER P4)

RESULTANT AT 16.1' FROM LAND FACE
 $E = 24.11 - 16.1 = 8.0 \text{ FT.}$

$$P = \frac{52.39}{48.22} \left[1 \pm \frac{6 \times 8.0}{48.22} \right] = 1.09 [1 \pm 1.005]$$


NOTE:

SHEAR WILL ALLOW 37.7K
AND THE COMPONENT IN TENSION ALLOWS 28.1K, SHEAR 37.7K.
SINCE THE BAR IS AT 30° WITH VERTICAL WE ASSUMED
THAT THE BAR WILL TEND TO BE PULLED IN TENSION RATHER
THAN BE SHEARED OFF. THIS IS A CONSERVATIVE ASSUMPTION

$$= \begin{array}{r} 2.18 \text{ } 2.00 \text{ KSF NET} \\ 1.42 \text{ } 2.19 \text{ KSF UPLIFT} \\ \hline 3.65 \text{ } 2.19 \text{ KSF TOTAL} \end{array}$$

UNBALANCED HORIZ: $40.0 - 20.5 - 0.2 \times 52.39 = 9.0 \text{ K} \therefore \text{TRY 4 BARS} (\#11)$

TENSION = $A_s F_s = 1.56 \times 36.0 = 56.2 \text{ K}$
SHEAR = $A_s F_s = 1.56 \times 18.2 \times 1.33 = 37.7 \text{ K}$



$$\frac{4 \times 28.1 \text{ K}}{9.0 \text{ K}} = 12.5' \text{ spacing}$$

(AXIAL COMPONENT GOVERNS)

LOADING #2
(REFER P5)

RESULTANT AT 17.5' FROM LAND FACE
 $E = 24.11 - 17.5 = 6.6 \text{ FT.}$

$$P = \frac{52.87}{48.22} \left[1 \pm \frac{6 \times 6.6}{48.22} \right] = 1.10 [1 \pm 0.823]$$


$$= \begin{array}{r} 2.00 \text{ } +1.19 \text{ KSF NET} \\ 1.42 \text{ } 2.00 \text{ UPLIFT} \\ \hline 3.42 \text{ KSF } 2.19 \text{ KSF} \end{array}$$

UNBALANCED HORIZONTAL:

$T = A_s F_s = 1.56 \times 27.000 = 42.1 \text{ K}$
 $33.7 - 19.75 - 0.2 \times 52.87 = 3.2 \text{ K}$


$(42.1) \frac{1}{2} = 21.05 \text{ K} \text{ component}$

$$\frac{4 \times 21.05}{3.2} = 26.3'$$




PRESSURES (AT BOTTOM OF CONCRETE)


LOADING #1 (P-4.9)



LOADING #2 (P5.9)



LOADING #3 (PB)




CONSTRUCTION (P.4)

$W_c = 55.01$ $908 \downarrow$
 $W_m = 194$ $19 \downarrow$

$$\frac{927}{56.95} = 16.3 \quad e = 7.8'$$

$$p = \frac{56.95}{48.22} \left[1 \pm \frac{6 \times 7.8}{48.22} \right] = 1.18 (1 \pm .972)$$




PROJECT CHICOPEE FALLS

SUBJECT MAIN ST. PUMPING STATION

PROJECT NO. 6205-2
 SHEET NO. 11 OF
 DATE FEB 63
 COMPUTED BY RR
 CHECKED BY PCP

HEEL APRON

LOADING #1 (P.4)




SHEAR

MOMENT

$W_{w1} = 50.00$	\downarrow	$\times 12.90 = 645.0 \downarrow$
$W_{es2} = 2.90$	\downarrow	$\times 2.50 = 7.2 \downarrow$
$W_{es3} = 6.00$	\downarrow	$\times 11.93 = 71.6 \downarrow$
$W_{es4} = 2.94$	\downarrow	$\times 21.63 = 63.6 \downarrow$
$W_{c21} = 7.74$	\downarrow	$\times 12.90 = 100.0 \downarrow$
$W_{c22} = 3.87$	\downarrow	$\times 8.60 = 33.3 \downarrow$
$W_{w2} = 1.61$	\downarrow	$\times 17.20 = 27.7 \downarrow$
$\frac{75.06}{\downarrow}$		
$2.19 \times 25.80 = P_{T1} = 56.60 \uparrow$		$\times 12.90 = 730.0 \uparrow$
$0.78 \times 25.80 \times .5 = P_{T2} = 10.00 \uparrow$		$\times 8.60 = 86.6 \uparrow$
<hr/>		
	$8.40 \downarrow$	$131.8 \downarrow$

LOADING #2 (P.5)



SHEAR

MOMENT

$W_{w1} = 45.20$	\downarrow	$\times 12.90 = 583.0 \downarrow$
$W_{es2} \rightarrow W_{w2} \text{ etc} = 25.06$	\downarrow	$= 303.4 \downarrow$
$2.19 \times 25.8 = P_{T1} = 56.60 \uparrow$		$\times 12.90 = 730.0 \uparrow$
$0.66 \times 25.8 \times .5 = P_{T2} = 8.52 \uparrow$		$\times 8.60 = 73.3 \uparrow$
<hr/>		
	$5.14 \downarrow$	$83.1 \downarrow$

LOADING #1 (GOVERNS BY INSPECTION)

$d = 48 - 4 = 44" \approx$

$A_s = \frac{131,800}{.907 \times 27,000 \times 44} = .1213 \text{ in}^2/\text{in}$

#11 @ 12" used

AT P.S. :

USE: #8 - 6" C-C (.131 in²/in) (TOP)

AT MID HEEL:

USE: #8 - 12" C-C


1.57 in²/ft (TOP)

PROJECT CHICOPEE FALLS

SUBJECT MAIN ST PUMPING STATION


HEEL APRON

LOADING #3 (P8,11)



SHEAR		MOMENT	
$w_{w1} = 9.68$	↓	$\times 12.90 = 124.8$	↓
$w_{c21} \rightarrow w_{c22} \rightarrow w_{w2} = 25.06$	↓	$\times \text{---} = 303.4$	↓
1.27×25.8	$= P_1 = 32.75$	↑	$\times 12.90 = 422.0$
$0.66 \times 25.8 \times 0.5$	$= P_2 = 8.52$	↑	$\times 8.60 = 73.3$
6.53		67.1	

CONSTRUCTION:



SHEAR		MOMENT	
$w_{c21-22} = 11.61$	↓	$\text{---} = 133.3$	↓
0.03×25.8	$= P_1 = 0.78$	↑	$\times 12.90 = 10.0$
$1.22 \times 25.8 \times 0.5$	$= P_2 = 15.73$	↑	$\times 8.60 = 135.0$
4.90		11.7	

LOADING #3

$$A_s = \frac{67.1}{1.44 \times 43} = 1.08 \text{ in}^2/\text{ft.}$$

AT PS : USE # 9-12" C-C $A_s = 1.00$ (BOTTOM)

AT MIDHEEL : USE # 9-24" C-C (BOTTOM)

PROJECT CHICOPEE FALLS

SUBJECT MAIN ST PUMPING STATION


PROJECT NO. 6205-2
SHEET NO. 13 OF 13
DATE FEB 63
COMPUTED BY GR
CHECKED BY EC

ROOF SLAB: E-W: $14'-1" + \frac{1}{2}[12'+15'] = 15.2 \text{ FT} \pm$ (BELOW PARAPET)
N-S: $17'-0" - \frac{1}{2}[12'+12'] = 16.0 \text{ FT} \pm$

USING 15'x16' FOR DESIGN

$$\frac{l_1}{l_2} = \frac{15}{16} = .94$$

CASE 4 - ACI		m = .94		Short	Long
C. NEGATIVE MOMENT	=	0.063	-	0.058	
D. NEGATIVE MOMENT	=	0.031	-	0.029	
POSITIVE MOMENT	=	0.048	-	0.044	



$W_{\text{CONC}} = 6/12 \times .150$	=	.075 KSF
$W_{\text{LL}} =$	=	.080 KSF
$W_{\text{ROOFING}} =$	=	.010 KSF
$W_{\text{WOOD}} =$	=	.062 KSF
		<u>.227 KSF</u>

= WOOD WT.
60 pieces @ 50 #/ft³ $\frac{1}{2} \times \frac{1}{2} \times 5'$
Volume = 60 x 1.25 ft³ = 75 ft³
.05 x 75 = 3.75 K[±]

OVER $\frac{1}{4}$ AREA $\therefore 3.75 \div \frac{1}{4} \text{ AREA} = \underline{.062}$

SHORT SPAN:

$$-M = .063 \times .227 \times 15^2 \times 12 = 38.5 \text{ WK/FT.}$$

$$d^2 = \frac{38,500}{160 \times 12} \therefore d = 4.50'' \text{ USE } d = 5.0$$

$$A_s = \frac{38,500}{20,000 \times .885 \times 5.0} = 0.44 \text{ in}^2/\text{FT} \text{ USE: } \underline{\#4-5\frac{1}{2}'' \text{ C-C}} \text{ (SHORT SPAN)}$$

#6 @ 12

LONG SPAN:

$$-M = \frac{.058}{.063} (38.5) = 35.5 \text{ WK/FT}$$

$$d^2 = \frac{35,500}{160 \times 12} \therefore d = 4.30''$$

$$A_s = \frac{35,500}{20,000 \times .885 \times 4.5} = 0.44 \text{ in}^2/\text{FT.}$$

$\therefore 4.3'' \#4 \text{ BAR} \approx 4.8''$
 \therefore USE $d = 5.0''$ in SHORT SPAN
USE $d = 4.5''$ in LONG SPAN

USE $\underline{\#4-5\frac{1}{2}'' \text{ C-C}}$ (LONG SPAN)

#6 @ 12

ROOF SLAB: (Continued)

SHORT SPAN:

$$+M = .048 \times .227 \times 15^2 \times 12 = 29.4 \text{ mk/FT}$$

$$d = 4.25 - \#4 = 3.75"$$

$$A_s = \frac{29,400}{.885 \times 20,000 \times 5.00} = .334 \text{ m}^2/\text{FT}$$

USE #4-7" C-C

#6 @ 16"




LONG SPAN

$$+M = \frac{.044}{.048} (29.4) = 27.0 \text{ mk/FT}$$

$$A_s = \frac{27,000}{.885 \times 20,000 \times 4.50} = .340 \text{ m}^2/\text{FT}$$

USE #4-7" C-C

#6 @ 16"




PROJECT CHICOPPE FALLS

SUBJECT MAINST PUMPING STATION

PROJECT NO. 6205-2
 SHEET NO. 15 OF
 DATE FEB 63
 COMPUTED BY DRJ
 CHECKED BY PCP

TOPSLAB - OVER 2 CHAMBERS (north side)



USING 6" SLAB

$$+M = \frac{1}{14} w l^2$$

$$-M = \frac{1}{9} w l^2$$

FROM P13 $W = .227$ KSF
 less $\frac{1}{2}$ WOOD = $.031$ KSF
 $.196$ KSF
 WT/FT = $.196$ K/FT²

$$+M = \frac{1}{14} (.196)(7.5)^2 = .787'K/FT$$

$$A_s = \frac{787 \times 12}{(20000)(885)(5)} = .107 \text{ in}^2/\text{FT}$$

#4-12" C-C

$$-M = \frac{1}{9} (.196)(7.5)^2 = 1.23'K$$

$$A_s = \frac{1230 \times 12}{(20000)(885)(5)} = .167 \text{ in}^2/\text{3FT}$$

#4-12" C-C


OPERATING FLOOR SLAB:

PUMP ENGINE :	2K	
GEAR UNIT :	1K	
PUMP :	3K	} 7K
THRUST :	3K	

$$D.L = .150 \times \frac{12}{12} = .150 \text{ KSF}$$

$$L.L = .100 \text{ KSF}$$

$$D.L + L.L = .250 \text{ KSF}$$




- ① MAIN BAND OF STEEL THROUGH OPENINGS AND ON THE SIDE WHERE THE CANTILEVER WOULD BE TOO GREAT TO ASSUME CANTILEVER DESIGN OF THE STEEL

LENGTH SAY = 16.5 FEET
WIDTH = 3.5 FEET

$$P_1 = \frac{1}{2}(7+7) = 7K$$

$$P_2 = \frac{1}{2}(2+2) = 2K$$



FOR 1FT SECTION: $wl^2/8 = .25 \times 16.5^2 \times 1/8 = 8.52 \text{ K} @ \text{ft}$

$$M \text{ under } P_1 : M = \frac{10.5}{16.5} (7)(5) \frac{1}{3.5} = 6.37 \text{ K}$$


$$M \text{ under } P_2 : M = \frac{6.5}{16.5} (2)(10) \frac{1}{3.5} = 2.26 \text{ K}$$

MAX MOMENT BETWEEN 5' & 8.25' LT RT. SUPPORT.

SAY 7' FROM RT SUPPORT. :

$$M_{\text{MAX}} = .250 \frac{7'(16.5-7')}{2} + \left[\frac{7(5)9.5'}{16.5} + \frac{2(6.5)(7)}{16.5} \right] \frac{1}{3.5}$$

$$M_{\text{MAX}} = 8.25 + 5.75 + 1.57 = 15.6 \text{ K}$$



$$d^2 = \frac{15,600 \times 12}{160 \times 12} = 9.8 \text{ IN} \quad \text{USE } 12 \text{ SLAB}$$


$$d = 12 \text{ IN} - \frac{3}{4} \text{ IN} - \frac{1}{2} \times 7 = 10.8$$

$$A_s = \frac{15,600}{20,000 \times .885 \times 10.8} = .82 \text{ m}^2/\text{lin}$$

BOTTOM: USE #7-7" C-C = (.086 m²/lin)

OPERATING SLAB FLOOR (CONTINUED) (REFER PREVIOUS PAGE)

② CAANTILEVER:



L.L. + D.L. = .250 KSF

$7K \div 2[4 + \frac{1}{3}] = .50 K/FT$ ALONG EDGES OF A 4x3 HOLE = P_3

FOR 1 FT SECTION:

$M = .50 \times 3 = 1.5 \text{ 'K}$
 $M = .250 \times 3 \times 1.5 = 1.125 \text{ 'K}$
2.7 'K

$A_s = \frac{2,700}{20,000 \times .885 \times 10.5} = .0146 \text{ in}^2/\text{in}$


USE # 5-12" C-C (TOP) (SEE NEXT PAGE)

③ MAIN BAND OF STEEL FOR SAY 4 FT. AS IN ①

LENGTH SAY = 16.5 FT.

WIDTH SAY = 4.0 FT.

REFER PREVIOUS PAGE




$\frac{1}{2}(P_1 + P_2) = \frac{1}{2}(7 + 2) = 4.5 \text{ K}$

ONE FT. SECTION $wl^2/8 = .25 \times 16.5^2 \times \frac{1}{8} = 8.52 \text{ 'K @ } \frac{1}{8}$

M UNDER LOADS: $M = \frac{13}{16.5} (4.5)(3.5) \frac{1}{4.0} = 3.10 \text{ 'K}$

$M = \frac{7}{16.5} (4.5)(9.5) \frac{1}{4.0} = 4.53 \text{ 'K}$



MAX MOMENT AT 7' ± FROM LEFT END

$M_{MAX} = 8.5 + 4.53 + \frac{7}{13} (3.10)$

$M_{MAX} = 8.5 + 4.53 + 1.67 = 14.7 \text{ 'K}$

$d = 10.8" - 0.9" = 9.9"$


$A_s = \frac{14,700}{20,000 \times .885 \times 9.9} = .084 \text{ in}^2/\text{in}$

BOTTOM USE # 7-7" C-C (086 in²/in)

OPERATING FLOOR SLAB (CONT.)

④ Length SAY 16.5 FT
 WIDTH SAY 6 FT

P_2 taken care of PREVIOUSLY BUT
 ADD $\frac{1}{2} P_2$ TO ENTIRE FLOOR REMAINING
 $2K \div 5' \times 15' = .03 KSF^+$



$$+M = \frac{1}{4} w l^2 = \frac{1}{4} \times .280 \times 16.5^2 = 5.4 \text{ 'K}$$


$$-M = \frac{1}{9} w l^2 = \frac{1}{9} \times .280 \times 16.5^2 = 8.5 \text{ 'K}$$

$$+A_s = \frac{5400}{20,000 \times .885 \times 9.9} = .031 \text{ in}^2/\text{in}$$


USE #7-12" C-C BOTTOM (.05 in²/in)

$$-A_s = \frac{8,500}{20,000 \times .885 \times 9.9} = .049 \text{ in}^2/\text{in}$$

USE #7-12" C-C (TOP)



OPERATING ROOM SLAB $\frac{3}{8}'' = 1'$



(T) #5-12" SHRINKAGE


Base Slab Design

Shears & Moments at Riverside of Wall from Heel design


Case I $V = 8.40^k \downarrow M = +131.8^k$

Case II $V = 5.14^k \downarrow M = +83.1^k$

Case III $V = 6.53^k \uparrow M = -67.1^k$



Case I 3.63%
Case II 3.42%
Case III 2.51%



Case I 2.97%
Case II 2.85%
Case III 1.93%


Case I

ΣMR_A out $H_2O = .0625 \times 31.0 \times 6.0$	$+ 11.63 \times 18.67 = +217.0$
in $H_2O = .0625 \times 13.42 \times 9.00$	$= +7.55 \times 7.46 = +56.3$
Conc $= .150 \times 22.42 \times 4.00$	$= +13.45 \times 10.46 = +140.8$
$P_1 = 2.97 \times 22.42$	$= -66.70 \times 10.46 = -695.0$
$P_2 = \frac{1}{2} \times .68 \times 22.42$	$= -7.63 \times 6.72 = -51.3$
$V =$	$+ 8.40 \times 21.67 = +182.0$
$M =$	$= +131.8$
	$\underline{-33.30^k} \quad \underline{-18.4^k}$

$R_B = \frac{18.4}{14.92} = +1.23^k$

$R_A = -33.30 + 1.23 = 0 \quad R_A = +32.07$

$V_u = (3.65 - .60)x - .033 \frac{x^2}{2} = 3.05x - .0165x^2$



$V = 0 = .0165x^2 - (3.05 - .56)x + 27.57 \quad .0165x^2 - 2.49x + 27.57$

$x = \frac{2.49 - \sqrt{6.20 - (4 \times .0165 \times 27.57)}}{.033} = 12.22'$

PROJECT Chicopee Falls
SUBJECT Main St. Pump Station

$$\begin{aligned} EM_x R_A & 32.07 \times 12.97 = -416.0 \uparrow \\ \text{Conc} & \frac{.60 \times 13.72^2}{2} = -56.5 \uparrow \\ P_{T1} & 3.65 \times \frac{13.72^2}{2} = +343.0 \downarrow \\ P_{T2} & .0165 \times \frac{13.72^3}{2} = -14.2 \uparrow \\ H_2O & .0625 \times 9.0 \times \frac{12.22^2}{2} = -41.9 \uparrow \\ & -185.6 \uparrow \end{aligned}$$


$$A_s = \frac{185.6}{2.00 \times 44} = 2.11 \square'' \quad \text{Top } \#11 @ 9'' \quad A_s = 2.08$$

Case II

$$\begin{aligned} \text{outside } H_2O & = .0625 \times 28.0 \times 6.0 = +10.50 \times 18.67 = +196.0 \\ \text{inside } H_2O & = + 7.55 + 56.3 \\ \text{Conc} & = + 13.45 + 140.8 \\ P_{T1} & = 2.85 \times 22.42 = -63.80 \times 10.46 = -668.0 \\ P_{T2} & = \frac{1}{2} \times .57 \times 22.42 = -6.38 \times 6.72 = -42.8 \\ V & = + 5.14 \times 21.67 = +111.5 \\ M & = + 83.1 \\ & -33.54 -123.1 \uparrow \end{aligned}$$

$$R_B = \frac{123.1}{14.92} = 8.25^k \quad R_A = 33.54 - 8.25 = 25.29^k$$

$$V_0 = (3.42 - .60)x - .0254 \frac{x^2}{2} = 2.82x - .0127x^2$$



$$V_0 = 21.09 - (2.80 - .56)x + .0127x^2 = .0127x^2 - 2.26x + 21.09 = 0$$

$$x = \frac{2.26 - \sqrt{5.10 - (4 \times .0127 \times 21.09)}}{.0254} = 9.85'$$


$$\begin{aligned} \sum M_x R_A &= 25.29 \times 10.60 &= -268.0 \quad \uparrow \\ \text{Conc} &= 1.20 \times \frac{11.35^2}{2} &= -38.6 \\ P_{T1} &= 3.42 \times \frac{11.35^2}{2} &= +220.0 \quad \downarrow \\ P_{T2} &= .0127 \times \frac{11.35^3}{3} &= -6.2 \\ H_2O &= .0625 \times 9.00 \times \frac{9.85^2}{2} &= -27.3 \\ &&= -120.1 \text{ K} \quad \uparrow \\ A_b &= \frac{120.1}{1.44 \times 44} = 1.89 \text{ ft}^2 \end{aligned}$$

Case III $\sum M R_A$

$$\begin{aligned} P_{T1} &= 1.93 \times 22.42 &= -43.30 \times 10.46 &= -452.0 \text{ ft}^2 \uparrow \\ P_{T2} &= \frac{1}{2} \times .58 \times 22.42 &= -6.50 \times 6.72 &= -43.7 \\ \text{Conc} &= &= +13.45 &= +140.8 \quad \downarrow \\ \text{outside } H_2O &= .0625 \times 6.0 \times 6.0 &= +2.25 \times 18.67 &= +42.0 \\ V &= &= -6.53 \times 21.67 &= -141.8 \\ M &= &= &= -67.1 \\ &&= -40.63 &= -521.8 \end{aligned}$$

$$R_B = \frac{521.8}{14.92} = +35.0 \text{ K} \quad R_A = 40.63 - 35.0 = +5.63 \text{ K}$$

$$V_0 = (2.51 - .60) \times -.0258 \frac{x^2}{2} = 1.91 \times -.0129 x^2$$



$$V = .0129 x^2 - 1.91 x + 2.76 = 0$$

$$x = \frac{1.91 - \sqrt{3.65 - (4 \times .0129 \times 2.76)}}{.0258} = 1.55'$$

PROJECT Chicopee Falls


SUBJECT Main St. Pump St.

PROJECT NO. 6205
 SHEET NO. _____ OF _____
 DATE 3/11/63
 COMPUTED BY JK
 CHECKED BY GR

$$\begin{aligned}
 R_A &= 5.63 \times 3.51 && - 19.8 \\
 \text{CONC} &= .60 \times \frac{4.26^2}{2} && - 5.4 \\
 P_1 &= 2.51 \times \frac{4.26^2}{2} && + 22.8 \\
 P_{T2} &= .0129 \times \frac{4.26^3}{3} && - 0.3 \\
 &&& - 2.7'k
 \end{aligned}$$

$$A_s = \frac{2.7}{1.44 \times 44} = .04 \square''$$

$$\text{min } A_s = .002 \times 12 \times 48 = 1.15 \square''$$



$$\begin{aligned}
 \# 11 @ 12 & \quad 2.11 \square'' \text{ req @ pump well} \\
 A_s &= \frac{1.56 \square}{.55} = \# 7 @ 12
 \end{aligned}$$

SLAB - OVER FILLED CHAMBERS

FLOOR ELEVATION 84.0
HI. WATER ELEVATION 105.0
∴ WATER = 21.0 FT.
INSIDE DIMENSIONS 6' x 5.0'
21.0 x .0625 = 1.31 KSF

$$+M = \frac{1}{14} (1.31) (5+2)^2 = 4.59 \text{ K}$$

$$-M = \frac{1}{9} (1.31) (7)^2 = 7.14 \text{ K}$$

$$d^2 = \frac{7,140 \times 12}{160 \times 12} = 6.7 \text{ in}^2$$

USING 12" SLAB, $d = 10^{\pm}$

$$+ \quad -A_s = \frac{4,590}{.885 \times 20,000 \times 10} = .026 \text{ in}^2/\text{in} \quad \# 5 @ 12" \text{ C-C}$$

$$- \quad A_s = \frac{7,140}{.885 \times 20,000 \times 10} = .040 \text{ in}^2/\text{in} \quad \# 6 @ 12" \text{ C-C}$$

$$\text{SHEAR } V = 1.15 wL = 1.15 \times 1.31 \times 7 = 10.6 \text{ K}$$

$$v = \frac{10,500}{(12) \times (9) \times (10)} = 97.5 \text{ psi} > 90 \text{ psi}$$


∴ USE 15" SLAB $d = 13.5$ ACTUAL SLAB = 18" USED

$$(// \text{ to RIVER}) +A_s = \frac{.026 \times 10}{13.5} = .0193 \text{ in}^2/\text{in} \quad \# 5 - 12" \text{ C-C (BOTTOM)}$$

$$-A_s = \frac{.040 \times 10}{13.5} = .0296 \text{ in}^2/\text{in} \quad \# 5 - 11" \text{ C-C (TOP)}$$

$$v = \frac{97.5 \times 10}{13.5} = 72 \text{ psi (OK)}$$

USE #5-12" BOTH WAYS TOP + BOTTOM



PROJECT CHICOPEE FALLS

SUBJECT MAIN ST PUMPING STATION

PROJECT NO. 6205-2

SHEET NO. 16 OF 16

DATE FEB 63


COMPUTED BY DJR

CHECKED BY 1

STOP LOG COLUMNS MIN WIDTH 2'-0"

CONTINUE WALL DESIGN ADJACENT TO STATION TO TIE INTO STATION USING THE 1'-6" DESIGN BEFORE - REFER TO WALL DESIGN

CONSIDERING CHAMBER FULL AND ONE EMPTY. WITH 21'± FT OF WATER PRESSING ABOVE SLAB (AT EL 84.) 3 FT. CANTILEVER FOR UNIFORM LOAD




$$P = .0625 \times 21^3 = 1.31 \text{ K/FT UNIFORM LOAD}$$

$$U = 1.31 \times 3' \times 1.5' = 5.9 \text{ K}$$

EA. FACE - VERTICAL STEEL :

$$A_s = \frac{5,900}{(.907)(27,000)(20)} = .012 \text{ m}^2/\text{in} \quad \text{AT BOTTOM}$$

[#6-12" ALL THE WAY UP]



HOIST SLAB OR TRAVEL

36" INTAKE - 11,600# AT STALL (MACMILLAN MILLS)
SAY - 900# APPARATUS
12,500#

GATE SUPPORT APP. 1'-0" FROM WALL

SLAB WIDTH OF 2 FT.


$$M = 12,500 \times 1.0 = 12,500 \text{ FT}$$

$$d = \sqrt{\frac{12,500 \times 12}{160 \times 12}} = 8.8 \text{ IN}$$

BENT BARS:

$$A_s = \frac{12,500}{.885(20,000)(8.8)(2 \text{ FT})} = .040 \text{ m}^2/\text{in}$$

USE #6-9" C-C (.049 m²/in)



PROJECT CHICOPEE FALLS

SUBJECT MAIN ST. DUMPING STATION

PROJECT NO. 6205-2
SHEET NO. 24 OF
DATE FEB 63
COMPUTED BY DR
CHECKED BY

LOADING #1 (BOTTOM FOOT) EL 75. FT

WATER @ 105.0 : $105 - 75 = 30$ FEET WATER
 $W = .0625 \times 30' = 1.875$ K/FT/FT. (RIVER SIDE)

WATER IN SOIL @ 89.0 : $89 - 75 = 14$ FEET WATER
 $W = .0625 \times 14' = 0.875$ K/FT/FT.

LATERAL EARTH (14') SATURATED. $\frac{1}{3} [1.135 - .0625] = .0242$ K/FT.³

$E = .0242 \times 14 = 0.340$ K/FT/FT. (LAND SIDE)

$E = .0242 \times 7 = 0.170$ K/FT/FT (RIVER SIDE)

WATER IN STATION = NEGLIGIBLE ≈ 0 (FOR WORST CASE)

LOADING #1 (EL. 91. FT.)

WATER @ 105.0 : $105 - 91 = 14$ FEET WATER

$W = .0625 \times 14 = 0.875$ K/FT/FT.

WATER IN SOIL @ 91 gives NO WATER PRESSURE
NO SOIL PRESSURE

LOADING #2 (BOTTOM FOOT) (EL. 75 FT.)

WATER @ 102.0 : $102 - 75 = 27$ FEET WATER

$W = .0625 \times 27 = 1.69$ K/FT/FT

WATER IN SOIL = 0.875 K/FT/FT

LATERAL EARTH = 0.340 K/FT/FT & 0.170 K/FT/FT

WATER IN STATION = NEGLIGIBLE ≈ 0 (WORST CASE)

LOADING #2 (EL 91 FEET)

WATER @ 102.0 : $102 - 91 = 11$ FEET WATER

$W = .0625 \times 11 = 0.69$ K/FT/FT

LOADING #3 (EL 75.0 BOTTOM FOOT) (REFER P 8)

WATER AT 80.0 EL. $80 - 75 = 5$ FEET WATER

$W = .0625 \times 5 = 0.312$ K/FT/FT

(Continued) A-27


LOADING #3 (continued) BOTTOM FOOT.

Pos : EARTH + T 89.0 ADD 3' SURCHARGE
 WATER AT 80.0

(PAGE 8) Pos1 : $.130 \times \frac{1}{3} \times 12 = .520 \text{ K/FT/FT}$ ORDINATE
 Pos2 : $.0725 \times \frac{1}{3} \times 5 = .121 \text{ K/FT/FT}$ ORDINATE
 $\text{LATERAL (E)} = .0641 \text{ K/FT/FT}$ LAND SIDE
 LATERAL E = $.017 \text{ K/FT/FT}$ WATERSIDE
 WATER INSIDE STATION = NEGLIGIBLE


LOADING #1

REFER TO P 24 CC





It's all the same

$$\begin{aligned} \text{FEM}_{AB-BA} &= \frac{1}{2}(2.045)(15.5)^2 = \pm 40.9 \text{ 'K} & \dot{E} K_{AB-BA} &= \frac{100}{15.5} = 6.45 \\ \text{FEM}_{AC-CA} &= \frac{1}{2}(1.215)(15.)^2 = \pm 22.8 \text{ 'K} & \dot{E} K_{AC-CA} &= \frac{100}{15.} = 6.67 \\ \text{FEM}_{CD-DC} &= \frac{1}{2}(1.215)(15.5)^2 = \pm 24.3 \text{ 'K} & \dot{E} K_{CD-DC} &= \frac{100}{15.5} = 6.45 \\ \text{FEM}_{DE-ED} &= \frac{1}{2}(1.215)(6)^2 = \pm 3.6 \text{ 'K} & \dot{E} K_{ED-DE} &= \frac{100}{6} = 16.67 \\ \text{FEM}_{EF-FE} &= \frac{1}{2}(1.215)(10)^2 = \pm 10.1 \text{ 'K} & \dot{E} K_{EF-FE} &= \frac{100}{10} = 10.0 \\ \text{FEM}_{FG-GF} &= \frac{1}{2}(1.215)(6)^2 = \pm 3.6 \text{ 'K} & \dot{E} K_{FG-GF} &= \frac{100}{6} = 16.67 \\ \text{FEM}_{GB-BG} &= \frac{1}{2}(1.215)(5.)^2 = \pm 2.5 \text{ 'K} & \dot{E} K_{GB-BG} &= \frac{100}{5.0} = 20 \\ & & \dot{E} K_{GD-DG} &= \frac{100}{10} = 10 \end{aligned}$$



LOADING #1 (BOTTOM FOOT)




SHEAR FROM UNIFORM LOADS PLUS ABOVE SHEAR :

$W \times \frac{1}{2}$ + SHEAR :


- AB = 15.85K ↑ ± 0.11 K
- AC = 9.12K ↑ ± 0.82 K
- CD = 9.40K ↓ ± 0.00 K
- DE = 3.62K ↓ ± 1.05 K
- EF = 6.08K → ± 0.35 K
- FG = 3.62K ↑ ± 2.11 K
- GB = 8.66K → ± 4.74 K
- GD = 0 ± 1.59 K

UNBALANCE ASSUMED TAKEN BY THIS RIGID STRUCTURE - DISCUSSED THAT THERE WILL BE AN UNBALANCE BUT IT WILL ENTER THE BASE WITH MINOR CHANGES IN MOMENT


BOTTOM FOOT:



NET = 0.82K BOTTOM FT.



ASSUMING IF POSSIBLE! G, VERTICALLY CAN MOVE FREELY



(NEGLIGIBLE)


$$M = 14 \times \frac{1}{3} \times 0.81 \times 14 = 2.64K$$

$$A_s = \frac{26,4000}{.907 \times 27,000 \times 6.8} = .0166 \frac{in^2}{in}$$

∴ MIN STEEL VERTICALLY @ F

(SEE LATER SHEETS) A-30


TENSION SIDE LOADING* BOTTOM FOOT



(FROM P27)


- A-B → $\frac{15.96}{x_L} = \frac{31.90}{15.5} \hat{=} x_L = 7.78' \equiv (15.96)(\frac{1}{2})(7.78) = 62.1 - 33.8 \rightarrow 28.3'k @ 7.78'$
- A-C → $\frac{8.30}{x_R} = \frac{15.24}{15.0} \hat{=} x_R = 6.82' \equiv (8.30)(\frac{1}{2})(6.82) = 28.3 - 33.8 \rightarrow 55'k @ 6.82'$
- C-D → $x_L = 7.75' \equiv (9.40)(\frac{1}{2})(7.75) = 36.4 - 21.6 \rightarrow 14.8'k @ 7.75'$
- D-E → $\frac{2.57}{x_R} = \frac{7.24}{6'} \hat{=} x_R = 2.12' \equiv (2.12)(\frac{1}{2})(2.57) = 2.7 - 6.2 \rightarrow 3.9'k @ 2.12'$
- E-F → $\frac{5.73}{x_L} = \frac{12.16}{10} \hat{=} x_L = 5.72' \equiv (5.72)(\frac{1}{2})(5.73) = 16.4 - 6.2 \rightarrow 10.2'k @ 5.72'$
- G-F → $\frac{5.73}{x_R} = \frac{7.24}{6'} \hat{=} x_R = 4.75' \equiv (5.73)(\frac{1}{2})(4.75) = 13.6 - 9.7 \rightarrow 3.9'k @ 4.75'$

LOADING #2 (REFER TO P24 ETC.)




$FEM_{AB-BA} = \frac{1}{2}(1.84)(5.5)^2 = \mp 37.3 \text{ 'K}$
 $FEM_{AC-CA} = \quad \quad \quad = \mp 22.8 \text{ 'K}$
 $FEM_{CD-DC} = \quad \quad \quad = \mp 24.3 \text{ 'K}$
 $FEM_{DE-ED} = \quad \quad \quad = \mp 3.6 \text{ 'K}$
 $FEM_{EF-FE} = \quad \quad \quad = \mp 10.1 \text{ 'K}$
 $FEM_{FG-GF} = \quad \quad \quad = \mp 3.6 \text{ 'K}$
 $FEM_{QB-BQ} = \quad \quad \quad = \mp 2.5 \text{ 'K}$

(REFER P26)





LOADING #2 (BOTTOM FOOT)



W_{R/2} + SHEAR :

AB =	14.40K ↑	± 0.03K
AC =	9.12K →	± 0.60K
CD =	9.40K ↓	± 0.05K
DE =	3.62K ↑	± 1.06K
EF =	6.08K →	± 0.37K
FG =	3.62K ↑	± 2.00K
GB =	3.04K →	± 8.16K
GD =	0	± 1.42K




PROJECT CHICOPEE FALLS

SUBJECT MAIN ST. PUMPING STATION

PROJECT NO. 6205-2
SHEET NO. 31 OF
DATE MAR 63
COMPUTED BY DR
CHECKED BY

TENSION SIDE LOADING BOTTOM FOOT.



$$AB \rightarrow \frac{14.43}{x_L} = \frac{28.80}{15.5} \quad \epsilon x_L = 7.78' \quad \therefore (14.43)(\frac{1}{2})(7.78) = 55.6'k - 31.7 = 23.9'k @ 7.78'$$

$$AC \rightarrow \frac{9.72}{x_L} = \frac{18.24}{15.0} \quad \epsilon x_L = 8.00' \quad \therefore (9.72)(\frac{1}{2})(8.00) = 38.9 - 22.2 = 16.7'k @ 8.00'$$

$$CD \rightarrow \frac{9.45}{x_L} = \frac{18.80}{15.5} \quad \epsilon x_L = 7.80' \quad \therefore (9.45)(\frac{1}{2})(7.80) = 36.9 - 22.2 = 14.7'k @ 7.80'$$


$$DE \rightarrow \frac{4.68}{x_L} = \frac{7.24}{6.0} \quad \epsilon x_L = 3.88' \quad \therefore (3.88)(\frac{1}{2})(4.68) = 9.1 - 12.4 = -3.3'k @ 3.88'$$

$$EF \rightarrow \frac{5.71}{x_L} = \frac{12.16}{10} \quad \epsilon x_L = 4.71' \quad \therefore (4.71)(\frac{1}{2})(5.71) = 13.5 - 6.0 = 7.5'k @ 4.71'$$

$$GF \rightarrow \frac{1.62}{x_L} = \frac{7.24}{6} \quad \epsilon x_L = 1.34' \quad \therefore (1.34)(\frac{1}{2})(1.62) = 1.2 + 2.3 = 3.5'k @ 1.34'$$

LOADING #3

(REFER P24,25)



COMPARING LOADING #3 - LOADING #2

ALL LOADINGS UNDER #3 ARE

LESS AND THE WALLS BEND SIMILARLY.

$$FEM_{AB} = \frac{1}{2}(.482)(15.5)^2 = 9.0'K \text{ VS. } 40.9'K_{\text{ref}}$$

A STATEMENT CAN BE MADE SAYING


THAT LD. #2 LOADS AND BENDING WILL GOVERN AS COMPARED TO LD. #3.

ADDITIONAL LOADING : (BOTTOM FOOT)

[TO BE ADDED TO MAKE MAX. CONDITIONS WHERE NEEDED]

WATER ON INSIDE CHAMBERS AT EL. 83.0 ∴ 9 FEET OF WATER

$$.0625 \times 9 = .5625 \text{ K/FT.}$$



$$FEM_{AB-BA} = \frac{1}{2}(.563)(15.5)^2 = 11.2'K$$

$$FEM_{CD-DC} = \frac{1}{2}(.563)(15.)^2 = 10.5'K$$

$$FEM_{AC-CA} = \frac{1}{2}(.563)(15.)^2 = 10.5'K$$


$$FEM_{DE-ED} = \frac{1}{2}(.563)(6)^2 = 1.7'K$$

$$FEM_{GF-FG} =$$

$$FEM_{FE-EF} = \frac{1}{2}(.563)(10)^2 = 4.7'K$$


$$FEM_{BG-GB} = \frac{1}{2}(.563)(5.)^2 = 1.2'K$$

ADDITIONAL LOADS: (BOTTOM FOOT)




QA-36

ADDITIONAL LOAD (BOTTOM FOOT)




$wl/2 + \text{SHEAR} :$

AB =	4.36k	± 0.18k
AC =	4.22k	± 0.05k
CD =	4.36k	± 0.11k
DE =	1.69k	± 0.28k
EF =	2.81k	± 0.04k
FG =	1.69k	± 0.73k
BG =	1.41k	± 1.98k
GD =	0	± 0.55k




TENSION SIDE (LOADING ADDITIONAL)



$AB \rightarrow \frac{4.54}{x_L} = \frac{8.82}{15.5} \quad x_L = 8.07' \quad \therefore (4.54)(\frac{1}{2})(8.07) = 18.3 - 11.7 = 6.6'K @ 8.07'$
 $AC \rightarrow \frac{4.27}{x} = \frac{8.44}{15} \quad x_L = 7.62' \quad \therefore (4.27)(\frac{1}{2})(7.62) = 16.2 - 11.7 = 4.5'K @ 7.62'$
 $CD \rightarrow \frac{4.47}{x_L} = \frac{8.72}{15.5} \quad x_L = 7.95' \quad \therefore (4.47)(\frac{1}{2})(7.95) = 17.8 - 11.0 = 6.8'K @ 7.95'$
 $DE \rightarrow \frac{1.97}{x_L} = \frac{3.38}{6} \quad x_L = 3.50' \quad \therefore (1.97)(\frac{1}{2})(3.50) = 3.4 - 5.7 = -2.3'K @ 3.50'$
 $EF \rightarrow \frac{2.85}{x_L} = \frac{5.62}{10} \quad x_L = 5.08' \quad \therefore (2.85)(\frac{1}{2})(5.08) = 7.2 - 4.0 = 3.2'K @ 5.08'$
 $G-F \rightarrow \frac{0.96}{x_L} = \frac{3.38}{6} \quad x_L = 1.70' \quad \therefore (0.96)(\frac{1}{2})(1.70) = 0.8 - 0.0 = 0.8'K @ 1.70'$

UNIT LOADING : {WALL DESIGN EL. 91.0}




$$FEM_{AB-BA} = \frac{1}{2}(1)(15.7)^2 = 20.5'k$$

$$K_{AB-BA} = \frac{100}{15.7} = 6.38$$


$$K_{AC-CA} = \left(\frac{12}{8}\right)^3 \left(\frac{100}{15.2}\right) = 1.95$$

$$K_{AD-DA} = \left(\frac{12}{8}\right)^3 \left(\frac{100}{15.2}\right) = 1.95$$



$$K_{CB-BC} = \left(\frac{12}{18}\right)^3 \left(\frac{100}{15.7}\right) = 1.89$$



WALL DESIGN EL 91.0 (UNIT LOADING)



$wl/2 + \text{shear}$
 $A'B' = 7.85 \uparrow \pm 0'K$
 $A'C = 0 \pm 0.55'K$
 $C'D = 0 \pm 0.00$
 $B'D' = 0 \pm 0.55'K$



$AB \rightarrow (7.85 \times \frac{1}{2}) (\frac{5.7}{2}) = 30.8'K$
 $30.8 - 7.0 = 23.8'K$

PROJECT CHICOPEE FALLS

SUBJECT MAIN ST. PUMPING STATION



PROJECT NO. 6205
 SHEET NO. 38 OF
 DATE MAR 63
 COMPUTED BY DR
 CHECKED BY PP

LOADING #1 @ EL 91.0 (REFER P. 37)


0.875 K/FT ACROSS A'B'
 [∴ 7.0' × 0.875 = 6.1'K IN A'B']

LOADING #2 @ EL 91.0 (REFER P. 37)

0.69 K/FT ACROSS A'B'



SUMMARY: (BOTTOM FOOT) REFER PREVIOUS PAGES (MAX-MIN) [ON TENSION SIDE]
(ADDITIONAL LOAD USED P. 32)*



PROJECT Chicopee Falls

SUBJECT Main Street Pump Sta.

Vertical Reinf in walls

12" wall

$$A_s = .002 \times 12 \times 12 = .29 \square'' \approx .15 \square'' \text{ ea face}$$

18" wall

$$A_s = .002 \times 12 \times 18 = .43 \square'' \approx .22 \square'' \text{ ea face}$$

} Use #6@12"
ea face
USE #5-12" ABOVE
EL. 90.0

Base slab


$$\text{Min } A_s = .002 \times 12 \times 48 = 1.15$$

#11@16"
USE: MAX #6-12" C-C

•
•

BOTTOM FT. - UNBALANCED SHEAR

P.A.30-



$$V = 15.9 \times 30/2 - 9.40 \times 14/2 = 172K$$

$$v = \frac{172,000}{15 \times 1.5 \times 144} = 53 \text{ PSI (OK)}$$

AVE LD. AT BOTTOM FT.

$$\downarrow (17.54 + 15.96) / 2 = 16.75K \downarrow$$

$$\uparrow 9.40K$$

$$M = 16.75 \times 30^2/6 - 9.40 \times 14^2/6$$

$$M = 2510'K - 307'K = 2203'K$$

CONSIDERING THE BOX
 REFER P4. R.C. HAND BOOK:



to be



T BEAM

$$S_s = 27,000 \text{ PSI}$$

$$f_c = 1400 \text{ PSI}$$

$$d = 15 \text{ FT} - 9" \text{ AVE} = 14.2 \text{ FT}$$

$$b = 15.5 \text{ FT}$$

$$M = 2203'K$$

$$t = 1.5' \quad t/b = .105$$

$$k = 115 \text{ (TABLE 8)}$$

$$b \times d = 220 \times 144 = 31,700 \text{ IN}^2 \times 155$$

$$F = \frac{b \times d^2}{12,000} = 451$$

$$M = 2203 = 2203$$

$$kF = 115 \times 451 = 51,900$$


$$M - kF = 49,700$$

$$a = 2.14 \text{ (TABLE 8)}$$

$$A_s = \frac{2703}{2.14 \times 14.2' \times 12} = 6.07 \text{ IN}^2 / 15.5 \text{ FT.}$$

$$A_s = 0.39 \text{ M}^2 / \text{FT} < \underline{\underline{*6@12" \text{ BOTH FACES ARE O.K.}}}$$

P.A.33



$$V = 14.43 \times 27/2 - 9.72 \times 14/2 = 127K$$

$$< 90 \text{ PSI}$$

AVE LD. AT BOTTOM FT.

$$\downarrow (14.43 + 15.99) / 2 = 15.21K$$

$$\uparrow (9.72 + 9.35) / 2 = 9.53K$$

$$M = 15.21 \times 27^2/6 - 9.53 \times 14^2/6$$

$$M = 1850 - 311 = 1539'K$$

STEEL REFER TOP. 38

$d = 18" - 3.5 = 14.5"$

@ A OUTSIDE : $A_s = \frac{31,700}{(14.5)(20,000)(.885)} = 0.124 \text{ m}^2/\text{IN}$ LD#2
 (257,000) [#9-8" or #8-6c.c]

AB MID PT : $A_s = \frac{28,300}{(14.5)(27,000)(.91)} = 0.0798 \text{ m}^2/\text{in}$ LD#1
 (INSIDE) (355,000) [#8-9 1/2 or #7-7 1/2]

@ B OUTSIDE : $A_s = \frac{32,200}{257,000} = 0.125 \text{ m}^2/\text{IN}$ LD#2
 [#9-8" or #8-6c.c]

AC MID PT. $A_s = \frac{9,600}{355,000} = 0.027 \text{ m}^2/\text{IN}$ LD#1
 (INSIDE) [#5-12"]

@ C OUTSIDE : $A_s = \frac{22,000}{257,000} = 0.0868 \text{ IN}^2/\text{IN}$ LD#2
 [#8-9" etc]

CD MID PT. $A_s = \frac{15,200}{257,000} = 0.0592 \text{ in}^2/\text{IN}$ LD#2
 (OUTSIDE) [#7-10" or #6-7 1/2"]

@ D OUTSIDE IT. $A_s = \frac{21,400}{257,000} = 0.0513 \text{ m}^2/\text{IN}$ LD#2
 [#6-8 1/2" or #7-11.7"]

@ D OUTSIDE RT $A_s = \frac{12,400}{(11.5)(20,000)(.885)} = 0.0608 \text{ m}^2/\text{IN}$ LD#2
 (204,000) [#7-10"]

DE MID PT : #5-12" (INSPECTION)

@ E OUTSIDE : $A_s = \frac{6,000}{204,000} = 0.0294 \text{ in}^2/\text{IN}$ LD#2
 [#5-11"]

EF MID PT : $A_s = \frac{7,500}{204,000} = 0.0368 \text{ m}^2/\text{IN}$ LD#2
 [#6-12"]
 [#5-8"]

PROJECT CHICOPEE FALLS

SUBJECT MAJEST PUMPING STATION

PROJECT NO. 6209-2
 SHEET NO. 41 OF _____
 DATE MAR 63
 COMPUTED BY [Signature]
 CHECKED BY [Signature]


EL. 91.0 AND UP REFER P38 $d = 12 - \#6 - \frac{1}{2} = 10^2$

(a) A' outside $A_s = \frac{6,100}{(907)(27,000)(10)} = 0.025 \text{ m}^2/\text{in}$ LD#1-

$A_s = \frac{4,800}{(.885)(20,000)(10)} = 0.0271 \text{ m}^2/\text{in}$ LD#2 - #5-12

- A' B' - $A_s = \frac{16,400}{257,000} = 0.0638 \text{ m}^2/\text{in}$ LD#2
 $d = 18'' - 3.5'' \text{ AS BELOW}$ [#8-12]
 $d = 18'' - 3'' - .5'' = \underline{14.5''}$

— RIVER SIDE —



LAP = 24 DIA
 1" = 5' SCALE
 #5-12 STRIKING

I. DEAD LOAD ONLY
 EAST - WEST DIRECTION
 MOMENTS AT WEST WALL

REF ARCH.
 PLATES #11 & 12

MARK	FACTORS	↓	↑	ARM	M _D	M _A
BASE SLAB C ₁	0.15 x 2.5 x 21.0 x 27.92	219		10.5	2300	
do C ₂	0.15 x 3.0 x 3.0 x 21.0	28		10.5	294	
do C ₃	0.15 x 2.0 x 6.75 x 21.0	42		10.5	441	
do C ₄	0.15 x 2.0 x 2 x 8.0 x 8.0	38		25.0	935	
W. WALL OUTLET CH.	0.15 x 1.5 x 12.67 x 24.25	69		0.75	52	
do SUMP	0.15 x 1.5 x 15.17 x 13.06	44		0.75	33	
do PUMP	0.15 x 1.0 x 15.08 x 14.19	32		0.5	16	
HOLE - FAN	0.15 x 1.0 x 2.5 x 2.5		1	0.5		1
W. WALL INTAKE	0.15 x 1.25 x 6.75 x 13.0	16		0.62	10	
do LOUVER	0.15 x 1.5 x 4.0 x 6.0		5	0.75		4
E. WALL OUTLET	0.15 x 1.5 x 12.67 x 13.37	31		20.25	625	
do do	0.15 x 1.42 x 12.67 x 13.52	36		20.2	730	
HOLE - GATE	0.15 x 1.5 x 4.0 x 4.0		5	20.25		101
E. WALL - SUMP	0.15 x 1.5 x 15.17 x 13.06	45		20.25	910	
do - PUMP	0.15 x 1.0 x 15.08 x 14.19	32		20.42	653	
DOOR	0.15 x 1.0 x 5.0 x 7.0		5	20.42		103
WINDOW	0.15 x 1.0 x 5.0 x 5.0		3	20.42		70
HOLE	0.15 x 1.0 x 1.0 x 1.3		1	20.42		20
CENTER WALL	0.15 x 1.5 x 18.0 x 10.73	44		10.5	460	
do	0.15 x 1.25 x 18.0 x 14.19	48		10.5	500	
HOLES	3 x 0.15 x 1.5 x 2 x 2		3	9.5		28
		724	23		7922	327
		23			-327	
		701			7595	

MARK	FACTORS	↓	↑	ARM	M ²	M ³
S. WALL	0.15x1.5x18.0x10.73	44		10.5	460	
do	0.15x1.42x18.0x13.52	52		10.5	545	
N. WALL	0.15x1.5x18.0x13.06	53		10.5	545	
do	0.15x1.0x18.92x14.19	41		10.5	430	
HOLES	0.15x1.5x5x3x2		7	7.5		52
do	0.15x1.0x5x3x3		7	9.5		67
N. WALL INTAKE	0.15x1.25x26.5x13.0	64		14.5	930	
EXTEND	0.15x1.25x16.0x13.0	15		28.38	425	
GATEWALL	0.15x1.25x5.5x13.0	13		20.38	262	
HOLE	0.15x1.25x4x4		3	20.36		61
S. WALL INTAKE	0.15x1.25x6.75x13.0	16		24.38	390	
HOLE	0.15x1.25xπx2 ²		2	24.38		49
COVER	0.15x0.5x5.5x26.5	11		14.50	160	
HOLE	0.15x0.5x5.5x2.0		1	16.0		16
E. INTAKE	0.15x1.25x10x10	19		28.38	540	
HOLES	0.15x1.25x6.75x10.2	25		24.38	610	
	0.15x1.25xπx2 ² x2		5	24.38		122
COVER	0.15x0.5x5.5x6.75	3		24.38	73	
DISCHARGE	0.15x1.0x4.5x18.0	12		10.5	126	
IF	0.15x1.0x5.0x18.0	14		10.5	147	
GRAVE	0.135x3.5x5.0x18.0	42.5		10.5	445	
PIERS	0.15x4.5x6.25x18.25	77		9.6	740	
STOP LOGS	36/4x1x4.17x.04	1.5		10.5	16	
do	48/4x1x6.5x.04	3		17.25	51	
INTAKE COVERS	0.15x0.5x3x3x2		1	26		26

Omitted (A) Arm M
 1.15x2.25x1.5x18.25=9 18.37=165
 506 26 6895 393
 26 373
 480 6502
 B-2

I. Cont. Dead Load, East-West Direction
Moments at West Wall.

Mark	Factors	↓	↑	Arm	M	M
Roof	$0.15 \times 0.5 \times 18.0 \times 10'$	13.5		10.5	142	
do	$0.15 \times 0.5 \times 14.08 \times 18.83$	19.8		10.5	208	
Holes	$0.15 \times 0.5 \times 2.0 \times 3.0 \times 3$		1.3	9.0		12
do	$0.15 \times 0.5 \times 2.0 \times 6.0$		1.	18		18
do	$0.15 \times 0.5 \times 3.5 \times 2.5$		0.7	2.5		2
Parapet	$0.15 \times 1.0 \times 2.0 \times 94$ $= (2 \times 28 + 2 \times 19)$	28.2		10.5	296	
Cross Raills	$(.031 + .035) \times 55'$	3.5		10.5	37	
Pump R. Floor	$0.15 \times 1.0 \times 14.08 \times 18.93$	40.		10.5	420	
Holes	$0.15 \times 1.0 \times 2' \times 2' \times 3$		1.8	9.5		17
do	$0.15 \times 1.0 \times 1 \times 1.25 \times 2$		0.4	10.5		4
do	$0.15 \times 1.0 \times 2.5 \times 2.5$		1.0	18.		18
do	$0.15 \times 1.0 \times \pi \cdot 3/4$		1.0	3.		3
		105	7.2		1103	74
		7			74	
		98			1029	
		712			7842	
		481			6529	
		1291			15398	
PUMPRM FLOOR, .15 x 13.42 x 18.0 = 36.2		ARM	M			
			10.5	380		
CORRECT. PUMP RAILL ADDITION, (A)		- 4			- 40	
		+ 9			+ 145	
		1296			15523	

See Below

Note: For purposes of weight, pump room floor is considered to be a 12' slab. B-3

I. Dead Load Only.
 North-South Direction.
 Moments at South Wall

Mark	Factors	↓	↑	Arm	M ↓	M ↑
Base slab ✓		219 ✓		13.96 ✓	3060 ✓	
do ✓		28 ✓		11.5 ✓	322 ✓	
do ✓		42 ✓		30.5 ✓	1280 ✓	
do ✓		38 ✓		17.65 ✓	670 ✓	660 ✓
W. Wall ✓		69 ✓		6.33 ✓	437 ✓	
do ✓		44 ✓		20.33 ✓	892 ✓	
do ✓		32 ✓		20.3 ✓	650 ✓	
Hole ✓			1 ✓	16 ✓		16 ✓
W. Wall ✓		16 ✓		31.3 ✓	500 ✓	
Hole ✓			5 ✓	4.25 ✓		21 ✓
E. Wall ✓		31 ✓		6.38 ✓	198 ✓	
do ✓		36 ✓		6.38 ✓	229 ✓	
Hole ✓			5 ✓	4.25 ✓		21 ✓
E. Wall ✓		45 ✓		20.3 ✓	913 ✓	
do ✓		32 ✓		20.3 ✓	650 ✓	
Door ✓			5 ✓	16.25 ✓		81 ✓
Window ✓			3 ✓	23.25 ✓		70 ✓
Hole ✓			1 ✓	23.25 ✓		23 ✓
Center wall ✓		44 ✓		12.25 ✓	538 ✓	
do ✓		48 ✓		12.13 ✓	580 ✓	
Holes ✓			3 ✓	12.25 ✓		37 ✓
		724 ✓	23 ✓		10909 ✓	269 ✓
		23 ✓			269 ✓	
		701 ✓			10640 ✓	

I. Cont. Dead Load Only.
 North-South Direction.
 Moments at South Wall.

Mark	Factors	↓	↑	Arm	M	ΣM
S. Wall		44 ✓		0.75 ✓	33 ✓	
do		52 ✓		0.81 ✓	42 ✓	
N. Wall		53 ✓		27.17 ✓	1440 ✓	
do		41 ✓		27.34 ✓	1120 ✓	
Holes			7 ✓	27.17 ✓		190 ✓
"			7 ✓	27.34 ✓		191 ✓
N. Intake		64 ✓		24.05 ✓	1540 ✓	
do		15 ✓		30.67 ✓	460 ✓	
do		13 ✓		30.67 ✓	398 ✓	
Hole			3 ✓	30.67 ✓		92 ✓
N. Intake		16 ✓		27.30 ✓	417 ✓	
Hole			2 ✓	27.30 ✓		55 ✓
Cover		11 ✓		30.67 ✓	336 ✓	
Hole			1 ✓	30.67 ✓		31 ✓
E. Intake		19 ✓		4.0 ✓	76 ✓	
do		25 ✓		4.0 ✓	100 ✓	
Holes			5 ✓	4.0 ✓		20 ✓
cover		3 ✓		4.0 ✓	12 ✓	
Dischge		12 ✓		9.25 ✓	112 ✓	
Gravel		14 ✓		7.5 ✓	105 ✓	
Piers		42.5 ✓		10.0 ✓	425 ✓	
Stop Logs		77 ✓		9.25 ✓	716 ✓	
do		1.5 ✓		8. ✓	12 ✓	
Intake		3. ✓		4 ✓	12 ✓	
Covers			1 ✓	18 ✓		18 ✓
Corrections, p. 6.		480 ✓	26 ✓		7994 ✓	597 ✓
					597 ✓	B-5 ✓
					7397 ✓	

I. Cont. Dead Load. North-South Direction
 Moments at South Wall.

Mark	Factors	↓	↑	Arm	M _D	M _R
Roof		13.5 ✓		6.5 ✓	88 ✓	
do		19.8 ✓		19.79 ✓	391 ✓	
Holes			1.3 ✓	9. ✓		12 ✓
do			1.0 ✓	4. ✓		4 ✓
do			0.7 ✓	25.5 ✓		20 ✓
Parapet		28.2 ✓		14. ✓	394 ✓	
Crane		3.5 ✓		19.79 ✓	69 ✓	
Rails						
Pump Rm		40. ✓		19.79 ✓	792 ✓	
Floor						
Holes			1.8 ✓	16. ✓		29 ✓
do			0.4 ✓	20.5 ✓		8 ✓
do			1.0 ✓	25. ✓		25 ✓
do			1.0 ✓	25 ✓		25 ✓
		105 ✓	7 ✓		1734 ✓	123 ✓
		7 ✓			123 ✓	
		98 ✓			1611 ✓	
		712 ✓			10691 ✓	
		481 ✓			6885 ✓	
		1291 ✓			19187 ✓	
	CORRECTIONS,					
	BASE SLAB, MOM.				-10 ✓	
	N. INTAKE				+620 ✓	
	N. INTAKE				+18 ✓	
	(A)	+ 9 ✓		7.75	+70 ✓	
	PUMP RM. FLOOR	- 4 ✓		19.79	-79 ✓	
		1296 ✓			19806 ✓	

Revised to El. 75.0 See Sheets 7A, 7B & 7C

II. Live Load Only. East-West Direction
Moments at West Wall.

Mark	Factors	↓	↑	Arm	M _↓	M _↑
Snow	$.040 \times 18 \times 26$ <small>20.83 x 27.75</small>	19	23.1	10.5	200	242
Water El. 80.0	$.0625 \times 7 \times 13.5 \times 18$	106		10.5	1110	
Discharge chamber	$.0625 \times 5.5 \times 18 \times 23.75$	147		10.5	1540	
do	$.0625 \times 4.5 \times 3.17 \times 17.75 \times 3$	48		9.42	451	444
Crane		4		10.5	42	
Pumps	3 x 3	9		9.42	85	
Gear Unit	3 x 1	3		9.42	28	
Thrust Engine	3 x 3	9		9.42	85	
		6		9.42	57	
WATER IN N. INTAKE $.0625 \times 7 \times 55 \times 25.75$		351		14.12	3598	
WATER IN E. " $.0625 \times 8 \times 5.5 \times 6.75$		20.8		24.37	825	
CORRECTION SNOW & DISCH. CHAMBER		+ 9.1			+ 35	
		437.9			5018	
II. LIVE LOAD ONLY N-S DIRECTION MOMENTS AT SOUTH WALL						
Snow		19		14	266	
Water		106		19.75	2090	
do		147		4.25	624	
do		48		9.25	443	
Crane		4		19.75	79	
Pumps		9		16	144	
Gears		3		16	48	
Thrust		9		16	144	
Exhaust		6		21	126	
WATER IN N. INTAKE		351		30.67	3964	
" " E. "		20.8		4.50	94	
CORRECTION SNOW		4.1		14.00	57	
		439.5			6065	

COMPUTATION FOR DIFFERENCE OF 5'-0" (80.0 TO 75.0 FT)
IN W. IN SUMP BAY AND N. INTAKE BAY,
THIS WILL BE A REDUCTION IN LIVE LOAD,
 $.0625 \times 5 = .313 \text{ KPSF.}$

USING FIGURES ON P 7 & 8 FOR AREAS AND ARMS,
E-W DIRECTION MOMENTS AT W. WALL,

		↓	↑	ARM.	M _W	M _N
WATER IN SUMP	$.313 \times 13.5 \times 18$	76.		10.5	798	
N. INTAKE	$.313 \times 5.5 \times 25.25$	44.		13.87	610	
E "	$.313 \times 5.5 \times 6.75$	12		24.37	292	
		132			1700.	


N-S DIRECTION MOMENTS AT SOUTH WALL,


		↓	↑	ARM.	M _W	M _N
WATER IN SUMP		76		19.75	1500	
N. INTAKE		44		30.67	1350	
E INTAKE		12		4.50	54	
		132			2904	

SOIL PRESSURES FROM 5'-0" OF WATER ABOVE,

C.G. OF LOADS FROM N-S AXIS, $\frac{1700}{132} = 12.90$ $\bar{y} = 12.90 - 12.70 = .20$
TOWARD EAST,

C.G. OF LOADS FROM E-W AXIS, $\frac{2904}{132} = 22.00$ $\bar{x} = 22.00 - 17.40 = 4.60$
TOWARD NORTH.






SOIL PRESSURES FROM
 5'-0" OF WATER IN SUMP
 AND N & E INLETS.
 TO BE DUCTED FROM
 L+D TO GET PRESSURES
 FROM WATER @ 75.0

A	.132 858	+	$\frac{132 \times 4.6 \times 17.4}{96900}$	-	$\frac{132 \times .20 \times 12.7}{49600}$	=	
	.154	-	.109	-	.007	=	.038
B	.154	+	$\frac{132 \times 4.6 \times 17.35}{96900}$	-	.007	=	
	.154	+	.109	-	.007	=	.256
C	.154	+	.109	+	$\frac{132 \times .20 \times 16.3}{49600}$	=	
	.154	+	.109	+	.009	=	.272
D	.154	-	.109	+	.009	=	.054
E	.154	-	$\frac{132 \times 4.6 \times 9.4}{96900}$	+	.009		
	.154	-	.059	+	.009	=	.104
F	.154	-	.059	+	$\frac{132 \times .20 \times 8.3}{49600}$		
	.154	-	.059	+	.004	=	.099
G	.154	+	$\frac{132 \times 4.6 \times 9.35}{96900}$	+	.004		
	.154	+	.059	+	.004	=	.217
H	.154	+	.059	+	.009	=	.222

B-9



Av. 2.11	1.53
(Av. 1.97)	(1.39)
Av. 1.82	1.25
Av. 1.66	1.09
Av. 1.50	.93

C.G. From West Wall

D.	1296	15523
L.	440	5052
D+L	1736	20575

Dead $\bar{x} = \frac{15523}{1296} = 11.97$


D+L $\bar{x} = \frac{20575}{1736} = 11.85$

C.G. From South Wall

D.	1296	19806
L.	440	6054
D+L	1736	25860

Dead $\bar{y} = \frac{19806}{1296} = 15.3$

D+L $\bar{y} = \frac{25860}{1736} = 14.9$



ABOUT E-W AXIS

$$\begin{aligned}
 21 \times 28 &= 588 \times 14 = 8230 \\
 6.75 \times 21 &= 142 \times 31.38 = 4450 \\
 8 \times 8 &= 64 \times 30.75 = 1970 \\
 8 \times 8 &= 64 \times 4 = 256 \\
 \hline
 &858 \qquad \qquad 14906 \\
 \text{C.G.} &= \frac{14906}{858} = 17.4
 \end{aligned}$$

ABOUT N-S AXIS

$$\begin{aligned}
 21 \times 28 &= 588 \times 10.5 = 6170 \\
 6.75 \times 21 &= 142 \times 10.5 = 1490 \\
 8 \times 8 \times 2 &= 128 \times 25 = 3200 \\
 \hline
 &858 \qquad \qquad 10860 \\
 \text{C.G.} &= \frac{10860}{858} = 12.7
 \end{aligned}$$

I ABOUT E-W AXIS

$$\begin{aligned}
 21 \times \frac{34.75^3}{12} &= 73400 \\
 8 \times \frac{8^3}{12} &= 342 \\
 8 \times \frac{8^3}{12} &= 342 \\
 \hline
 &74084
 \end{aligned}$$


$$\begin{aligned}
 730^1 \times 1.02 &= 220 \\
 64 \times 13.35^2 &= 11400 \\
 64 \times 13.4^2 &= 11450 \\
 \hline
 &22850 \\
 &74084 \\
 \hline
 &96934
 \end{aligned}$$

I ABOUT N-S AXIS


$$\begin{aligned}
 34.75 \times 21^3/12 &= 26700 \\
 2 \times 8 \times 8^3/12 &= 684 \\
 \hline
 &27384
 \end{aligned}$$

$$\begin{aligned}
 588 \times 2.2^2 &= 2840 \\
 2 \times 64 \times 12.3^2 &= 19360 \\
 \hline
 &22200 \\
 &27384 \\
 \hline
 &49584
 \end{aligned}$$


B-11



A.	1296 858	+ $\frac{1296 \times 2.1 \times 17.4}{96934}$	+ $\frac{1296 \times .80 \times 12.7}{49584}$	
	1.51	+ 0.49	+ 0.27	= 2.27
B.	1.51	- $\frac{1296 \times 2.1 \times 17.35}{96934}$	+ 0.27	= 1.29
		(0.49)		
C.	1.51	- 0.49	- $\frac{1296 \times 0.8 \times 16.3}{49584}$	= 0.68
			(0.34)	
D.	1.51	+ 0.49	- 0.34	= 1.66
E.	1.51	+ $\frac{1296 \times 2.1 \times 9.4}{96934}$	- 0.34	= 1.43
		(0.26)		
F.	1.51	+ 0.26	- $\frac{1296 \times 0.8 \times 8.3}{49584}$	= 1.60
			(0.17)	
G.	1.51	- $\frac{1296 \times 2.1 \times 8.35}{96934}$	- 0.17	= 1.08
		(0.26)		
H.	1.51	- 0.26	- 0.34	= 0.91



A.	$\frac{1736}{858}$ (2.02)	$+$	$\frac{1736 \times 2.5 \times 17.4}{96934}$ (0.78)	$+$	$\frac{1736 \times 0.8 \times 12.7}{49584}$ (0.36)	$=$	3.16
B.	2.02	$-$	$\frac{1736 \times 2.5 \times 17.35}{96934}$ (0.78)	$+$	0.36	$=$	1.60
C.	2.02	$-$	0.78	$-$	$\frac{1736 \times 0.8 \times 11.63}{49584}$ (0.46)	$=$	0.78
D.	2.02	$+$	0.78	$-$	0.46	$=$	2.34
E.	2.02	$+$	$\frac{1736 \times 2.5 \times 9.4}{96934}$ (0.42)	$-$	0.46	$=$	1.98
F.	2.02	$+$	0.42	$-$	$\frac{1736 \times 0.8 \times 8.3}{49584}$ (0.22)	$=$	2.21
G.	2.02	$-$	$\frac{1736 \times 2.5 \times 9.35}{96934}$ (0.42)	$-$	0.22	$=$	1.38
H.	2.02	$-$	0.42	$-$	0.46	$=$	1.14




GREEN ENGINEERING AFFILIATES
ENGINEERS
BOSTON, MASS.

PROJECT MASS. CHICOPEE FALLS,

SUBJECT OAK ST. PUMPING STA.

PROJECT NO. 6205-2
SHEET NO. 9F OF _____
DATE MAR. 2 1963
COMPUTED BY M.A.
CHECKED BY FNW



B-15

GREEN ENGINEERING AFFILIATES
ENGINEERS
BOSTON, MASS.

PROJECT MASS. CHICOPEE FALLS

SUBJECT OAK ST. PUMPING STA

UPLIFT MOMENTS AT WEST WALL

PROJECT NO. 6205-2

SHEET NO. 907 OF

DATE MAR. 3, 1963

COMPUTED BY M.A.

CHECKED BY F/W

	UPLIFT	ARM	\curvearrowright
$.99 \times 8.5 \times 2 =$	16.8	} 1.00	
$1.08 \times 3 \times 2 =$	6.5		
$1.17 \times 16.5 \times 2 =$	38.6		
$1.14 \times .67 \times 2 =$	1.5		
$1.12 \times 6.08 \times 2 =$	13.6		
	77.0		77.
$.84 \times 8.5 \times 8 =$	57.2	} 6.00	
$.93 \times 3 \times 8 =$	22.3		
$1.03 \times 16.5 \times 8 =$	135.7		
$.99 \times .67 \times 8 =$	5.3		
$.95 \times 6.08 \times 8 =$	46.2		
	266.7		1600.
$.71 \times 8.5 \times 11 =$	66.4	} 15.5	
$.80 \times 3 \times 11 =$	26.4		
$.90 \times 16.5 \times 11 =$	163.5		
$.89 \times .67 \times 11 =$	6.5		
$.87 \times 6.08 \times 11 =$	58.0		
	320.8		4980.
$.74 \times 8 \times 8 \times 2$	94.7	25.	2370
Σ UPLIFT	759.2		9027
CENTROID FROM WEST WALL			
$\frac{9027}{759.2} = 11.90$			

SUBJECT OAK ST. PUMPING STA.


UPLIFT MOMENTS AT SOUTH WALL

	UPLIFT.	ARM.	\overline{M}
99 x 8.5 x 2	16.8	} 4.25	597.
.84 x 8.5 x 8	57.2		
.71 x 8.5 x 11	66.4		
	<u>140.4</u>		
1.08 x 3 x 2	6.5	} 10	552.
.93 x 3 x 8	22.3		
.80 x 3 x 11	26.4		
	<u>55.2</u>		
1.17 x 16.5 x 2	38.6	} 19.75	6660.
1.03 x 16.5 x 8	135.7		
.90 x 16.5 x 11	163.5		
	<u>337.8</u>		
1.14 x 6.7 x 2	1.5	} 28.33	376.
.99 x 6.7 x 8	5.3		
.89 x 6.7 x 11	6.5		
	<u>13.3</u>		
1.12 x 6.08 x 2	13.6	} 31.71	3730
.95 x 6.08 x 8	46.2		
.87 x 6.08 x 11	58.0		
	<u>117.8</u>		
.74 x 8 x 8 x 2	99.7	17.37	1643
	<u>759.2</u>		<u>13,558.</u>

Σ UPLIFT.

CENTROID FROM SOUTH WALL

$$\frac{13558}{759.2} = 17.85$$



		UPLIFT PRESSURES.		
A	$\frac{759.2}{858.}$	$-\frac{759.2 \times .45 \times 17.40}{96934}$	$+\frac{759.2 \times .80 \times 12.70}{49584}$	
	.89	-.06	+.16	= .99
B	.89	+.06	+.16	= 1.11
C	.89	+.06	$-\frac{759.2 \times .80 \times 16.30}{49584}$	= .75
D	.89	-.06	$-.20$	$-.20 = .63$

COMPARING RESULTS WITH VALUES FOR DEAD LOAD
WE SEE THAT LOAD ON CORNERS
A, B & D IS GREATER THAN UPLIFT. CORNER C
HAS .75 UPLIFT AND .68 LOAD. THIS WILL AFFECT A VERY SMALL
AREA AT CORNER AND WILL DO NO PARTICULAR HARM.

10 REVISED


PRESSURE TAKEN = 3.16 WAS FOR DEAD PLUS LIVE
 Slab = $\frac{0.37}{2.79}$

①

Water $.0625 \times 23.75$ $\frac{1.48}{1.31}$ We should also take out
 Water in discharge Chamber
 Net uplift for 6'-0" span

The 5'-0" span should have uplift reduced by
 weight of gravel fill

$2.85 - 0.37$ 2.48
 Gravel 0.135×5 $\frac{.68}{1.80}$ Net uplift




②

On the other hand using Dead Load

Corrected Value Max $p = 2.27$
 Slab $\frac{0.37}{1.90}$

For 5'-0" span $2.05 - .37 = 1.68$ Net 6'-0" span
 Take out gravel $\frac{.68}{1.00}$



D+L

		.45	.55	
	+3.93	-3.93	+3.75	-3.75
		+1.13	+1.15	
M	+1.06	-3.80	+3.90	+1.07
	+3.99			-3.68
R	3.94	3.94	4.50	4.50
	+1.03	-1.03	+1.24	-1.24
	3.97	3.97	4.74	4.26
			8.65	

O shear $\frac{3.97}{1.31} = 3.03$ $\frac{4.26}{1.80} = 2.36$

Span M $8.77 \times \frac{3.03}{2} = 6.02$ $4.26 \times \frac{2.36}{2} = 5.03$
 End M $\frac{3.99}{2.03}$ $\frac{3.68}{1.35}$
 Span M



		.45	.55	
	+5.70	-5.70	+2.08	-2.08
		+1.63	+1.99	
	+1.82	-4.07	+4.07	+1.00
	+6.52			-1.08
	5.70	5.70	2.50	2.50
	+1.41	-1.41	+1.60	-1.60
	6.11	5.29	3.10	1.70
			8.39	

$\frac{6.11}{1.90} = 3.22$ $\frac{1.70}{1.00} = 1.70$
 $6.11 \times \frac{3.22}{2} = 9.83$ $\frac{1.70 \times 1.70}{2} = 1.81$
 $\frac{6.52}{3.31}$ $\frac{1.08}{.73}$



REVISED DESIGN FLOOR - DISCHARGE CHANNEL

Max Pos M. (Bottom steel) 6.52

$$\frac{M}{K} = \frac{6.52}{160} = 0.040 \quad \text{Min } d = 6\frac{1}{2} \text{ we have } 25\frac{1}{2}$$

$$A_s = \frac{6.52}{1.44 \times 25\frac{1}{2}} = 0.18 \quad \# 5 \text{ @ } 18 = 0.21$$

Max neg. M. 3.21 (Top steel)

$$A_s = \frac{3.21}{1.44 \times 26\frac{1}{2}} = 0.087 \quad \# 5 \text{ @ } 18 = 0.21$$

$$\text{Min Steel } 0.001 \times 12 \times 25\frac{1}{2} = 0.31 \quad \# 5 \text{ @ } 12 = 0.31$$

$$\text{Max. } v = \frac{6110}{12 \times 7\frac{1}{8} \times 25\frac{1}{2}} = 23 < 90$$

$$w = \frac{6110}{2 \times 7\frac{1}{8} \times 25\frac{1}{2}} = 137 < 300$$

5 @ 12 T & B will be o.k.

REVISION OF DESIGN FOR FLOOR OF SUMP AND
 N. INLET, WITH WATER AT 75.0
 LOADS

THIS SHEET
 REVISES
 SHEET 12

SUMP - DEAD 1.23 KSF. NET UP } AS BEFORE
 INLET - DEAD .99 " " " " }

SUMP P+L. 1.97 - .37 - 2x.0625 = 1.48 NET UP.
 INLET. 1.39 - .30 - 2x.0625 = .97

IT WOULD SEEM THAT A LOAD OF 1.50 IN THE SUMP
 COMBINED WITH A LOAD OF 1.00 IN INLET WOULD BE OK.

$\frac{1}{2} \times 1.50 \times 14.17^2 = 25.0$ $\frac{1}{2} \times 1.00 \times 6.88^2 = 3.94$


	49.51			
	+25.00	-25.00	+3.94	-3.94
	+5.16	+10.32	+10.74	+5.37
M.	+30.16	-14.68	+14.68	+1.43
R ₁	10.63	10.63	3.44	3.44
	+1.09	-1.09	+2.34	-2.34
	11.72	9.54	5.78	1.10

ZERO SHEAR. $\frac{11.72}{1.50} = 7.80$

SPAN M. $11.72 \times \frac{7.80}{2} = 45.8$
 END M. $\frac{30.2}{15.6}$

ZERO SHEAR. $\frac{1.10}{1.0} = 1.10$

SPAN M. $1.10 \times \frac{1.10}{2} = .60$
 END M. $\frac{1.43}{2.03}$



$u = \frac{11,720}{12 \times \frac{7}{8} \times 25 \frac{1}{2}} = 44 < 90$

$u = \frac{5,780}{12 \times \frac{7}{8} \times 19 \frac{1}{2}} = 28$

$u = \frac{11,720}{3.5 \times \frac{7}{8} \times 25 \frac{1}{2}} = 150 < 300$

$u = \frac{5,780}{2.8 \times \frac{7}{8} \times 19 \frac{1}{2}} = 121$

BOTTOM STEEL


LEFT, $\frac{30.16}{1.44 \times 25 \frac{1}{2}} = .82 \#9 @ 12$

CEN. SUPPT. $A_s = \frac{14.68}{1.44 \times 19 \frac{1}{2}} = .52 \#7 @ 12$

TOP STEEL $A_s = \frac{15.16}{1.44 \times 26 \frac{1}{2}} = .4 \#6 @ 12$


$A_s = \frac{2.03}{1.44 \times 20 \frac{1}{2}} = .07 \#4 @ 12$

(Sh. 13 deleted)



p. 11. pressure = 0.90
 $w = 3.34 \frac{1}{2} = 1.67$
 $.15 \cdot 2 = .30$
 $M = 1.37 \times \frac{6.75^2}{10} = 6.24$
 $A_s = \frac{6.24}{1.44 \cdot 19.5} = 0.22$
 #5 @ 12 = 0.3 Both ways

Side Walls as Cantilevers



Approx. Load.

REINF. IN CANTILEVER WALLS.

$A_s = \frac{32.2}{1.44 \cdot 150} = 0.149$

$1.37 \times 8 \times 8 = 87.5$
 Walls. $0.15 \cdot 13 \cdot 1.25 \cdot 8 \cdot 2 = 39$
 " $0.15 \cdot 13 \cdot 1.25 \cdot 5.5 \cdot 13.5$
 Cover $0.15 \cdot 0.5 \cdot 5.5 \cdot 6.75 = 2.8$
 $\frac{55.3}{32.2}$

CANT. M.M.

Run two #6 top + bot. along walls.

South 8 x 8 Intake.

Pressure = 3.10 - 0.30 = 2.80


$M = 2.8 \times \frac{6.75^2}{10} = 12.75$

$A_s = \frac{12.75}{1.44 \cdot 19.5} = 0.455$
 $= 0.23$ for 2-way steel

#4 @ 12 top

Use #5 @ 12 both ways.

B-22



B-23

BURSTING IN SOUTH INTAKE

AT CORNER. HOR. STEEL - $M_y = .025 \times 284 \times 5.50^3 = 116$

$A_s = \frac{116}{1.44 \times 11 \frac{1}{2}} = .071$

SEE BULLETIN ST 63
 PORTLAND CEM. ASSOC.

VERT. STEEL

$M_x = .005 \times 284 \times 5.50^2 = .235$

$A_s = \frac{.235}{1.44 \times 11 \frac{1}{2}} = .014$

AT MIDDLE HOR.

$M_y = .011 \times 284 \times 5.50^3 = .52$

$A_s = \frac{.52}{1.44 \times 11 \frac{1}{2}} = .031$

VERT.

$M_x = .009 \times 284 \times 5.50^3 = .45$

$A_s = \frac{.45}{1.44 \times 11 \frac{1}{2}} = .026$

FOR 1-3 WALL

TEMP. STEEL $.001 \times 12 \times 11 \frac{1}{2} = .138$ MIN.

USE #4 @ 12 HOR. = .20

#5 @ 12 VERT. = .31

THE TOP SLAB HAS AN UP LOAD OF 1.02

12" SLAB

NET $\frac{.15}{.85}$

2 WAY, $M = .05 \times 85 \times 6.75^2 = 1.94$


$A_s = \frac{1.94}{1.44 \times 8 \frac{1}{2}} = .158$ ← #12 = .20

TOP SLAB L+D. DOWN.

$L = 1200$

$D = \frac{.150}{.350}$

← #12 EA WAY.



HORIZ. SECT.
 SOUTH INTAKE

HORIZ. SECT.
 N. INTAKE

DESIGN OF WALLS

1. As ring at El. 770

Due to submerged earth pressure. No water inside the structure

Saturated earth pressure @ 135 #/sq ft, $135 - 62.5 = 72.5$

Horiz = 0.0625

$+ \frac{1}{3} \times 0.725 = 0.2242$

$0.0867 = 0.087 \text{ #/ft}^2$

On West Side. Pres. = $89.0 - 77.0 = 0.087 \times 12 = 1.05$



On Other Sides $83.5 - 77.0 = 0.087 \times 6.5 = 0.57$

$84.73 - 78.0 = 6.73$

SPANS

For dimensions See. Sh 23


AB	$M = 1.05 \times 6.75^2 / 12 = 4.0$	$I/2 = 1.5^3 / 6.75 = 0.5$
BC	$M = 1.05 \times 4.75^2 / 12 = 2.0$	$I/2 = 1.5^3 / 4.75 = 0.71$
CD	$M = 1.05 \times 14.92^2 / 12 = 19.4$	$I/2 = 1.5^3 / 14.92 = 0.226$
DE	$M = 1.05 \times 6.82^2 / 12 = 4.1$	$I/2 = 1.25^3 / 6.75 = 0.29$
EF	$M = 0.57 \times 19.5^2 / 12 = 18.1$	$I/2 = 1.25^3 / 19.5 = 0.1$
FG	$M = 0.57 \times 8.0^2 / 12 = 3.0$	$I/2 = 1.25^3 / 8.0 = 0.244$
GH	$M = 0.57 \times 6.75^2 / 12 = 2.16$	$I/2 = 1.25^3 / 6.75 = 0.29$
HJ	$M = 0.57 \times 8.0^2 / 12 = 3.0$	$I/2 = 1.25^3 / 8.0 = 0.244$
IJ	$M = 0.57 \times 14.92^2 / 12 = 10.6$	$I/2 = 1.5^3 / 14.92 = 0.226$
JK	$M = 0.57 \times 4.75^2 / 12 = 1.07$	$I/2 = 1.5^3 / 4.75 = 0.71$
KL	$M = 0.57 \times 8.0^2 / 12 = 3.0$	$I/2 = 1.25^3 / 8.0 = 0.244$
LM	$M = 0.57 \times 6.75^2 / 12 = 2.16$	$I/2 = 1.25^3 / 6.75 = 0.29$
MN	$M = 0.57 \times 8.0^2 / 12 = 3.0$	$I/2 = 1.25^3 / 8.0 = 0.244$
NA	$M = 0.57 \times 19.5^2 / 12 = 18.1$	$I/2 = 1.5^3 / 19.5 = 0.174$
CJ	$M = 0.0$	$I/2 = 1.5^3 / 19.5 = 0.174$
BK	$M = 0.0$	$I/2 = 1.0^3 / 19.5 = 0.051$
DI	$M = 0.0$	$I/2 = 1.5^3 / 19.5 = 0.174$
IF	$M = 0.0$	$I/2 = 1.25^3 / 6.75 = 0.29$
NK	$M = 0.0$	$I/2 = 1.5^3 / 6.75 = 0.5$



OAK STREET PUMPING STATION
 MOMENT DISTRIBUTION AT ELEVATION 77.0 NO WATER
 NO SCALE

Design of Walls.

1. As Ring at El. 77.0 Inward Pressure.
 Distribution and Carry-Over Factors.





DESIGN OF WALLS

1. As Ring @ El. 77.0 Outward Pressure

In discharge bay $p = (99.75 - 77) 0.0625 = 1.42 \text{ #/ft}$

In sump bay $p = (80 - 77) 0.0625 = 0.19$

Pressures from saturated earth as before





NET PRESSURES

Design of Walls.

1. As Ring at El. 77.0 With Outward Pressure.
Fixed End Moments.


Spans.

AB	$M = 0.37 \cdot 6.75^2/12 =$	1.4 ✓	OUT.
BC	$M = 1.05 \cdot 4.75^2/12 =$	2.0 ✓	IN.
CD	$M = 0.86 \cdot 14.92^2/12 =$	15.9 ✓	IN.
DE	$M = 0.86 \cdot 6.75^2/12 =$	3.3 ✓	IN.
EF	$M = 0.38 \cdot 19.5^2/12 =$	12.0 ✓	IN.
FG	$M = 0.38 \cdot 8.0^2/12 =$	2.0 ✓	IN.
GH	$M = 0.38 \cdot 6.75^2/12 =$	1.4 ✓	IN.
HI	$M = 0.38 \cdot 8.0^2/12 =$	2.0 ✓	IN.
IJ	$M = 0.38 \cdot 14.92^2/12 =$	9.0 ✓	IN.
JK	$M = 0.57 \cdot 4.75^2/12 =$	1.1 ✓	IN.
KL	$M = 0.57 \cdot 8^2/12 =$	3.0 ✓	IN.
LM	$M = 0.57 \cdot 6.75^2/12 =$	2.2 ✓	IN.
MN	$M = 0.57 \cdot 8^2/12 =$	3.0 ✓	IN.
NA	$M = 0.85 \cdot 19.5^2/12 =$	27. ✓	OUT
CJ	$M = 0$ NOT CONSIDERED		
BK	$M = 1.42 \cdot 19.5^2/12 =$	45. ✓	OUT.
DI	$M = 0$		
IF	$M = 0$		
NK	$M = 1.42 \cdot 6.75^2/12 =$	5.4 ✓	OUT.









OAK STREET PUMPING STATION
 MOMENT DISTRIBUTION AT ELEVATION 77.0 WITH WATER
 NO SCALE





DESIGN OF WALLS E1.77.0




DESIGN OF WALLS EL. 77.0'




DESIGN OF WALLS EL. 77.0







K B
 B-K, no water
 inside - no stress



BK - with water →



DESIGN OF WALLS




8'x8' Intakes.
 Run #5 @ 12" ea. face
 except @ joint F,
 where steel from EF
 will extend into F.G.

SUBJECT OAK ST. PUMPING STA.


REVISED DISTRIBUTION AT EL. 77.0 B&K.

STRESS ANALYSIS OF KB FOR WATER INSIDE SHOWS A 20" WALL NEEDED TO CARRY MOMENT AS FOUND USING A 12" WALL. SUCH A CHANGE IN THICKNESS WILL CAUSE QUITE A CHANGE IN MOMENT DISTRIBUTION IN KB AND ALL ADJACENT WALLS. WE SHALL RE FIGURE THE MOMENT DISTRIBUTION ASSUMING FIXED ENDS ON ALL ADJACENT BEAMS AT FAR END.

<u>+4.36</u>	<u>-3.28</u>	<u>+3.05</u>	<u>-1.48</u>
+ .02 C	D + .04	+ .07 D	+ .03 C
+ .34 C	D + .68	+ .98 D	+ .49 C
+ 4.00 F	F - 4.00	+ 2.00 F	- 2.00 F




EXTERNAL PRESSURES




WATER + EXTERNAL PRESSURE

REVISED MOMENTS.



FOR THE REMAINDER OF THE BEAMS,
 WE SHALL USE THE END MOMENT ADJACENT TO KB AS JUST
 FOUND BUT SHALL USE THE PREVIOUS MOMENT FOR THE FAR END.




EXTERNAL LOADS

$$\frac{1}{2} \times 1.05 \times 6.75 = 3.54$$

$$\text{MAX. POS. } .73 \times \frac{6.75}{2} = .25$$

$$\frac{3.28}{3.53}$$



COMBINED LOADS







$$\frac{1}{2} \times 1.37 \times 6.75 = 4.62$$

$$1.74 \times 2.05 = .76$$

$$\frac{16.68}{15.92}$$

$$\text{MIN. MOM. } \frac{16.68}{15.92}$$



REVISED MOMENTS




PROJECT MASS, CHICOPEE FALLS.

SUBJECT OAK ST. PUMPING STA.

PROJECT NO. 6205-2
 SHEET NO. 22G OF _____
 DATE MAR. 8, 1963
 COMPUTED BY M.A.
 CHECKED BY FNW






PLAN @ EL 77.0 ±

DESIGN OF WALLS E1.77.0


AB	$\frac{15.7}{1.44 \times 14.5} = 0.76$ (out)	#8 @ 12
	$\frac{19.98}{1.44 \times 14.5} = 0.96$ (in)	#9 @ 12
BC	$29.1 / (1.44 \times 14.5) = 1.4$ (out)	#8 @ 6
CD	$18.62 / (1.44 \times 14.5) = 0.9$ (out)	#8 @ 12
DE	$7.96 / (1.44 \times 11.5) = 0.48$ (out)	#7 @ 12
	$14.27 / (1.44 \times 11.5) = 0.86$ (out)	#9 @ 12
EF	$11.3 / (1.44 \times 11.5) = 0.68$ (in)	#8 @ 12
	$17.3 / (1.44 \times 11.5) = 1.04$ (out)	#9 @ 12
IJ	$9.63 / (1.44 \times 14.5) = 0.46$ (out)	#6 @ 12
	$7.17 / (1.44 \times 14.5) = 0.35$ (in)	#6 @ 12
JK	$23.3 / (1.44 \times 14.5) = 1.12$ (out)	#10 @ 12
MK	$18.93 / (1.44 \times 14.5) = 0.91$	#9 @ 12
NA	$24.3 / (1.44 \times 14.5) = 1.17$ (in)	#10 @ 12
	$16.8 / (1.44 \times 14.5) = 0.81$ (out)	#8 @ 12
	$11.3 / (1.44 \times 14.5) = 0.55$ (in)	#7 @ 12
	$18.3 / (1.44 \times 14.5) = 0.88$ (out)	#9 @ 12
BK	$d = \sqrt{\frac{44400 \times 12}{160 \times 12}} = 16.5 + 3.5 = 20$	
	$44.4 / (1.44 \times 16.5) = 1.88$	#9 @ 6
	$25.7 / (1.44 \times 16.5) = 1.06$	#9 @ 12
CJ	$7.2 / (1.44 \times 14.5) = 0.346$	#6 @ 12
Intakes	$6.8 / (1.44 \times 11.5) = 0.41 = \text{max}$	
	If $M \leq 5.0'K$ use	#5 @ 12

Design of walls Fl. 84.0 As Ring .
 In discharge bay $p = (99.75 - 84.0) 0.0625 = 0.98$
 West Wall Earth pres. = $(89.0 - 84.0) 0.087 = 0.44$
 Submerged Earth $(135 - 62.5)^{1/3} = 0.0625 + 0.0242 = 0.087$
 Earth on other sides exerts no pressure





Design of Walls. Ring at El. 84.0

AB	$M = 0.54 \cdot 11.5^2 / 12 = 5.9$	$I/l = \frac{1.5^3}{11.5} = 0.294$
BC	$M = 0.44 \cdot 14.92^2 / 12 = 8.2$	$I/l = \frac{1.5^3}{14.92} = 0.226$
CD	$M = 0.44 \cdot 6.75^2 / 12 = 1.7$	
IJ	$M = 0.98 \cdot 4.75^2 / 12 = 1.9$	$I/l = \frac{1.5^3}{4.75} = 0.715$
JM	$M = 0.98 \cdot 6.75^2 / 12 = 3.7$	$I/l = \frac{1.5^3}{6.75} = 0.5$
MH	$M = 0.98 \cdot 19.5^2 / 12 = 31$	$I/l = \frac{1.5^3}{19.5} = 0.174$
BI	$M = 0.98 \cdot 19.5^2 / 12 = 31$	$I/l = \frac{1.5^3}{19.5} = 0.174$




Other values as at El. 77.0






LOADING DIAGRAM

OAK STREET PUMPING STATION
 MOMENT DISTRIBUTION AT ELEVATION 84.0 WITH WATER
 NO SCALE

DESIGN OF WALLS. RING @ EL. 84.0




DESIGN OF WALLS D.F.I. 84.00



DESIGN OF WALLS, RING @ F1 84.0

AB	21.55 / (1.44 x 14.5)	= 1.04	#9 @ 12
BC	18.21 / (1.44 x 14.5)	= 0.88	#9 @ 12
CD	Nominal		
BI	28.85 / (1.44 x 14.5)	= 1.38	#8 @ 6
	19.75 / (1.44 x 15.5)	= 0.88	#9 @ 12
	26.37 / (1.44 x 14.5)	= 1.26	#10 @ 12
MA	30.28 / (1.44 x 14.5)	= 1.45	#8 @ 6
IJ	6.67 / (1.44 x 15.5)	= 0.30	#5 @ 12
	22.43 / (1.44 x 15.5)	= 1.00	#9 @ 12
NJ	22.6 / (1.44 x 14.5)	= 1.08	#10 @ 12
LM	7.83 / (1.44 x 12.5)	= 0.43	#6 @ 12

COVER ALL WALLS 3" + 1/2 @ THIS ELEV.



THE QUESTION OF AXIAL TENSION IN RING @ EL. 84
THE RESULTS OF CONSIDERATION OF AXIAL TEN. IN RING AT EL. 87
MAKE IT SEEM THAT TEN. IN LONG SIDES IS UNIMPORTANT,
TENSION IN SHORT SIDES DOES HAVE A SIGNIFICANT EFFECT.
WE THEREFORE CONSIDER TENSION IN AB, M-J AND. J-I
TEN IS SHEAR IN M-A = 9.15 @ A 10.05 AT M,

$$A-B. \quad M @ A = 21.55 \quad N = -9.15 \quad d'' = 9 - 3\frac{1}{2} - 5\frac{1}{2}$$

$$e = \frac{12M}{N} + 5\frac{1}{2} = \frac{12 \times 21.55}{-9.15} + 5\frac{1}{2} = -28.2 + 5.5 = -22.7 \quad E = 1.89$$

$$i = \frac{1}{1 - \frac{.875 \times 14.5}{-22.7}} = \frac{1}{1 + .56} = .64 \quad NE = 17.3$$

$$A_s = \frac{17.3}{1.44 \times 14.5 \times .64} = 1.30 \quad \# 10 @ 12$$

$$A-B. \quad M @ B, \quad 8.17 \quad N = -9.15$$

$$e = \frac{12 \times 8.17}{-9.15} + 5.5 = -10.70 + 5.5 = -5.20 \quad E = .433$$

$$i = \frac{1}{1 - \frac{.875 \times 14.5}{5.20}} = \frac{1}{1 + 2.44} = .29 \quad NE = 3.96$$

$$A_s = \frac{3.96}{1.44 \times 14.5 \times .29} = .65 \quad \# 8 @ 12$$

$$A-B. \quad M \text{ IN MIDDLE} = 4.65$$

$$e = \frac{12 \times 4.65}{-9.15} + 5.5 = -6.10 + 5.5 = -.60 \quad E = .05$$

$$i = \frac{1}{1 - \frac{.875 \times 14.5}{.60}} = \frac{1}{1 + 21.2} = .045 \quad NE = .46$$

$$A_s = \frac{.46}{1.44 \times 14.5 \times .045} = .49 \quad \# 7 @ 12$$

SAME SIDE AS ENDS.

$$M. \quad M-J \quad \text{Mom. @ M} = 22.6 \quad N = 10.05$$

$$e = \frac{12 \times 22.6}{-10.05} + 5.5 = -27.0 + 5.5 = -21.5 \quad E = -1.79$$

$$i = \frac{1}{1 - \frac{.875 \times 14.5}{-21.5}} = \frac{1}{1 + .59} = .63 \quad NE = 18.00$$

$$A_s = \frac{18.00}{1.44 \times 14.5 \times .63} = 1.37 \quad \# 8 @ 6$$

$$\text{Mom @ J} = 6.08$$

$$e = \frac{12 \times 6.08}{-10.05} + 5.5 = -7.25 + 5.5 = -1.75 \quad E = .146 \quad NE = 1.47$$

$$i = \frac{1}{1 - \frac{.875 \times 14.5}{-1.75}} = \frac{1}{1 + 7.25} = .121$$

$$A_s = \frac{1.47}{1.44 \times 14.5 \times .121} = .58 \quad \# 7 @ 12$$

PROJECT MASS, CHICOPEE FALLS

PROJECT NO. 6205-2

SHEET NO. 30B OF

DATE MAR. 12, 1963

SUBJECT OAK ST. PUMPING STA.

COMPUTED BY M.A.


RING @ 84

CHECKED BY FNW

BM. J, I. AT J SIMILAR TO END J OF BM. M-J

@ I. M = 22.43 H = 10.05

$$e = \frac{12 \times 22.43}{-10.05} + 5.56 \quad \text{VERY SIMILAR TO END M OF BEAM, M-J - SAME STEEL.}$$




Design of Walls. Ring at El. 87.0

In discharge bay, $p = (99.75 - 87.0) \cdot 0.0625 = 0.8$


AB } $M = 0.8 \cdot 11.5 / 2 = 8.8$
CD } $\frac{I}{L} = \frac{1.42}{11.5} = 0.25$

AD } $M = 0.8 \cdot 19.5 / 2 = 25.4$
 $\frac{I}{L} = \frac{1.42}{19.5} = 0.147$

BC } $M = 0.8 \cdot 19.5 / 2 = 25.4$
 $\frac{I}{L} = \frac{1.25}{19.5} = 0.1$




Neglect pump room bay - no load. With 12" walls effect from discharge bay will be small.





	+8.8	
0.25	25.4	0.067
	-25.4	= 1/14.92
	0.1	
0.25	0.67	0.25/4.17 = 0.66
	1.0	0.1/4.17 = .24
	0.417	0.067/0.417 = .16
25.4	8.8	
	16.6	16.6 * 0.16 = 2.65"
		= #5 @ 12.


DESIGN OF WALLS, RING 2 FT. 8 1/2



Cover $2" + d/2$
 $= 14.5 \text{ \& } 12.5$



RING AT ELEV. ^{87.0} CONSIDERING RING AT EL. 87
WITH AXIAL TENSION.



RIGHT END
 $e = \frac{12M}{N} + d'' = \frac{12 \times 20.9}{-7.80} + 6'' = -26.1$ $E = -2.17$

$K = 160$
 $F = 121$
 $NE = (-7.80) \times (-2.17) = 16.9$
 $KE = 160 \times 2.1 = 33.6$ O.K.

$\bar{z} = \frac{1}{1 - \frac{.875 \times 14.5}{-26.1}} = \frac{1}{1 + .49} = .67$

$A_s = \frac{16.9}{1.44 \times 14.5 \times .67} = 1.20$ #10 @ 12

LEFT END
 $e = \frac{12 \times 19.0}{-7.80} + 6'' = -29.3 + 6'' = -23.3$ $E = -1.94$

$NE = 1.94 \times 7.80 = 15.1$

$\bar{z} = \frac{1}{1 - \frac{.875 \times 14.5}{-23.3}} = \frac{1}{1 + .55} = .65$

$A_s = \frac{15.1}{1.44 \times 14.5 \times .65} = 1.11$ #10 @ 12

MIDDLE -
 $e = \frac{12 \times 6.8}{-7.80} - 6'' = -10.4 + 6'' = -4.4$ $E = -.367$

$NE = 2.86$

$\bar{z} = \frac{1}{1 - \frac{.875 \times 14.5}{-4.4}} = \frac{1}{1 + 2.88} = .258$

$A_s = \frac{2.86}{1.44 \times 14.5 \times .258} = .53$ #7 @ 12

DA - ENDS $M = 19.0$ $N = 4.43$
 $e = \frac{12 \times 19.0}{-4.43} + 6'' = -51.5 + 6'' = -45.5$ $E = -3.79$ $NE = 16.75$

$\bar{z} = \frac{1}{1 - \frac{.875 \times 14.5}{-45.5}} = \frac{1}{1 + .28} = .78$

$A_s = \frac{16.75}{1.44 \times 14.5 \times .78} = 1.03$ #9 @ 12 O.K.

DA - MIDDLE SAME -

RING @ EL. 87 CONSIDERING AXIAL TEN.

C - B

ENDS $M = 20.9$ $K = 4.43$ $d'' = 7\frac{1}{2} - 2\frac{1}{2} = 5''$

$$e = \frac{12 \times 20.9}{-4.43} + 5'' = -56.7 + 5'' = -51.7$$

$E = -4.31$

$NE = 19.1$

$$z = \frac{1}{1 - \frac{.875 \times 12.5}{-51.7}} = \frac{1}{1 + .21} = .825$$

$$A_s = \frac{19.1}{1.44 \times 12.5 \times .825} = 1.27 \quad \# 10 @ 12 \quad \text{OK}$$


MIDDLE $M = 17.1$ $N = 4.43$

$$e = \frac{12 \times 17.1}{-4.43} + 5'' = -46.5 + 5'' = -41.5$$

$E = 3.45$ $NE = 15.3$

$$z = \frac{1}{1 - \frac{.875 \times 12.5}{-41.5}} = \frac{1}{1 + .26} = .80$$

$$A_s = \frac{15.3}{1.44 \times 12.5 \times .80} = 1.06 \quad \# 9 @ 12 \quad \text{OK}$$



PROJECT Chicopee Falls

SUBJECT Pumping Sta. Oak St.


PROJECT NO. 6205

SHEET NO. 35A OF

DATE 4/2/63

COMPUTED BY POP

CHECKED BY PPP



PLAN @ EL. 87.0'±

B-55

ROOF OVER DISCHARGE BAY


Note: A row of openings prevents the use of two way steel. Run a beam between the stop-log piers. The resulting slab has length ratios of 3:1. One-way steel is mandatory, except for spacers & temp. & shrinkage.

LOADS


Tar & Gravel	6.5
6" slab	75.0
40" snow + 20" gate	60.0
stop logs	20.0
	<u>162.0</u>

Cover: $\frac{3}{4} + \frac{d}{2} = 1.0"$
 $d = 6" - 1" = 5"$

SLAB




At ϕ $M = 0.162 \times 7^2/8 = 1.0'k$
 $A_s = \frac{40}{1.44 \times 5} = 0.14$
Use #5 @ 12 = 0.30" @ supports, neg. steel, #5 @ 12 min.



By using Gate Load as follows:
(Gate Vertical) $\frac{3000}{3.0 \times 5.5} = 180 \#/ft.$
T & G = 6
slab = 75
gate = 180
live = 50
311 #/ft.
 $\frac{311(7.0 + 4.5)}{2} = 1790$
wt. $\frac{8 \times 6}{144} \times 150 = 50$
Span = 3'-2" Clear = 3'-7"

$M = \frac{1}{10} \times 1,840 \times 3.17^2 = 18.5'k$
 $F = \frac{18.5}{160} = .115$ $b = 12"$ $d = 11"$ $t = 14"$
 $A_s = \frac{18.5}{1.44 \times 11} = 1.170"$ 4 - #5 T & B $A_s = 1.240"$

ROOF OVER PUMP FLOOR



Note: Every $\frac{1}{4}$ th bar, pos. steel extends into supports.
Neg. steel runs to $\frac{1}{4}$ th points

ACI Bldg. Code p. 945

Short Span { Neg = cws^2
 Pos.

Long Span { Neg.
 Pos.

$$M = \frac{15.08}{19.92} = 0.75$$

$$0.0515 \times 181 \times 15.08^2 = 2115' \text{ #}$$

$$0.0385 \times 181 \times 15.08^2 = 1580' \text{ #}$$


$$0.033 \times 181 \times 15.08^2 = 1355' \text{ #}$$

$$0.025 \times 181 \times 15.08^2 = 1025' \text{ #}$$

$$d = \sqrt{\frac{2115 \times 12}{160 \times 12}} = 3.63" \quad \text{Have } d = 5"$$

$$A_g = \frac{2.115}{1.44 \times 5} = .294' \text{ #}$$

Use #5 @ 12 for pos. & neg.



Plan Operating Floor
EL. 86.06'

B-58

PUMP ROOM FLOOR

BEAMS

Bms. 5.0' o.c.

Take unit load as $100 + 100 = 200 \text{ #/ft}$,
 Plus Conc. loads of 6K & 3K.

Beam "A" is most heavily loaded

Unit load = $200(5/2 + 7.5/2) = 200 \times 6.25 = 125 \text{ #/ft}$

Compute as simple beam, then allow for
 fixed ends.


Loads: D.L. 100 #/ft
 L.L. 100 #/ft

+ 3 Pump & thrust @ 6

3 Prime movers @ 3

+ on slab only

3K over $4' \times 3' = 0.25$



$$\begin{aligned}
 M &= 14.22 \times 6.76 = 96.0 \\
 -1.25 \times 6.76^2 / 2 &= 28.6 \quad \frac{56.7}{39.3} = \text{Max Pos. Mom.} \\
 -6.0 \times 3.76 &= 22.6 \\
 \text{ML} & \quad \frac{5.5}{56.7}
 \end{aligned}$$

PUMP ROOM FLOOR

BEAMS To determine amount of fixed-end moments

$$M_2 = \frac{Pab^2}{L^2} = \frac{3 \times 6 \times 10.42^2}{13.42^2} = 10.8$$

$$3 \times 8 \times \frac{5.42^2}{13.42^2} = \frac{3.9}{14.7}$$

$$+ 125 + \frac{13.42^2}{12} = \frac{18.0}{33.5}$$

$$M_R = P \frac{b a^2}{12}$$

$$\text{Unif} = 18.8$$

$$3 \times 5.42 \times \frac{8^2}{13.42^2} = 5.8$$

$$6 \times 10.42 \times \frac{3^2}{13.42^2} = \frac{3.2}{27.8}$$

PUMP ROOM FLOOR

BEAMS. width = 2'-6" @ openings

$$d = \sqrt{\frac{39300 \times 12}{160 \times 12}} = 9.9" + 2.0 = 11.9 = 12.0"$$

$d = 10"$


Cover, interior floor beam, $1\frac{1}{2} + \frac{1}{2} = 2"$

Cover, slabs $\frac{3}{4} + \frac{1}{4} = 1.0"$

Pos M₁, $A_s = \frac{39.3}{1.44 \times 10} = 2.74"$ 9-#5 = 2.79

$v = 14,200 / (30 \times 0.86 \times 10) = 55 \text{ #/ft}^2$

$u = 200 = 14,200 / (\epsilon_0 \times 0.86 \times 10)$ $\therefore \epsilon_0 = 8.2"$
to provide



At ends, $A_s = \frac{33.5}{1.44 \times 10} = 2.34$ 6-#6 = 2.64

Effect on Wall of Floor Beam


$P(\text{wall}) = \frac{2.64}{60 \times 14.5} = 0.00304$ $k = 0.22$
 $j = 0.93$

$33,500 \times 12 = \frac{1}{2} f_c (0.22 \times 0.93) \times 60 \times 14.5^2$
 $f_c = 310\%$

From bending as ring, $p = \frac{4.0}{18 \times 12} = 0.0046$ $k = 0.25$
 $j = 0.92$

$20,000 \times 12 = \frac{1}{2} f_c (0.25 \times 0.92) \times 12 \times 14.5^2$
 $f_c = 830\%$ $v = 260$, but there is two way steel

P.S. — the two f_c 's act on diff. sides



PUMP ROOM FLOOR

DL. Allow	150 #/ft'
L.L. $\frac{3000}{4 \times 3}$	<u>250</u>
	400
Regular L.L.	<u>100</u>
	500 #/ft'

SLAB

Load Beam "C"
D.L. = 150
Reg. L.L. = 250
Pump, L.D. = 500
12 lin. ft. 900

$$M = 0.9 \times \frac{6.25^2}{12} = 2.94 + 2 \times 0.9 \times \frac{6.25}{4} = 2.82$$

$M = 5.76$, $d = 6.0$, this section of floor to be 12"

$$A_s = \frac{5.76}{1.44 \times 10} = 0.4'' \quad \text{Two \#5. pos \& neg. in this beam} = 0.6''$$

Slab "E" between bm. "A" and East wall

$$D.L. = 100$$


$$\text{Equip L.L.} = 250 = 3000/(4 \times 3)$$

$$\text{Reg. L.L.} = \frac{100}{450 \text{ #/ft}' \times \frac{6.25^2}{12}} = M = 1.46''$$

$$d = \sqrt{\frac{1.46 \times 12}{160 \times 12}} = 3'' \quad \text{Use 6" slab } d = 5''$$

$$A_s = \frac{0.46}{1.44 \times 5} = 0.2'' \quad \text{Use \#5 @ 12 min.}$$

Cantilevers "J"



$$P = \frac{6000}{12} = 500 \text{ #/ft'}$$

$$\text{Wt.} = 0.15 \times 1.25^2 / 2 = 0.12$$

$$0.5 \times 1.25 = 0.63$$

$$0.75$$

$$A_s = \frac{0.75}{1.44 \times 10} = 0.052 = \text{Negligible}$$

Use #5 @ 12

PUMP ROOM FLOOR

Cantilever "K"


$$M = \frac{0.15 \times 1.75^2}{2} = 0.23$$

$$\frac{0.15 \times 1.75}{1.11} = 0.23$$

$$A_s = \frac{1.11}{1.44 \times 10} = 0.08$$

Use #5 @ 12

Beam D. LOCAL B.M.




Using $w = 0.9 = \text{heavy}$
 $M = \frac{0.9 \times 4.25^2}{12} = 1.36$
6" slab o.k.

$$A_s = \frac{1.36}{1.44 \times 5} = 0.19$$

Use #5 @ 12

No special beam needed




PROJECT NO. 6205-2
SHEET NO. 1 OF 33
DATE 2-14-63
COMPUTED BY JD
CHECKED BY REP

PROJECT CHICOPEE FALLS

SUBJECT Local Protection Project
Pump Selection - MAIN ST

MAIN ST.

Q = HWL 9000 GPM
LWL 9900 GPM



dynamic losses - 18" column -	velocity head -	Low	High
		2.4	2
	Flap - 1/2 hv	0.024	0.02
		<u>2.43</u>	<u>2.02</u>

Total Head	Low stage	High stage
Static	7.7	19.4
dynamic (18")	<u>2.4</u>	<u>2.0</u>
	10.1'	21.4'

Use 18" column.

Flap losses from hydraulic design chart 340-1.

K = 0.01, from curve

$$H_L = K \frac{V^2}{2g} = .01 \times 2.4 = 0.024' \text{ for low head.}$$

$$= .01 \times 2.0 = 0.02' \text{ for high head.}$$

Static head at top of local protection - 29.0'±

PROJECT Chicopee Falls

SUBJECT Local Protection Project

Pump selection - Main St.

PROJECT NO. 6205-2
SHEET NO. 2 OF 33
DATE 2-25-63
COMPUTED BY ROP
CHECKED BY tpf

Condition #1 head = 10.1 ft $Q_1 = 9900 \text{ GPM} = 22.1 \text{ cfs}$

Condition #2 head = 21.4 ft $Q_2 = 9000 \text{ GPM} = 20.1 \text{ cfs}$

#1 Discharge Dia = $\sqrt{\frac{4 \times 22.1 \times 144}{12 \times \pi}} = 18.4''$
use chart #1B

#3 $D_p = D_m \left(\frac{Q_p}{Q_m} \right)^{\frac{1}{2}} = 16 \left(\frac{9900}{10,140} \right)^{\frac{1}{2}} = 15.95''$ use 16" Mixed

#4 $Q_m = \frac{Q_p}{\left(\frac{D_p}{D_m} \right)^2} = \frac{9900}{\left(\frac{16.00}{16.00} \right)^2} = 9900 \text{ GPM}$

#5 $H = 8 \text{ ft} \quad Q_x = Q_c \left(\frac{H_x}{H_c} \right)^{\frac{1}{2}} = 9900 \left(\frac{8}{10.1} \right)^{\frac{1}{2}} = 8800 \text{ GPM}$

$H = 12 \text{ ft} \quad Q_x = 9900 \left(\frac{12}{10.1} \right)^{\frac{1}{2}} = 10800 \text{ GPM}$

$N_c = N_x \left(\frac{Q_c}{Q_x} \right) = 1298 \left(\frac{9900}{10,125} \right) = 1269$

$Q_c = Q_x \left(\frac{N_c}{N_x} \right) = Q_x \times \left(\frac{1269}{1298} \right) = Q_x \times .980$

$H_c = H_x \left(\frac{N_c}{N_x} \right)^2 = H_x \times \left(\frac{1269}{1298} \right)^2 = H_x \times .960$

$P_c = P_x \left(\frac{N_c}{N_x} \right)^3 = P_x \times \left(\frac{1269}{1298} \right)^3 = P_x \times .941$

H_x	Q_x	P_x	$\frac{H_p}{H_c}$	$\frac{Q_p}{Q_c}$	$\frac{P_p}{P_c}$	EFF. = $\frac{QH}{3960P}$
10.0	10150	62	9.6	9950	58	41.5
12.5	10050	64	12.0	9850	60	
15.0	9900	67	14.4	9700	63	56.0
17.5	9700	69	16.8	9500	65	
20.0	9500	72	19.2	9300	68	66.0
22.5	9250	74	21.6	9050	70	70.5
25.0	8975	75	24.0	8800	71	75.0
35.0	7250	77	33.6	7100	72	Max. Eff. 83.5


#9 For $H = 33.7 \quad N_s = 7725 \quad \therefore$ Suction Lift = 1.4 Ft. (Plate #16)

PROJECT CHICOPEE FALLS

SUBJECT LOCAL PROTECTION PROJECT

PUMP SELECTION - MAIN ST.

PROJECT NO. 6265-2
 SHEET NO. 3 OF 33
 DATE 2-25-63
 COMPUTED BY RAT
 CHECKED BY _____



CAPACITY TGPM C-3

REF PLATE # 21B
 16" MIXED

PROJECT Chicopee Falls

SUBJECT Local Protection Project
Pump Selection - Main St.

Try 18" Pump Mixed Flow H = 10.1 Q = 9900

#4 (Thru pt. #1)

$$Q_m = \frac{Q_p}{\left(\frac{D_p}{D_m}\right)^2} = \frac{9900}{\left(\frac{18}{16}\right)^2} = 7830$$

$$H = 10.1 \text{ ft} \quad Q_x = Q_c \left(\frac{H_x}{H_c}\right)^{1/2} = 7830 \left(\frac{10}{10.1}\right)^{1/2} = 7800$$

$$H = 15.0 \text{ ft} \quad Q_x = 7830 \left(\frac{15.0}{10.1}\right)^{1/2} = 9580$$

$$H = 20.0 \text{ ft} \quad Q_x = 7830 \left(\frac{20}{10.1}\right)^{1/2} = 11050$$

$$H = 22.5 \text{ ft} \quad Q_x = 7830 \left(\frac{22.5}{10.1}\right)^{1/2} = 11750$$

$$N_c = N_x \left(\frac{Q_c}{Q_x}\right) = 1298 \left(\frac{7830}{9850}\right) = 1035$$

$$Q_c = Q_x \left(\frac{N_c}{N_x}\right) = Q_x \left(\frac{1035}{1298}\right) = .796 Q_x$$

$$H_c = H_x \left(\frac{N_c}{N_x}\right)^2 = H_x \left(\frac{1035}{1298}\right)^2 = .632 H_x$$

$$P_c = P_x \left(\frac{N_c}{N_x}\right)^3 = P_x \left(\frac{1035}{1298}\right)^3 = .505 P_x$$

(See "x" values previous p.)

H _c	Q _c	P _c	H _p	Q _p	P _p	
6.3	8100	31.4	6.3	10,250	40	40.8
7.9	8000	32.3	7.9			
9.5	7880	33.8	9.5	10,000	43	55.8
11.0	7710	34.8	11.0			
12.6	7560	36.4	12.6	9,600	46.3	66.0
14.2	7350	37.4	14.2			
15.8	7120	37.8	15.8	9,080	48.0	75.5
22.1	5780	38.9	22.1	7,330	49.5	82.8
23.7	5200	38.5	23.7	6,600	49.0	80.5

#5

$$H_p = H_m$$

$$Q_p = Q_m \left(\frac{18}{16}\right)^2 = 1.268 Q_m$$

$$P_p = P_m \left(\frac{18}{16}\right)^2 = 1.268 P_m$$

$$N_p = \left(\frac{D_m}{D_p}\right) N_m = \frac{16}{18} \times 1035 = 920$$

PROJECT Chicopee Falls

SUBJECT Local Protection Project

Pump Selection - Main St.

PROJECT NO. 6205-3
SHEET NO. 4 OF
DATE 2-26-63
COMPUTED BY RD-
CHECKED BY HP1

#6 H-Q Curve 3HP Curve thru Condition Point #2

$$Q_m = Q_p \left(\frac{D_m}{D_p} \right)^2 = 9000 \left(\frac{16}{18} \right)^2 = 7120$$

18" Mixed Flow

H = 21.4 Q = 9000

$$Q_x = 7120 \left(\frac{H_x}{H_c} \right)^{\frac{1}{2}}$$

$$H_x = 27.5 \quad Q_x = 7120 \left(\frac{27.5}{21.4} \right)^{\frac{1}{2}} = 8100$$

$$H_x = 32.5 \quad Q_x = 7120 \left(\frac{32.5}{21.4} \right)^{\frac{1}{2}} = 8820$$

$$N_c = 1298 \left(\frac{7120}{8370} \right) = 1103 \text{ RPM}$$

$$Q_c = Q_x \left(\frac{1103}{1298} \right) = .85 Q_x$$

$$H_c = H_x \left(\frac{1103}{1298} \right)^2 = .723 H_x$$

$$P_c = P_x \left(\frac{1103}{1298} \right)^3 = .614 P_x$$

H	Q _c	P _c	H _D	Q _P	P _P	EFF.
7.2	9650	38.0	7.2	11,000	48.3	41.4
9.1	8570	39.4	9.1	10,950	50.0	50.
10.8	8400	41.1				
12.7	8250	41.5	12.7	10,450	52.8	64.
14.4	8100	44.2				
16.2	7970	45.5	16.2	10,000	57.8	71
18.0	7610	46.0	18.0	9,700	58.5	75
25.3	6180	47.3	25.3	7,850	60.0	83.5
27.1	5580	47.0	27.1	7,100	59.7	81.5

$$H_p = H_m$$

$$N_s = 7725 \quad H = 25.3 \quad 10' \text{ lift}$$

$$Q_p = 1.268 Q_m$$


$$P_p = 1.268 P_m$$

$$N_p = \frac{16}{18} \times 1103 = 982$$

This has unknown capacity at top of protection works - apparently not high except at the top sump level.

with river

C-5



C-6

CAPACITY TGPM

REF PLATE #21B
 18" MIXED

PROJECT CHICOPEE FALLS

SUBJECT LOCAL PROTECTION PROJECT

PUMP SELECTION - MAIN ST.

PROJECT NO. 6205-2

SHEET NO. 1 OF

DATE 3-21-63

COMPUTED BY HDM

CHECKED BY PT

From sh. 3A, 18" pump would be controlled at the high head point. This could ultimately shift control partially to a case with water at the top of the wall, H = 31-32' total. It is desirable that significant capacity be available at this head.

To meet this requirement using Plate No 21B would be difficult, and would involve overcapacity at point 1 and probably at point 2, since it would be necessary to design for a point at 31.5' head as a point 3.

Say pt. 3 = 31.5', 5500 gpm

$$Q_m = \frac{5500}{\left(\frac{18}{16}\right)^2} = 4350$$

$$H = 20' \quad Q_x = 4350 \frac{20}{31.5} = 2760$$

$$40' \quad Q_x = 4350 \frac{40}{31.5} = 5520$$

$$50' \quad Q_x = 4350 \frac{50}{31.5} = 6900$$

} this is beyond
the curves
Pl. 21B.

Try 31.5', 6000

$$Q_m = \frac{6000}{\left(\frac{18}{16}\right)^2} = 4740$$

$$H = 30', \quad Q_x = 4740 \frac{30}{31.5} = 4500$$

$$H = 40' \quad Q_x = 4740 \frac{40}{31.5} = 6000$$

$$H = 50' \quad Q_x = 4740 \frac{50}{31.5} = 7500$$

} also beyond
Curves, Pl. 21B

PROJECT Chicopee Falls

SUBJECT Local Protection Project
Pump selection, Main St.

PROJECT NO. 6205-2
SHEET NO. 5 OF
DATE 3-22-63
COMPUTED BY JBT
CHECKED BY PSC

20" Mixed-Flow, Curve 21A

Thru pt. #2 - 21.4', 9000 gpm

$$Q_m = \frac{Q_p}{\left(\frac{D_p}{D_m}\right)^2} = \frac{9000}{\left(\frac{20}{16}\right)^2} = 5760$$

$$H = 20, \quad Q_x = Q_m \left(\frac{H_x}{H_c}\right)^{1/2} = 5760 \left(\frac{20}{21.4}\right)^{1/2} = 5580$$

$$35, \quad Q_x = 7360$$

$$40, \quad Q_x = 7870$$

$$N_c = N_x \left(\frac{Q_c}{Q_x}\right) = \frac{5760}{7525} (1288) = 985 \text{ RPM}$$

$$\frac{Q_p}{Q_m} = \frac{P_p}{P_m} = \left(\frac{D_p}{D_m}\right)^2 = \left(\frac{20}{16}\right)^2 = 1.56$$

$$Q_p = 1.56 Q_c = 1.56 \left(\frac{985}{1288}\right) Q_x = 1.195 Q_x$$

$$H_p = H_c = \left(\frac{960}{1288}\right)^2 H_x = .585 H_x$$

$$P_p = 1.56 Q_c = 1.56 \left(\frac{985}{1288}\right)^3 P_x = .700 P_x$$

$$N_p = \frac{D_m}{D_p} N_m = \frac{16}{20} (985) = 788$$

H_x	Q_x	P_x	H_p	Q_p	P_p	EFF.
45	5550	80.9	26.3	6640	56.6	78.0
37*	7450	82.5	21.7	8900	57.7	82.1
30	8450	81.0	17.5	10100	56.7	78.7
10	9800	65.0	5.9	11830	45.5	38.8

$N_s = 7400$ $H = 21.7$ 13' lift

PROJECT CHICOPPEE FALLS

SUBJECT LOCAL PROTECTION PROJECT

PUMP SELECTION MAIN ST.


PROJECT NO. 62052

SHEET NO. _____ OF _____

DATE 3/24/63

COMPUTED BY POP

CHECKED BY _____



CAPACITY TGPM C-9
 20" Mixed Flow

REF. PLATE # 21A

PROJECT Chicopee Falls

SUBJECT Local Protection Project

Pump Selection - Main St.

8" Axial Flow Pump - Plate #19

Condition Pt. #1 H = 10.1 Q = 9900

$$D_p = 20 \left(\frac{9900}{14250} \right)^{1/2} = 16.7 \quad \text{Try } 18''$$

$$Q_m = 9900 \left(\frac{20.0}{18.0} \right)^2 = 12230$$

$$H_x = 10.0 \quad Q_x = 12230 \sqrt{\frac{10.0}{10.1}} = 12800$$

$$H_x = 15.0 \quad Q_x = 12230 \sqrt{\frac{15.0}{10.1}} = 14900$$

$$H_x = 12.5 \quad Q_x = 12230 \sqrt{\frac{12.5}{10.1}} = 13600$$

$$N_c = 1037 \times \frac{12230}{13800} = 920$$

$$Q_p = Q_x \times \left(\frac{920}{1037} \right) \left(\frac{18.0}{20.0} \right)^2 = .719 Q_x$$

$$H_p = H_x \times \left(\frac{920}{1037} \right)^2 = .788 H_x$$

$$P_p = P_x \times \left(\frac{920}{1037} \right)^3 \left(\frac{18.0}{20.0} \right)^2 = .567 P_x$$

H_x	Q_x	P_x	$Eff = \frac{Q \times H}{3960 \times P}$
32.5	9500	97.0	
25.25	11650	86.0	
15.25	13500	68.0	
4.00	14900	46.0	

H_p	Q_p	P_p	Eff.
25.6	6830	55.0	80.3
19.9	8380	48.8	86.4 Max
12.0	9720	38.6	76.3
3.2	10710	26.1	33.2

$$N_p = \frac{20}{18} \times 920 = 1021$$

$$N_s = 9930 \quad H = 19.9 \quad 7' \text{ lift}$$

C-10

PROJECT Chicopee Falls
SUBJECT Local Protection Project
Pump Selection - Main St.

18" Axial Flow Pump - Plate #19

Condition Pt. #2 H = 21.4 Q = 9000

18" Pump

$$Q_m = 9000 \left(\frac{20.0}{18.0} \right)^2 = 11120$$

$$H_x = 25.0 \quad Q_x = 11120 \sqrt{\frac{25.0}{21.4}} = 12000$$

$$H_x = 22.5 \quad Q_x = 11120 \sqrt{\frac{22.5}{21.4}} = 11400$$

$$N_c = 1037 \times \frac{11120}{11800} = 975$$


$$Q_p = Q_x \left(\frac{975}{1037} \right) \times .81 = .763 Q_x$$

$$H_p = H_x \left(\frac{975}{1037} \right)^2 = .887 H_x$$

$$P_p = P_x \left(\frac{975}{1037} \right)^3 \times .81 = .676 P_x$$

H _p	Q _p	P _p	Eff.
28.8	7250	65.5	80.4
22.4	8900	58.2	86.5 <i>max</i>
13.5	10300	45.9	76.4
3.6	11400	31.1	33.3

$$N_p = \frac{20}{18} \times 975 = 1085$$



PROJECT Chicopee Falls

SUBJECT Local Protection Project
Pump Selection - Main St.

20" Axial Flow Pump Plate #19
 Condition Pt. #2 H = 21.4' Q = 9000 20" Pump

$$Q_m = 9000 \left(\frac{20.0}{20.0} \right)^2 = 9000$$

$$H_x = 27.5 \quad Q_x = 9000 \left(\frac{27.5}{21.4} \right)^{1/2} = 10200$$

$$H_x = 30.0 \quad Q_x = 9000 \left(\frac{30.0}{21.4} \right)^{1/2} = 10650$$

$$N_c = 1037 \frac{9000}{10550} = 885$$

$$Q_p = Q_x \left(\frac{885}{1037} \right) \left(\frac{20.0}{20.0} \right)^2 = .853 Q_x$$

$$H_p = H_x \left(\frac{885}{1037} \right)^2 = .727 H_x$$

$$P_p = P_x \left(\frac{885}{1037} \right)^3 \left(\frac{20.0}{20.0} \right)^2 = .621 P_x$$

H _x	Q _x	P _x
32.5	9500	97.0
25.25	11650	86.0
15.25	13500	68.0
4.0	14900	46.0

H _p	Q _p	P _p	Eff.
23.6	8100	60.2	80.2
18.4	9950	54.5	84.8 Max
11.1	11530	42.2	76.5
2.9	12710	28.6	32.6

$$N_p = 885$$

$$N_s = 9930 \quad H = 18.4 \quad 8' \text{ lift}$$

PROJECT CHESAPEE FALLS

SUBJECT LOCAL PROTECTION PROJECT

PUMP SELECTION - MAIN ST.


PROJECT NO. 6205-2

SHEET NO. _____ OF _____

DATE 3/22/63

COMPUTED BY POP

CHECKED BY _____



CAPACITY TGPM
 20" Axial Flow

C-14
 REF. PLATE #19

PROJECT Chicopee Falls

SUBJECT Local Protection Project
Pump Selection - Main St.

22" Axial Flow Pump - Plate #19

Condition Pt. #2 H = 21.4 Q = 9000 22" Pump

$$Q_m = 9000 \left(\frac{20.0}{22.0} \right)^2 = 7440$$

$$H_x = 32.5 \quad Q_x = 7440 \left(\frac{32.5}{21.4} \right)^2 = 9170$$

$$H_x = 30.0 \quad Q_x = 7440 \left(\frac{30.0}{21.4} \right)^2 = 8820$$

Note: The line of constant specific speed lies beyond the limits of the H-Q Curve. A pump can not be selected on this basis without extrapolating from the H-Q curves. No further selection will be attempted.

PROJECT CHICOPEE FALLS

SUBJECT LOCAL PROTECTION

PUMP SELECTION - MAIN ST.


PROJECT NO. 6205-2

SHEET NO. _____ OF _____

DATE 5/26/63

COMPUTED BY PCP

CHECKED BY _____



CAPACITY TGPM

C-16

REF. PLATE #19

SUBJECT Local Protection Project
Pump Selection - Main St

Pump Type	Pump Size (Inches)	Pump Speed RPM	Condition Pt. #1				Condition Pt. #2				Top of Local Protection				actual Submgs - 8.0' lift	
			GPM	Head	BHP	Eff.	GPM	Head	BHP	Eff.	GPM	Head	BHP	Eff.		
Mixed 2, 7 (21B)	16"	1263	9900	10.1	60	56.5	9000	21.4	65	75	7900	30.0	66.5	82.5	1.4' lift	
			Comparitive Cost = \$1200													
Mixed 3, 4, 5 (21B)	18"	982	10750	10.1	51.5	56	9000	21.4	60	80	Does not Reach				10.0' lift	
Mixed 7, 8 (21A)	20"	788	11400	10.1	50	53.5	9000	21.4	58	82	Does not Reach				13.0' lift	
Axial 9, 10 11 19)	18"	1085	10350	10.1	50	82.5	9000	21.4	57	86	Does not Reach				7.0' lift	
Axial 12, 13 (17)	20"	885	11700	10.1	40	74.5	9000	21.4	58	83	Does not Reach				8.0' lift	
Axial (17) 27, 28)	22"	See note sheet #C-15														

C-17

PROJECT CHICOPEE FALLS

SUBJECT Local Protection Project
Pump Selection - OAK ST.

PROJECT NO. 6205-2
 SHEET NO. 6 OF _____
 DATE 2-19-63
 COMPUTED BY RAJ
 CHECKED BY RDP

OAK ST.


Q - H.W.L. 7000 gpm
 L.W.L. 8600 "

Static Heads

H.W.L. - 21.1
 L.W.L. - 7.0

Project Design Elev.

H.W.L. = 96'
 L.W.L. = 82'



16" Col. , $V = 13.5$ Fps , L.W.L.
 11.1 Fps , H.W.L.

Conduit velocity, 3 pumps -
 2.9 Fps H.W.L.
 3.55 Fps L.W.L.

(size set for by-pass)
 gravity flow

$$TDH = \text{Static} + H_b + .01 H_{v \text{ col}} + H_{v \text{ Conduit}} + \frac{1}{2} H_{v \text{ conduit}} + H_f \text{ Conduit}$$

Col. (Flap) (dischg. chamber) & entrance

PROJECT Cherokee Falls

SUBJECT Local Protection Project
Pump Selection - Oak St.

PROJECT NO. 6205-2
SHEET NO. 7 OF _____
DATE 2-26-63
COMPUTED BY ROP
CHECKED BY HDM

Condition #1

Static head =		7.0
Col Hr =	$\frac{13.5}{2.9}$	2.83
Flap Hr =	$.01 \times \frac{13.5}{2.9}$	0.03
Conduit Hr =	$\frac{3.55^2}{2.9}$	0.20
Ent. Disch. Chamber =	$\frac{1}{2} \frac{3.55^2}{2.9}$	0.10
Conduit Hf =	$2.87 \times (0.013)^2 \times 82 \times \frac{3.55^2}{4.52^{4/3}}$	0.67
		<u>10.83</u>

TDH = 10.8'

Condition #2

Static Head =		21.10
Col Hr =	$\frac{11.1}{2.9}$	1.93
Flap Hr =	$.01 \frac{11.1}{2.9}$	0.02
Conduit Hr =	$\frac{2.9^2}{2.9}$	0.13
Ent. Disch. Chamber =	$\frac{1}{2} \frac{2.9^2}{2.9}$	0.07
Conduit Hf =	$2.87 \times (0.013)^2 \times 82 \times \frac{2.9^2}{4.52^{4/3}}$	0.28
		<u>23.53</u>

TDH = 23.5'

Note: Revising Flap valve losses & pump col size increased TDH, ea. condi, by only 1/10 of a foot. Changes on subsequent sheets not made because changes are insignificant for preliminary pump selection

PROJECT Chicopee Falls

SUBJECT Local Protection Project.

Pump Selection - Oak St.

Try 16" Pump - Plate 21C Mixed
#1

$$\text{Discharge Dia.} = \sqrt{\frac{4 \times 17.6 \times 144}{12\pi}} = 16.4"$$

#2
Condition #1 $H_1 = 10.8'$ $Q_1 = 8600$ GPM
 $H_2 = 23.5'$ $Q_2 = 7000$ GPM

#3
$$D_p = D_m \left(\frac{Q_p}{Q_m} \right)^2 = 16 \left(\frac{8600}{9425} \right)^2 = 15.30" \text{ Use 16" Pump}$$

#4
$$Q_m = \frac{Q_p}{\left(\frac{D_p}{D_m} \right)^2} = \frac{8600}{\left(\frac{16}{16} \right)^2} = 8600$$

$$Q_x = Q_c \left(\frac{H_x}{H_c} \right)^2$$

for $H_x = 10.0$ $Q_x = 8600 \left(\frac{10.0}{10.7} \right)^2 = 8310$

$H_x = 12.5$ $Q_x = 8600 \left(\frac{12.5}{10.7} \right)^2 = 9290$

$H_x = 15.0$ $Q_x = 8600 \left(\frac{15.0}{10.7} \right)^2 = 10200$

$$N_c = N_x \left(\frac{Q_c}{Q_x} \right) = 1378 \left(\frac{8600}{9275} \right) = 1278$$

$$Q_c = C_x \left(\frac{N_c}{N_x} \right) = Q_x \left(\frac{1278}{1378} \right) = .927 Q_x$$

$$H_c = H_x \left(\frac{N_c}{N_x} \right)^2 = H_x \left(\frac{1278}{1378} \right)^2 = .859 H_x$$

$$P_c = P_x \left(\frac{N_c}{N_x} \right)^3 = P_x \left(\frac{1278}{1378} \right)^3 = .796 P_x$$

H_x	Q_x	P_x	H_c	Q_c	P_c	EFF.
44.5	4750	68.5	38.2	4400	54.5	77.8
36.0	6650	68.5	30.9	6160	54.5	Max. 88.3
25.0	8075	63.5	21.5	7480	50.5	80.4
10.0	9475	53.5	8.6	8780	42.6	44.8

$N_p = 1278$


$N_3 = 7650$ $H = 30.9$ Submergence = 5.0' lift.

C-20

PROJECT NO. 6205-2
 SHEET NO. _____ OF _____
 DATE 2/26/63
 COMPUTED BY RJP
 CHECKED BY _____

PROJECT CHICOPEE FALLS

SUBJECT LOCAL PROTECTION PROJECT
PUMP SELECTION - OAK ST.



CAPACITY TGPM C-21
 16" Maxed REF. PLATE #21C

PROJECT Chicopee Falls

SUBJECT Local Protection Project
Pump Selection - Oak St.

Try 18" pump - Plate 21C Pt.#1 H=10.8' Q=8600

#4
$$Q_m = Q_p \left(\frac{D_m}{D_p} \right)^2 = 8600 \left(\frac{16}{18} \right)^2 = 6790$$

$$Q_x = Q_c \left(\frac{H_x}{H_c} \right)^{1/2}$$

$$H_x = 17.5 \quad Q_x = 6790 \left(\frac{17.5}{10.7} \right)^{1/2} = 8800$$

$$H_x = 20.0 \quad Q_x = 6790 \left(\frac{20.0}{10.7} \right)^{1/2} = 9290$$

$$N_c = N_x \left(\frac{Q_c}{Q_x} \right) = 1378 \left(\frac{6790}{8850} \right) = 1058$$

$$Q_p = Q_x \left(\frac{N_c}{N_x} \right) \left(\frac{D_p}{D_m} \right)^2 = \left(\frac{1058}{1378} \right) \left(\frac{18.0}{16.0} \right)^2 Q_x = .971 Q_x$$

$$H_p = H_x \left(\frac{N_c}{N_x} \right)^2 = \left(\frac{1058}{1378} \right)^2 H_x = .588 H_x$$

$$P_p = P_x \left(\frac{N_c}{N_x} \right)^3 \left(\frac{D_p}{D_m} \right)^2 = \left(\frac{1058}{1378} \right)^3 \left(\frac{18.0}{16.0} \right)^2 P_x = .572 P_x$$

H _p	Q _p	P _p	Eff.
26.2	4610	39.2	78.8
21.2	6470	39.2	88.4 Max.
14.7	7840	36.3	80.2
5.9	9200	30.3	45.2

$$N_p = 1058 \left(\frac{16.0}{18.0} \right) = 939$$

$$N_s = 7650 \quad H = 21.2 \quad \text{Submergence} = 13 \text{ft. lift.}$$

PROJECT Chicopee Falls

SUBJECT Local Protection Project

Pump Selection - Oak St.

18" Pump # 21C Pt. # 2 H = 23.5 Q = 7000
6

$$Q_m = 7000 \left(\frac{16}{18} \right)^2 = 5530$$

$$Q_x = Q_c \left(\frac{H_x}{H_c} \right)^{1/2}$$

$$H_x = 37.5 \quad Q_x = 5530 \left(\frac{37.5}{23.4} \right)^{1/2} = 7000$$

$$H_x = 35.0 \quad Q_x = 5530 \left(\frac{35.0}{23.4} \right)^{1/2} = 6770$$

$$N_c = N_x \left(\frac{Q_c}{Q_x} \right) = 1378 \left(\frac{5530}{6770} \right) = 1125$$

$$Q_p = Q_x \left(\frac{N_c}{N_x} \right) \left(\frac{D_p}{D_m} \right)^2 = Q_x \left(\frac{1125}{1378} \right) \left(\frac{18.0}{16.0} \right)^2 = 1.035 Q_x$$

$$H_p = H_x \left(\frac{N_c}{N_x} \right)^2 = H_x \left(\frac{1125}{1378} \right)^2 = .608 H_x$$

$$P_p = P_x \left(\frac{N_c}{N_x} \right)^3 \left(\frac{D_p}{D_m} \right)^2 = P_x \left(\frac{1125}{1378} \right)^3 \left(\frac{18.0}{16.0} \right)^2 = .691 P_x$$

H_p	Q_p	P_p	EFF.
29.7	4920	47.3	78.0
24.2	6890	47.3	89.0 Max
16.7	8360	43.8	80.5
6.7	9810	36.9	45.0

$$Eff = \frac{H_p Q_p}{P_p \times 3960}$$

$$N_p = \frac{16}{18} 1125 = 1000$$

$$N_s = 7650 \quad H = 24.2 \quad \text{Submergence} = 11' \text{ lift}$$

PROJECT CHKOPEE FALLS

SUBJECT LOCAL PROTECTION PROJECT

PUMP SELECTION - OAK ST


PROJECT NO. 6205-2

SHEET NO. _____ OF _____

DATE 2/27/63

COMPUTED BY RDY

CHECKED BY _____



C-24

CAPACITY TGPM

18" Mixed

REF. PLATE #21C

PROJECT Chicopee Falls

SUBJECT Local Protection Project
Pump Selection - Oak St

Try 20" Mixed Flow H=10.8 Q=8600 PT#1

$$\#4 \quad Q_m = Q_p \left(\frac{D_m}{D_p} \right)^2 = 8600 \left(\frac{16.0}{20.0} \right)^2 = 5500$$

$$Q_x = Q_L \left(\frac{H_x}{H_L} \right)^{\frac{1}{2}}$$

$$H_x = 25.0 \quad Q_x = 5500 \sqrt{\frac{25.0}{10.8}} = 8360$$

$$H_x = 22.5 \quad Q_x = 5500 \sqrt{\frac{22.5}{10.8}} = 7940$$

$$N_L = N_x \left(\frac{Q_L}{Q_x} \right) = 1378 \left(\frac{5500}{8175} \right) = 926$$

$$Q_p = Q_x \left(\frac{N_L}{N_x} \right) \left(\frac{D_p}{D_m} \right)^2 = Q_x \left(\frac{926}{1378} \right) \left(\frac{20.0}{16.0} \right)^2 = 1.052 Q_x$$

$$H_p = H_x \left(\frac{N_L}{N_x} \right)^2 = H_x \left(\frac{926}{1378} \right)^2 = .453 H_x$$

$$P_p = P_x \left(\frac{N_L}{N_x} \right)^3 \left(\frac{D_p}{D_m} \right)^2 = P_x \left(\frac{926}{1378} \right)^3 \left(\frac{20.0}{16.0} \right)^2 = .476 P_x$$

H_x	Q_x	P_x	$EFF = \frac{Q \times H}{3960 \times P}$
44.50	4750	69.0	
36.00	6650	69.0	
25.75	8000	64.0	
10.00	9475	54.0	

H_p	Q_p	P_p	Eff.
20.2	5000	32.8	78
16.3	7000	32.8	88 <i>prop</i>
11.7	8420	30.4	82
4.5	9975	25.6	44

$$N_p = \frac{16}{20} \times 926 = 742$$

PROJECT Chicopee Falls

SUBJECT Local Protection Project

Pump Selection - Cat St.

20" Mixed Flow H = 23.5 Q = 7000 Pt #2

#6

$$Q_m = 7000 \left(\frac{16.0}{20.0} \right)^2 = 4480$$

$$H_x = 42.5 \quad Q_x = 4480 \sqrt{\frac{42.5}{23.5}} = 6025$$

$$H_x = 40.0 \quad Q_x = 4480 \sqrt{\frac{40.0}{23.5}} = 5850$$

$$N_c = 1378 \left(\frac{4480}{5850} \right) = 1055$$

$$Q_p = \left(\frac{1055}{1378} \right) \left(\frac{20.0}{16.0} \right)^2 Q_x = 1.197 Q_x$$


$$H_p = \left(\frac{1055}{1378} \right)^2 H_x = .586 H_x$$

$$P_p = \left(\frac{1055}{1378} \right)^3 \left(\frac{20.0}{16.0} \right)^2 P_x = .702 P_x$$

H_p	Q_p	P_p	Eff.
26.1	5680	48.4	77.4
21.1	7960	48.4	87.6 <i>max.</i>
15.1	9575	44.9	81.3
5.9	11350	37.9	44.6

$$N_p = \frac{16}{20} \times 1055 = 845$$

$$N_s = 7650 \quad H = 21.1 \quad 14' \text{ lift}$$



C-27

REF PLATE #21C
 20" MINED

PROJECT Chicopee Falls

SUBJECT Local Protection Project

Pump Selection - Oak St.

16" Axial Flow - Pump Selection Plate 19

#3 Conduction Point #1 H = 10.8 Q = 8600

$$D_p = 20 \left(\frac{8600}{14625} \right)^{\frac{1}{2}} = 15.3" \text{ Use } 16"$$

$$Q_m = 8600 \left(\frac{20.0}{16.0} \right)^2 = 13450$$

$$H = 12.5 \quad Q_x = 13450 \left(\frac{12.5}{10.8} \right)^{\frac{1}{2}} = 14470$$

$$H = 10.0 \quad Q_x = 13450 \left(\frac{10.0}{10.8} \right)^{\frac{1}{2}} = 12950$$

$$N_c = 1037 \left(\frac{13450}{14000} \right) = 995$$

$$Q_p = Q_x \left(\frac{995}{1037} \right) \left(\frac{16.0}{20.0} \right)^2 = .615 Q_x$$

$$H_p = H_x \left(\frac{995}{1037} \right)^2 = .922 H_x$$

$$P_p = P_x \left(\frac{995}{1037} \right)^3 \left(\frac{16.0}{20.0} \right)^2 = .566 P_x$$

H _x	Q _x	P _x
32.5	9500	98.5
23.75	12000	83.0
11.75	14000	61.0
4.00	14900	43.0

H _p	Q _p	P _p	Eff.
30.0	5850	55.7	79.5
21.9	7380	46.1	88.6 Max.
10.8	8610	34.5	64.5
3.7	9170	24.3	35.3

$$N_p = \frac{20}{16} \times 995 = 1245$$

$$N_s = 9930 \quad H = 21.9 \quad 5' \text{ lift}$$

PROJECT NO. 6205
SHEET NO. _____ OF _____
DATE 3/26/63
COMPUTED BY ROP
CHECKED BY _____


C-28

PROJECT CHKOPEE FALLS

SUBJECT LOCAL PROTECTION PROJECT

PUMP SELECTION - OAK ST.

PROJECT NO. 6205-2
 SHEET NO. _____ OF _____
 DATE 3/26/63
 COMPUTED BY ROP
 CHECKED BY _____



C-29
 REF PLATE #19
 16" Axial

PROJECT Chicopee Falls

SUBJECT Local Protection Project

Pump Selection - Oak St.

18" Axial Flow - Pump Selection Plate 18 of 19

Condition Point # 2 Try 18"

$$Q_m = 7000 \left(\frac{20.0}{18.0} \right)^{\frac{1}{2}} = 7380$$

$$H_x = 25.0 \quad Q_x = 7380 \left(\frac{25.0}{23.5} \right)^{\frac{1}{2}} = 7620$$

$$H_x = 35.0 \quad Q_x = 7380 \left(\frac{35.0}{23.5} \right)^{\frac{1}{2}} = 9000$$

$$H_x = 32.5 \quad Q_x = 7380 \left(\frac{32.5}{23.5} \right)^{\frac{1}{2}} = 8670$$

Note: The line of constant specific speed lies beyond the limits of the H-Q curve. A pump can not be selected on this basis without extrapolating from the H-Q curves.
No further selection will be attempted.

20" Axial Flow - Selection not attempted
No Curves Drawn

PROJECT CHICOPEE FALLS

SUBJECT LOCAL PROTECTION PROJECT

PUMP SELECTION - OAK ST.


PROJECT NO. 6205

SHEET NO. _____ OF _____

DATE 3/24/63

COMPUTED BY REP

CHECKED BY _____



18" Axial

CAPACITY TGPM

REF. PLATE #19

C-31

PROJECT CHICOPPEE FALLS

SUBJECT LOCAL PROTECTION PROJECT
PUMP SELECTION - OAK ST


PROJECT NO. 1225-2

SHEET NO. _____ OF _____

DATE 3/26/63

COMPUTED BY POOP

CHECKED BY _____



CAPACITY TGPM

C-32

18" Axial

REF PLATE #19

SUBJECT Local Protection Project

Pump Selection - Oak St.

Pump Type	Pump Size Inches	Pump Speed RPM	Condition Pt. #1				Condition Pt. #2				Top of Local Protection				Pump ft. lift
			GPM	Head	BHP	EFF.	GPM	Head	BHP	EFF.	GPM	Head	BHP	EFF.	
Mixed	16"	1278	8600	10.8	46	53	7250	23.5	52	82.5	6800	27.0	53.5	86	5' lift
			Comparitive Cost = \$1200												
Mixed	18"	1000	9250	10.8	40	65	7000	23.5	48	88.5	6000	27.0	49	87	11.0' lift
			Comparitive Cost = \$1400												
Mixed	20"	845	10400	10.8	42	71	7000	23.5	49	86.5	Does not Reach				14.0' lift
Axial	16"	1245	8600	10.8	34.5	64.5	7100	23.5	44	88.5	6500	27.0	56	86	5.0' lift
			Comparitive Cost = \$1100												
Axial	18"	See note		sh. # C-29											
Axial	20"	See note		sh. # C-29											

C-33

PROJECT CHICOPEE FALLS

SUBJECT Local Protection Project
Pump Selection - Main St.
Effect of Varying speed

PROJECT NO. 6205-2
SHEET NO. 30 OF _____
DATE 4-2-63
COMPUTED BY _____
CHECKED BY _____

$$N_p = 1269 \text{ RPM}$$

$H_p (1269)$	$Q_p (1269)$	$H (1200)$	$Q_p (1200)$	$H (1000)$	$Q (1000)$
9.6	9950	8.6	9350	5.9	7850
14.4	9700	12.8	9100	8.9	7650
19.2	9300	17.1	8750	11.9	7350
24.0	8800	21.4	8300	14.8	6900
33.6	7100	30.0	6700	20.8	5600

$$Q_{1200} = \frac{1200}{1269} Q_p = .94 Q_p$$

$$H_{1200} = \left(\frac{1200}{1269}\right)^2 H_p = .89 H_p$$

$$Q_{1000} = \frac{1000}{1269} Q_p = .79 Q_p$$

$$H_{1000} = \left(\frac{1000}{1269}\right)^2 H_p = .62 H_p$$

$$Q_{800} = \frac{800}{1269} Q_p = .63$$

$$H_{800} = \left(\frac{800}{1269}\right)^2 H_p = .4$$


H_{800}	Q_{800}
3.8	6300
5.8	6100
7.7	5850
9.6	5500
13.1	4500

PROJECT CHIGOPEE FALLS

SUBJECT LOCAL PROTECTION PROJECT
PUMP SELECTION - MAIN ST.

PROJECT NO. 6205-2
SHEET NO. _____ OF _____
DATE 4/2/63
COMPUTED BY _____
CHECKED BY _____

EFFECT OF VARYING SPEED



PROJECT Chicopee Falls

SUBJECT Local Protection Protection
Pump Selection - Oak St.

PROJECT NO. 6205-2
SHEET NO. 32 OF _____
DATE 4-2-63
COMPUTED BY _____
CHECKED BY _____

Effect of varying speed

$$N_p = 1245 \text{ RPM}$$

H_p	Q_p	H_{1100}	Q_{1100}	H_{800}	Q_{800}
30	5850	23.5	5150	12.3	3750
21.9	7380	17.0	6500	9.0	4700
10.8	8610	8.5	7600	4.4	5500
3.7	9170	2.9	8100	1.5	5850

$$Q_{1100} = Q_p \frac{1100}{1245} = .88 Q_p$$

$$H_{1100} = H_p \left(\frac{1100}{1245}\right)^2 = .78 H_p$$

$$Q_{800} = Q_p \frac{800}{1245} = .64 Q_p$$

$$H_{800} = H_p \left(\frac{800}{1245}\right)^2 = .41 H_p$$

EFFECT OF VARYING SPEED

