Inspection Report for North Sturbridge Road Solar Facility NPDES ID No.: MAR10031G

NPDES ID No.: MAR10031G Inspection Date: 04/27/2022

			General Info	ormation					
Weather conditions during inspection	52°F, 0	cloudy	Inspection	9:00 AM	Inspection end	9:35 AM			
Inspector Name, Title Contact Information	&	Chanler Florian, Environmental Scientist (BETA Group, Inc.) cflorian@beta-inc.com 8603297045							
Present Phase of Construction		Phase 1. NOTE: The access road and stabilized construction entrance has been established pursuant to the Phase 1 scope of work. However, the entirety of the Site has been cleared of trees. No grubbing/stumping has occurred other than that required to establish the Site access road.							
Inspection Location		North Sturbridge Road Solar Fa	oridge Road Solar Facility – Entirety of Site (0 North Sturbridge Road, Charlton, MA 01507)						
Standard Frequency: ☐Every 7 days	_	may be subject to different inspec							
Every 14 days and within 24 hours of a 0.25" rain or the occurrence of runoff from snowmelt sufficient to cause a discharge  Increased Frequency:  Every 7 days and within 24 hours of a 0.25" rain (for areas of sites discharging to sediment or nutrient-impaired waters or to waters designated as Tier 2, or Tier 3)									
Reduced Frequency:  Twice during first month, no more than 14 calendar days apart; then once per month after first month; (for stabilized areas)  Twice during first month, no more than 14 calendar days apart; then once more within 24 hours of a 0.25" rain (for stabilized areas on "linear construction site									
Was this inspection triggered by a 0.25" storm event? ☐ Yes ☐ No  If yes, how did you determined whether a 0.25" storm event has occurred?  ☐ Rain gauge on site ☐ Weather station representative of site. Specify weather station source: Worcester Regional Airport  Total rainfall amount that triggered the inspection (inches): 0.25"  Was this inspection triggered by the occurrence of runoff from snowmelt sufficient to cause a discharge? ☐ Yes ☐ No									

Inspection Report for North Sturbridge Road Solar Facility

NPDES ID No.: MAR10031G Inspection Date: 04/27/2022

Unsafe Conditions for Inspection
----------------------------------

Did you determine that any portion of your site was unsafe for inspection per CGP Part 4.1.5? 

Yes 
No If "yes", complete the following:

- Describe the conditions that prevented you from conducting the inspection in this location: N/A
- Location where conditions were found: N/A

	Condition and Effectiveness of Erosion and Sediment (E&S) Controls (CGP Part 2.2)							
Type/Location of E&S Control	Maintenance Needed?*							
Silt Fence and Straw Wattles	Yes	Yes	1/28/ 2022	On 1/28/2022 Supreme repaired previously reported damage to silt fence and wattles at the Site.  On 2/2/2022 BETA verified the repairs made by				
			2/2/ 2022	Supreme.				
			3/15/ 2022	On 3/15/2022 BETA observed torn silt fence in multiple lo-				
Stabilized Construction Entrance     (Site Entrance – Access Road)	No	No		cations along the perimeter of the Site. The silt wattles  are still serving their intended purpose but require main-				
3. Stump and Soil Stockpile Area	No	No		tenance.				
4. Dust Controls	N/A	N/A	3/24/2022	On 3/24/2022 BETA observed damaged silt fence in the southeast corner and northern portions of the Site. No evidence of discharge was observed.				
5. Jute Mesh (Steep Slopes)	N/A	N/A						
6. Temporary Seeding	No	No						

Inspection Report for North Sturbridge Road Solar Facility NPDES ID No.: MAR10031G

NPDES ID No.: MAR10031G Inspection Date: 04/27/2022

1spection Date: 04/21/2022								
7. Topsoil Re-Use 8. Storm Drain Inlets (North Brookfield Road) 9. Temporary Drainage Swales (Throughout Site) 10. Temporary Sediment Basins (Throughout Site)		N/A N/A N/A		N/A N/A N/A		4/1/2022 4/8/2022		On 4/1/2022 BETA observed repairs on the collapsed portions of the silt fence located in the north east corner. BETA observed damage to the silt fence and wattle in the north east corner of the Site. No evidence of discharge was observed.  On 4/8/2022 BETA observed torn silt fence in the eastern portion of the Site, No evidence of discharge was observed.
()						4/27/2022		On 4/27/2022 BETA observed damage to the wattles in the northeast and east corners of the Site. No evidence of discharge was observed.
		Condi	tion and	l Effectiv	eness (	of Pollution P	reventic	on (P2) Practices (CGP Part 2.3)
Type/Location of P2 Practices [insert additional rows if applicable]	Mainte Neede	enance	Correct Action Require	tive	Date o Mainte Correc	n Which nance or tive Action entified?	Notes	
Equipment Refueling	□Yes	⊠No	□Yes	⊠No	[Enter o	date]		
Staging Area  2. Hydraulic Lines	□Yes	⊠No	□Yes	⊠No	[Enter o	date]		
Staging/Work Areas	□Yes	⊠No	□Yes	⊠No	[Enter o	date]		
Equipment Maintenance     Staging Area	□Yes	⊠No	□Yes	⊠No	[Enter o	date]		
4. Sanitary Toilets	□Yes	⊠No	□Yes	⊠No	[Enter o	date]		
Staging Area  5. Vehicle Accident	□Yes	⊠No	□Yes	⊠No	[Enter o	date]		
Entire Site	□Yes	⊠No	□Yes	⊠No	[Enter o	date]	•	

Inspection Report for North Sturbridge Road Solar Facility

NPDES ID No.: MAR10031G Inspection Date: 04/27/2022

Staging/Work Areas				
8. Concrete Washout	□Yes⊠No	□Yes⊠No	[Enter date]	

Stabilization of Exposed Soil (CGP Part 2.2.14)							
Stabilization Area [insert additional rows if applicable]	Stabilization Method	Have You Initiated Stabilization?	Notes				
Earthen access road leading to stockpile area	Straw mulch or hydroseed	⊠Yes 7/30/2021 □No	The stockpile area and associated access road have been hydroseeded. Germination has begun and the area will be monitored for successful establishment.				
Informal access road along northern portion of the Site	Straw mulch or hydroseed	□Yes [Enter date] ⊠No	Erosion channels are beginning to form within upgradient portions of the informal access road (Figure 1). The contractor indicated that stabilization by smoothing out soils and seeding or spreading mulch would occur on 7/30/2021. Stabilization of this area has not been initiated. After inspection of the area on 8/24/2021, it was determined that				

<sup>\*</sup> Note: The permit differentiates between conditions requiring routine maintenance, and those requiring corrective action. The permit requires maintenance in order to keep controls in effective operating condition. Corrective actions are triggered only for specific conditions, which include: 1) A stormwater control needs repair or replacement (beyond routine maintenance) if it is not operating as intended; 2) A stormwater control necessary to comply with the permit was never installed or was installed incorrectly; 3) You become aware that the stormwater controls you have installed and are maintaining are not effective enough for the discharge to meet applicable water quality standards or applicable requirements in Part 3.1; 4) One of the prohibited discharges in Part 1.3 is occurring or has occurred; or 5) EPA requires corrective actions as a result of a permit violation found during an inspection carried out under Part 4.8. If a condition on your site requires a corrective action, you must also fill out a corrective action form found at <a href="https://www.epa.gov/npdes/stormwater-discharges-construction-activities#resources">https://www.epa.gov/npdes/stormwater-discharges-construction-activities#resources</a>. See Part 5 of the permit for more information.

Inspection Report for North Sturbridge Road Solar Facility

NPDES ID No.: MAR10031G Inspection Date: 04/27/2022

ispection bate. 04/21/2022	•	•	
			temporary swales would likely alleviate the issue of channelization in this area; however, these swales will not be constructed until work resumes at the Site in the spring (pending local approval). This area will continue to be monitored; however, stabilization is not required since the area is not discharging sediment beyond the limits of work.
Area beyond the limits of work at Discharge 1	Hand application of seed	⊠Yes 8/24/2021 □No	The sediment deposit previously observed has been removed from beyond the limits of work and the area has been seeded. No sediment migrated within 50 feet of a "water of the US". Straw and additional seed was applied on 8/24/2021.
			On 10/2/2021 BETA verified that grass seed had been successful established. BETA will continue to monitor grass growth in the spring.
Area beyond limits of work at Discharge 2	Hand application of seed	☐Yes Enter Date ☐No	On 4/27/2022 BETA observed the recently seeded grass to be thriving.



Description of Discharges (CGP Part 4.6.6)					
Was a stormwater discharge or other discharge occurring from any part of your site at the time of the inspection?   No  Yes  If "yes", provide the following information for each point of discharge:					
Discharge Location	Observations				
Discharge 1	Describe the discharge: NA  At points of discharge and the channels and banks of surface waters in the immediate vicinity, are there any visible signs of erosion and/or sediment accumulation that can be attributed to your discharge?   No Yes  If yes, describe what you see, specify the location(s) where these conditions were found, and indicate whether modification, maintenance, or corrective action is needed to resolve the issue: NA				

Inspection Report for Month Sturbodge Road Solar Facility NPDES ID No.: MART0031G

Inspection Date: 04/27/2022




#### Contractor or Subcontractor Signature and Certification

system designed to distre that qualified personnel properly gather person or persons who manage the system, or those persons direct best of any implication and belief, true, accurate, and complete.)	ents were prepared under my election or supervision in accordance with a red and exclusion the information submitted, based on my insulty of the fly responsible for gathering the information, the information submitted is to the make no paisanch knowledge that the information submitted is other than true, notifies for submitting false information, including the possibility of the and					
Signature of Contractor or Subcontractor						
Printed Name and Affiliation						
Ореквит.	Signature and Certification					
system designed to assure that qualified paraonnel properly gather person or persons who manage the system, or those persons direct pert of my knowledge and belief, true, accurate, and complete.	ents were prepared under my direction or supervision in accordance with a sed and evokusted the information submitted. Scient on my inquiry of the try responsible for gothering the information, the information submitted is other than their have no personal knowledge that the information submitted is after than that notices for submitting take information, including the possibility of five and their following the possibility of the and the possibility of the and their following the possibility of the and the possibility of					

Printed Name and Attlication:

Chanler Florian

04/27/2022



### Photo 1



View of damaged silt fence in eastern portion of the Site — facing south

#### Photo 2



View of damaged silt fence in southeast portion of the Site — facing south east

# PHOTOGRAPHIC DOCUMENTATION North Sturbridge Road Solar Facility Charlton, Massachusetts Photographs Documented 04.27.2022

## Photo 3



View of damaged silt wattle in northern portion of the Site — facing north

#### Photo 4



View of damaged silt wattle in nort tern portion of the Site — facing north east

#### PHOTOGRAPHIC DOCUMENTATION

North Sturbridge Road Solar Facility Charlton, Massachusetts Photographs Documented 04.27.2022

## Photo 5



View of seeded grass at Discharge 2 — facing north

PHOTOGRAPHIC DOCUMENTATION North Sturbridge Road Solar Facility Charlton, Massachusetts Photographs Documented 04.27.2022