

# SHOP DRAWING REVIEW FORM AND TRANSMITTAL

**DATE:** October 15, 2021

**TO:** Carl Hendrickson  
Project Manager  
Veolia Water  
825 West Water Street  
Taunton, MA 02780

**FROM:** Michael Andrus, P.E.  
Project Manager  
BETA Group, Inc.  
701 George Washington Hwy  
Lincoln, Rhode Island 02865

**RE:** City of Taunton, MA  
WWTF Phase 1 Improvements  
Contract S-2021-1

Shop Drawing No. 02277-01 REV 0 – Straw Wattles

---

## **BETA COMMENTS:**

<u>Item</u>	<u>Action Code</u>	<u>Description/Comments</u>
1	1	<b>Straw Wattles</b> 1. Acceptable as submitted.

### Action Codes

- 1 - No Exception Taken
- 2 - Make Corrections Noted
- 3 - Amend and Resubmit
- 4 - Rejected, See Remarks
- 5 - Record File Only

- a. Installation shall proceed only when Action Code is '1' or '2'.
- b. Submittals action coded '3' shall be resubmitted within time limit set in Contract.
- c. Review does not relieve Contractor from responsibility of compliance with the Contract Documents.



**PROJECT:** 9900. - Veolia/Taunton WWTF Phase 1 Improvements

**DATE:** 10/12/2021

**SUBMITTAL:** 02277-01 - Straw Waddles

**REVISION:** 0

**STATUS:** Eng

**SPEC #:** 02277

**TO:**  
**Michael Andrus**  
 Beta Group Inc.  
 6 Blackstone Place  
 Lincoln, RI 02865  
 MAndrus@BETA-Inc.com

**FROM:**  
**Ryan Murphy**  
 Hart Engineering Corporation  
 800 Scenic View Drive  
 Cumberland, RI 02864  
 rmurphy@hartcompanies.com

Item	Revision	Description	Status	Date Sent	Date Returned
02277-01	0	Straw Waddles	Eng	10/12/2021	
Notes:					

**SHOP DRAWING REVIEW**

1 – Approved                       2 – Approved as Noted  
 3 – Revise and Resubmit             4 - Rejected  
 5 – Record File Only – No Action Taken

(Above Check Designates Action Code – See Review Comments)

**IMPORTANT NOTE FOR CONTRACTOR**

Review is only for general compliance with the design concept and information provided in Contract Documents. Corrections and comments made on the Shop Drawings during review do not relieve the Contractor from compliance with the requirements of the plans and specifications. Review and/or approval of a specific item shall not include review or approval of an assembly of which the item is a component. No approval or correction of a Shop Drawing shall be construed as an order for extra work. The Contractor is responsible for: all quantities and dimensions to be confirmed and correlated; information that pertains solely to the fabrication processes or to the means, methods, techniques, sequences and procedures of construction; coordination of the Work with that of all trades and subcontractors; and performing all Work in a safe and satisfactory manner.

**BETA GROUP, INC.**                      Checked By: BM  
 By: Mike Andrus                      Date: 10/15/2021

Additional Notes:

**Status Codes**

- 1-APP – No Exceptions Taken
- 2-ANR – Make Corrections Noted
- 3-R&R – Revise and Resubmit
- 4-REJ – Rejected
- 5-IPO – For Information Purposes Only
- 6-NRR – Not Required for Review
- ENG – Submitted to Engineer

Sincerely,  
 Hart Engineering Corporation

DATE: 10/12/2021



**EASTCOAST**  
erosion blankets

## MATERIAL SPECIFICATION

### **9Wattle** **9” Straw Wattle**

The 9” straw wattle shall be made with compacted agricultural straw compressed inside tubular polypropylene netting. Both ends shall be tied shut. The sediment control product shall have a nine inch diameter ( $\pm 10\%$ ). The wattle shall be in standard length of 20’-0” ( $\pm 10\%$ ), with other lengths available upon request. It shall weigh approximately 68 pounds ( $\pm 10\%$ ).

Wattles shall be packaged 5 per pallet. Each pallet shall be wrapped snugly in shrink film. The wattle shall be installed with wooden or metal stakes placed 4’-0” on center. They shall be tightly adjoined.

#### **MATERIALS:**

Fiber: 100% Straw Fiber  
3.4 lbs/sq yd

Netting: Tubular Black polypropylene  
Photodegradable

Closures: Metal Tie

