



5/21/2021 8:04 AM W:\YEAR - 2016\160809.00 - TAUNTON WWTF UPGRADES\PLUMBING DEPARTMENT\PHASE 2\160809.00 PLUMBING LEGEND SCHEDULES DETAILS PHASE 2.DWG (BETA STB BY STB)

### PLUMBING FIXTURE SCHEDULE

DESIGNATION	FIXTURE DESCRIPTION	CONNECTION SIZE							REMARKS
		WT	HWI	BLW	SNH	V	NPW1	RPHW1	
HB-1	HOSE BIBB	1/2"	-	-	-	-	-	-	-
HB-2	HOSE BIBB	1"	-	-	-	-	-	-	-
HB-3	HOSE BIBB	3/4"	-	-	-	-	-	-	DUAL TEMPERATURE - HOT AND COLD WALL FAUCET
EWU-1	EMERGENCY SHOWER/EYEWASH	-	-	1 1/4"	-	-	-	-	INTERIOR MOUNTED, CORROSION RESISTANT, EMERGENCY SHOWER/EYEWASH (COMBINATION UNIT) WITH HORN, STROBE AND FLOW SWITCH - DOOR CONTROL ROOM

### SUMP PUMP SCHEDULE

DESIGNATION	LOCATION	MODEL	CAPACITY (GPM)	HEAD (FEET)	TYPE	ELECTRICAL REQUIREMENTS				REMARKS
						RPM	HP	VOLTS	Φ	
4SP-1	SLUDGE PUMP STATION NO.1 PLAN	WEIL 2443	20	40	DUPLEX SUBMERSIBLE	1750	1/2	480	3	AUTOMATIC WITH FLOAT
4SP-2	SLUDGE PUMP STATION NO.2 PLAN	WEIL 2443	20	40	DUPLEX SUBMERSIBLE	1750	1/2	480	3	AUTOMATIC WITH FLOAT

### SHOCK ABSORBER SCHEDULE

PDM RATING SYMBOL	A	B	C	D	E
PRECISION PLUMBING PRODUCTS	SC-500	SC-750	SC-1000	SC-1250	SC-1500
WATTS REGULATOR COMPANY	0750030	0750053	0750060	0750070	0750090
WADE	5-P	10-P	20-P	50-P	75-P

\* MANUFACTURERS NAMES AND MODEL NUMBERS ARE SHOWN ONLY TO REPRESENT TYPE, STYLE AND LEVEL OF QUALITY EXPECTED, REFER TO SPECIFICATIONS FOR ACCEPTABLE EQUAL MANUFACTURERS.

### DRAIN SCHEDULE

DESIGNATION	TYPE	MANUFACTURER	MODEL	OUTLET	STRAINER	REMARKS
FD'A'	FD	J.R. SMITH	2005Y-A-PO50	NO HUB	NICK-BRZ	FINISHED AREAS
FD'B'	FD	J.R. SMITH	9700C-EFB4-HB	CAULK	NICK-BRZ	CLASSIFIED OR HAZARDOUS AREAS
FD'C'	FD	J.R. SMITH	2005Y-B-PO50	CAULK	NICK-BRZ	SHOWERS
RD'A'	RD	ZURN	Z121	NO HUB	CAST IRON DOME	REPLACE DRAIN TO ACCOMMODATE NEW ROOF

\* ALL FLOOR DRAINS SHALL BE PROVIDED WITH AUTOMATIC TRAP PRIMERS. REFER TO DETAIL FOR PIPING ARRANGEMENT.

\* MANUFACTURERS NAMES AND MODEL NUMBERS ARE SHOWN ONLY TO REPRESENT TYPE, STYLE AND LEVEL OF QUALITY EXPECTED, REFER TO SPECIFICATIONS FOR ACCEPTABLE EQUAL MANUFACTURERS.

PREPARED BY



REGISTERED PROFESSIONAL

SUBCONSULTANT



PROJECT

**Taunton Wastewater Treatment Facility Improvements Phase 2**

Taunton, MA

TITLE

Plumbing Schedules

NO. REVISIONS DATE

DRAWN BY: RLB

DESIGNED BY: RHB

CHECKED BY: RHB

ISSUE DATE: 10/16/2020

BETA JOB NO.: 6050

SCALE

NONE

UNLESS OTHERWISE NOTED OR CHANGED BY REPRODUCTION

**For Review Only**

SHEET NO.

P-0.2

















