

SHOP DRAWING REVIEW FORM AND TRANSMITTAL

DATE: October 18, 2021

TO: Carl Hendrickson
Project Manager
Veolia Water
825 West Water Street
Taunton, MA 02780

FROM: Michael Andrus, P.E.
Project Manager
BETA Group, Inc.
701 George Washington Hwy
Lincoln, Rhode Island 02865

RE: City of Taunton, MA
WWTF Solids Handling Improvements
Contract S-2020-3

Shop Drawing No. 02660-002 – Biofilter Media

BETA COMMENTS:

<u>Item</u>	<u>Action Code</u>	<u>Description/Comments</u>
1	3	Biofilter Media 1. Submitted media is too fine. Resubmit with coarser ground media.

Action Codes

- 1 - No Exception Taken
- 2 - Make Corrections Noted
- 3 - Amend and Resubmit
- 4 - Rejected, See Remarks

- a. Installation shall proceed only when Action Code is '1' or '2'.
- b. Submittals action coded '3' shall be resubmitted within time limit set in Contract.
- c. Review does not relieve Contractor from responsibility of compliance with the Contract Documents.



PROJECT: 9722. - Veolia/Taunton WWTP Solids Handling Improvements

DATE: 09/27/2021

SUBMITTAL: 02660-002 - Biofilter - Media Samples

REVISION: A

STATUS: New

SPEC #: 02660

TO:
Carl Hendrickson
 Veolia North America
 125 S. 84th Street, Suite 175
 Milwaukee, WI 53214
 carl.hendrickson@veolia.com

FROM:
Christiaan George
 Hart Engineering Corporation
 800 Scenic View Drive
 Cumberland, RI 02864
 cgeorge@hartcompanies.com

Item	Revision	Description	Status	Date Sent	Date Returned
02660-002	A	Biofilter - Media Samples			
Notes:			<div style="border: 2px solid red; padding: 5px;"> <p style="text-align: center; margin: 0;">SHOP DRAWING REVIEW</p> <p> <input type="checkbox"/> 1 - Approved <input type="checkbox"/> 2 - Approved as Noted <input checked="" type="checkbox"/> 3 - Revise and Resubmit <input type="checkbox"/> 4 - Rejected <input type="checkbox"/> 5 - Record File Only - No Action Taken </p> <p style="font-size: small; margin: 0;">(Above Check Designates Action Code - See Review Comments)</p> <p style="margin: 0;">IMPORTANT NOTE FOR CONTRACTOR</p> <p style="font-size: x-small; margin: 0;">Review is only for general compliance with the design concept and information provided in Contract Documents. Corrections and comments made on the Shop Drawings during review do not relieve the Contractor from compliance with the requirements of the plans and specifications. Review and/or approval of a specific item shall not include review or approval of an assembly of which the item is a component. No approval or correction of a Shop Drawing shall be construed as an order for extra work. The Contractor is responsible for: all quantities and dimensions to be confirmed and correlated; information that pertains solely to the fabrication processes or to the means, methods, techniques, sequences and procedures of construction; coordination of the Work with that of all trades and subcontractors; and performing all Work in a safe and satisfactory manner.</p> <p> BETA GROUP, INC. Checked By: <u>MLA</u> By: <u>Mike Andrus</u> Date: <u>10/18/21</u> </p> </div>		

Additional Notes:

Status Codes

- 1-APP – No Exceptions Taken
- 2-ANR – Make Corrections Noted
- 3-R&R – Revise and Resubmit
- 4-REJ – Rejected
- 5-IPO – For Information Purposes Only
- 6-NRR – Not Required for Review
- ENG – Submitted to Engineer

Sincerely,
 Hart Engineering Corporation

DATE: _____ 09/27/2021 _____